

Singapore Arts School Ltd
Co. Reg. No. 200500775C
1 Zubir Said Drive
Administration Office #05-01
Singapore 227968

Tel: 6338 9663
Fax: 6338 9763

Our Ref: **SAS/OP/2026/001/T**

3 June 2026

Dear Sir/Mdm,

INVITATION TO TENDER (ITT) FOR THE PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT SCHOOL OF THE ARTS, SINGAPORE (ITT REFERENCE NO: SAS/OP/2026/001/T)

- Singapore Arts School Ltd. (SAS)**, the company that manages the **School of the Arts, Singapore (SOTA)**, governed by the Ministry of Culture, Community and Youth (MCCY), invites proposals for the **Tender for the Provision of Dehumidifier System and Installation Works for Level 7 and Level 9 (corridor areas serving music classrooms) at School of the Arts, Singapore at 1 Zubir Said Drive, Singapore 227968** as described in the attached documents.
- You must submit your proposal and any accompanying information to our **Tender Submission Box 2** at Level 2, beside Security Counter at 1 Zubir Said Drive, Singapore 227968 by **24 June 2026, 1400 hours Singapore Time**. All late and/or incomplete submissions will be disqualified.
- The documents enclosed in this ITT include:
 - Schedule 1 : Instruction to Tenderers
 - Schedule 2 : Form of Tender
 - Schedule 3 : Schedule of Price
 - Annex A : Conditions of Contract
 - Annex B : Specification of Works
 - Annex C : Scope of Services
 - Annex D : Selection Criteria
 - Annex E : Statement of Compliance

Singapore Arts School Ltd
Co. Reg. No. 200500775C
1 Zubir Said Drive
Administration Office #05-01
Singapore 227968

Tel: 6338 9663
Fax: 6338 9763

- (i) Annex F : Non-Disclosure Agreement to Safeguard Official Information
(refer to Point 10 for more details)
 - (j) Appendix 1 : House Rules
 - (k) Appendix 2 : Floor Plan for Level 7 and Level 9
 - (l) Appendix 3 : Temperature and Humidity Data Logger
4. The Invitation to Tender must be submitted by the Tenderer's authorised representatives.
 5. The **Online Tender Briefing** for the tender requirements and document submission is **mandatory** and will be held on **10 June 2026, 1030 hours Singapore Time** via Microsoft Teams video conferencing.
 6. A **Site-show session** is **mandatory** for tenderers to understand the requirement specifications at our school compound on **11 June 2026, at 1000 hours Singapore Time** onwards at 1 Zubir Said Drive, Level 2 Security Counter.
 7. Attendance is **mandatory** for both the **Online Tender Briefing** and the **Site-show Session** in order to participate in the Tender.
 8. Tenderers must fill in the registration form (<https://forms.gle/jFVBrCnamQDZnQjDA>) to confirm their attendances for the Online Tender Briefing and Site-show Session no later than **9 June 2026, 1400 hours Singapore Time**.
 9. Details of the Microsoft Teams Meeting for the **Online Tender Briefing** will be provided after we receive your registration.
 10. Tenderers are required to submit duly filled **Annex F: Non-Disclosure Agreement to Safeguard Official Information** through email: procurement@sota.edu.sg in order to retrieve the Appendix 2: Floor Plan for Level 7 and Level 9 during the **Site-show session**.

Singapore Arts School Ltd
Co. Reg. No. 200500775C
1 Zubir Said Drive
Administration Office #05-01
Singapore 227968

Tel: 6338 9663
Fax: 6338 9763

11. All enquiries regarding this Invitation to Tender should be made in writing and directed to:
 - (a) Tender Matters : Ms Lisa Yao, Direct line: 6594 8413
Email : procurement@sota.edu.sg
 - (b) Requirement Specifications : Ms Sabrian Ang, Direct line: 6594 8462
Email : sabrina.ang@sota.edu.sg
12. No oral representation must be binding on SAS or construed as varying or adding to any part of this Invitation to Tender.
13. SAS accepts only original Tender Documents Submission and strictly without any alteration to the content and format.
14. Only shortlisted Tenderers will be invited for a presentation.

Yours sincerely

(No Signature Required)

Lisa Yao,

BUYER, OFFICE OF PROCUREMENT for CHIEF EXECUTIVE OFFICER
SINGAPORE ARTS SCHOOL LTD



TENDER FOR

**PROVISION OF DEHUMIDIFIER SYSTEM AND
INSTALLATION WORKS AT SCHOOL OF THE
ARTS, SINGAPORE**

Name of Tenderer : _____

Closing Date/Time : **24 JUNE 2026 at 1400 hours**

Submit To : **Tender Submission Box 2
Level 2, Beside Security Counter**

TABLE OF CONTENTS

		<u>PAGE</u>
SCHEDULE 1.	INSTRUCTION TO TENDERERS	IT/1 to IT/11
SCHEDULE 2.	FORM OF TENDER	FOT/1 to FOT/3
SCHEDULE 3.	SCHEDULE OF PRICE	SOP/1 to SOP/2
ANNEX A.	CONDITIONS OF CONTRACT	COC/1 to COC/20
ANNEX B.	SPECIFICATION OF WORKS	SOW/1 to SOW/5
ANNEX C.	SCOPE OF SERVICES	SOS/1 to SOS/17
ANNEX D.	SELECTION CRITERIA	SC/1
ANNEX E.	STATEMENT OF COMPLIANCE	SOC/1 to SOC/10
ANNEX F.	NON-DISCLOSURE AGREEMENT TO SAFEGUARD OFFICIAL INFORMATION	NDA/1
APPENDIX 1.	HOUSE RULES	HR/1 to HR/6
APPENDIX 2.	FLOOR PLAN FOR LEVEL 7 AND LEVEL 9	FP/1 to FP/4
APPENDIX 3.	TEMPERATURE AND HUMIDITY DATA LOGGER	PAGE 1 to PAGE 108

Schedule 1:
INSTRUCTION TO TENDERERS

**TENDER FOR THE PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT
SCHOOL OF THE ARTS, SINGAPORE**

INSTRUCTION TO TENDERERS

1. The Tender Submission MUST comprise the following Tender documents:
 - a) Schedules 1, 2, and 3;
 - b) Annexes A, B, C, D, E and F;
 - c) Appendices 1, 2 and 3;
 - d) The submission **must include proposal** and should have the following (refer to SOS/11, Point 7.22):
 - i. Proposed layout drawings indicating the location and quantity of dehumidifier units;
 - ii. Equipment arrangement and installation details (ceiling/wall mounting, enclosure concept, etc.);
 - iii. Schematic diagram showing system configuration and condensate drainage routing;
 - iv. Indicative control strategy and sensor locations;
 - v. Preliminary equipment sizing calculations or design basis;
 - vi. Contractor must clearly indicate equipment model, capacity, and quantity in tabulated format.
 - e) Relevant certifications (where applicable);
 - f) Company Profile;
 - g) Client Track Records for past three (3) years;
 - h) Two (2) most recent Audited Financial Statements or Latest Statement of Accounts.
2. Tenderers must submit **two (2) full sets** of Tender documents in hardcopy. One (1) set is to be marked "Original" and the other marked "Duplicate" and endorsed with **company stamp and authorised signatory on every page.**
3. Tender documents must be submitted to the "**TENDER SUBMISSION BOX 2**" located **at Level 2, beside Security Counter by 24 June 2026 (1400 hours)** in sealed envelope(s) with the following marked:

"TO: OFFICE OF PROCUREMENT

**TENDER FOR PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT
SCHOOL OF THE ARTS, SINGAPORE**

TENDER REFERENCE: SAS/OP/2026/001/T

School of the Arts, Singapore
1 Zubir Said Drive Administration Office #05-01
Singapore 227968"

4. All Tender documents appended with conditions other than those set out herein and/or at variance thereto shall be invalidated.
5. Any items which the Tenderer considers to have no value must be marked with dashes or other suitable marks placed against them in the cash columns. Any items not priced and without dashes or other suitable marks must be deemed to be no value.

6. Incomplete Tender submissions or submissions which are found not meeting the full requirements of the Tender will not be considered.
7. Any doubt as to the meaning of any part of these Tender documents may be clarified with SAS's representative. SAS is hereinafter known as the "Company".
8. Tenderers shall note that the award of the Contract may not necessarily be based on the lowest quotation of any proposal and any claims for expenses incurred in the preparation of this Tender will not be entertained. The Company may choose to award the Tender in whole or in parts.
9. All Tenders submitted must be deemed to be valid for a period of ninety (90) days from the date of submission thereof.
10. Before the submission of their Tenders, Tenderers must attend the Online Tender Briefing and Site-show to acquaint themselves thoroughly with the requirements, conditions and all aspects of the Tender which may affect the works under this contract. Any unforeseen difficulties and works for which provision has not been made in the Tender price quoted will under no circumstance relieve the Tenderers from the full performance of this Contract.
11. Tenderers are also reminded that the Specification of Works (Annex B) and Scope of Services (Annex C) attached herein must be strictly adhered to unless otherwise specified by SAS that alternative proposals are accepted.
12. A "NIL" return of the Tender submission is not accepted.
13. The Contract Sum submitted excludes any Goods and Services Tax (hereinafter referred to as GST) under the Goods and Services Tax Act Singapore.

CONFIDENTIAL

PARTICULARS OF TENDERER

All sections are mandatory to fill up.

Note: From IT/3 onwards, if the space provided is insufficient, please continue on an extension page setting out the required data in a similar manner.

1. **REGISTERED BUSINESS NAME AND ADDRESS OF FIRM/COMPANY**

Full Business Name :
Registered Address :
Correspondence Address :
Telephone Number :
Fax Number :
GST Registration : Yes/No (please circle one)
GST Registration No. :
Date and Number of Business Registration :
Date of Incorporation :
Form of Business :
Name (as in NRIC/FIN) and Designation of Authorised Representative :

2. **CAPITAL**

- a) If Partnership to state the capital set aside for business;

Capital Set Aside:

- b) If Limited Company, to state the authorised and paid-up capital;

Paid-up Capital:

- c) Extracted from two (2) most recent Audited Financial Statements or Latest Statement of Accounts.
- i. Company with an annual revenue less than Singapore Dollars five million (S\$5,000,000.00), to submit company endorsed Statement of Account;
 - ii. Company with an annual revenue Singapore Dollars five million (S\$5,000,000.00) or more, to submit Audited Financial Statement.

Latest Audited Financial Statements/Statements of Account

Please submit Audited Financial Statements or Statements of Account.

ANNUAL REPORT YEAR AND DESCRIPTIONS	FINANCIAL YEAR 20__	FINANCIAL YEAR 20__
Paid-Up Capital (S\$)		
Current Assets (S\$)		
Current Liabilities (S\$)		
Non-Current Assets (S\$)		
Non-Current Liabilities (S\$)		
Total Revenue (S\$)		
Net Profit/Loss (S\$)		

3. **REGISTRATION WITH GOVERNMENT SUPPLIER REGISTRATION (GSR)/BUILDING AND CONSTRUCTION AUTHORITY (BCA) - REGISTRATION SYSTEM INFORMATION**

GSR HEAD/BCA REGISTRATION (WITH DATE OF EXPIRY IF APPLICABLE)	HEAD TITLE/BCA WORKHEAD(S)	FINANCIAL CATEGORY/BCA GRADE

4. **DEBARMENT/SUSPENSION/PROHIBITION (OR ANY FORM OF EXCLUSION OR EQUIVALENT, IF ANY)**

NAME OF AUTHORITY/REGULATORY BODY OR EQUIVALENT	REASONS FOR DEBARMENT/SUSPENSION/PROHIBITION OR ANY FORM OF EXCLUSION OR EQUIVALENT, IF ANY	EFFECTIVE DATE OF DEBARMENT/SUSPENSION/PROHIBITION OR ANY FORM OF EXCLUSION OR EQUIVALENT, IF ANY	
		FROM DD/MM/YYYY	TO DD/MM/YYYY

5. **DETAILED PARTICULARS OF PARTNERS/COMPANY DIRECTORS**

FULL NAME/DESIGNATION	WORKING EXPERIENCE

6. **PARTICULARS AND EMPLOYMENT HISTORY OF PROFESSIONAL/SUPERVISORY/TECHNICAL STAFF**

	S/NO	NAME	QUALIFICATION	INSTITUTION	YEAR AWARDED	RELEVANT WORKING EXPERIENCE IN THE LAST FIVE (5) YEARS (WITH POSITION HELD AND RESPONSIBILITIES)
1						
<u>PROFESSIONAL</u> Degree Holder or equivalent						
2						
<u>SUPERVISORY</u> Diploma Holder or equivalent						
3						
<u>TECHNICAL</u> Trade Certificate Holders						

If space provided above is insufficient, please continue on an extension page setting out the required data in a similar manner.

7. **CONTRACTS SECURED IN THE LAST THREE (3) YEARS (EXCLUDE PROJECTS MENTIONED IN SECTION 8, IT/9)**

S/N	PROJECT TITLE AND DESCRIPTION OF PROJECT#	CLIENT (ORGANISATION, DEPARTMENT AND ADDRESS)	DURATION AND VALUE OF CONTRACT (\$)	DATE OF COMMENCEMENT AND COMPLETION (DD/MM/YYYY TO DD/MM/YYYY)	OFFICER-IN-CHARGE (JOB TITLE, DESIGNATION, EMAIL, TELEPHONE AND FAX NO.)
Project/s of similar service and scale					
Other Project/s					

*If space provided above is insufficient, please continue on an extension page setting out the required data in a similar manner.
With reference to Firm/Company stated in Page IT/3, Section 1.*

8. **DETAILS OF CURRENT PROJECTS IN PROGRESS OR DUE TO BE EXECUTED (EXCLUDE PROJECTS MENTIONED IN SECTION 7)**

S/N	PROJECT TITLE AND DESCRIPTION OF PROJECT#	CLIENT (ORGANISATION, DEPARTMENT AND ADDRESS)	DURATION AND VALUE OF CONTRACT (S\$)	DATE OF COMMENCEMENT AND COMPLETION (DD/MM/YYYY TO DD/MM/YYYY)	OFFICER-IN-CHARGE (JOB TITLE, DESIGNATION, EMAIL, TELEPHONE AND FAX NO.)
Project/s of similar service and scale					
Other Project/s					

*If space provided above is insufficient, please continue on an extension page setting out the required data in a similar manner.
With reference to Firm/Company stated in Page IT/3, Section 1.*

9. **CONTACT DETAILS FOR REFERENCE CHECK**

S/N	PROJECT TITLE AND DESCRIPTION OF PROJECT#	CLIENT (ORGANISATION, DEPARTMENT AND ADDRESS)	DURATION AND VALUE OF CONTRACT (S\$)	OFFICER-IN-CHARGE (NAME AND DESIGNATION)	OFFICER-IN-CHARGE (EMAIL)	OFFICER-IN-CHARGE (TELEPHONE NO.)

*If space provided above is insufficient, please continue on an extension page setting out the required data in a similar manner.
With reference to Firm/Company stated in Page IT/3, Section 1.*

10. **DECLARATION**

I/We declare that the information provided in this offer (including the prescribed forms) are correct and true. Should there be any false statement, I/We understand that our Tender will be invalidated or if already awarded will be immediately terminated without prejudice to the Company's right to claim damages.

I/We hereby undertake to inform the Company of any changes of partnership/director or firm/company taking place during the term of the Contract.

I/We agree that SAS may conduct reference checks with any of our past and existing clients that I/we have provided in Section 7, 8 and 9.

NAME AS IN NRIC/FIN AND SIGNATURE

DATE

(AUTHORISED REPRESENTATIVE)

COMPANY STAMP

IMPORTANT NOTES:

- (a) All items in Schedules 1, 2, 3, Annexes E and F must be filled. Any items which are not applicable should be clearly stated. Incomplete forms shall render the Tender to be rejected;
- (b) All forms submitted must be signed by an Authorised Representative with company stamp and signatory on every page. The Authorised Representative must be the partner or director of the firm/company and legally empowered to act and endorse on behalf of the firm/company;
- (c) For a Partnership Firm, the forms must be accompanied by the latest copy of computer information (Business Profile) from the Accounting and Corporate Regulatory Authority (ACRA);
- (d) For a Limited Company, the forms must be accompanied by a Memorandum and Articles of Association and the latest copy of computer information (Business Profile) from ACRA;
- (e) Tenderer who fails to attach items as specified in (c) and (d) as indicated above and any other required supporting documents may render the Tender to be rejected.

Schedule 2:
FORM OF TENDER

FORM OF TENDER

TO: SINGAPORE ARTS SCHOOL LTD.

TENDER (ITT) FOR THE PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT SCHOOL OF THE ARTS, SINGAPORE

1. I/We, the undersigned having visited the site, hereby submit this Tender For the **Provision of Dehumidifier System and Installation Works for Level 7 and Level 9 (corridor areas serving music classrooms) at School of the Arts, Singapore** as specified in this Tender document in accordance with the Conditions of Contract (Annex A), Specification of Works (Annex B), Scope of Services (Annex C) and Statement of Compliance (Annex E) attached hereto, to the entire satisfaction of the Company.

2. My/Our Total Tender for the Contract is for Total Amount ("the Contract Sum") of Singapore Dollars:

_____ (S\$ _____)

*(*Amount brought forward from Schedule 3 - Schedule of Price, SOP/1, Total Contract Sum. The Contract Sum is deemed to exclude the Goods and Services Tax "GST".)*

3. Until a formal Contract is executed, this Tender together with your written acceptance thereof, will constitute a binding contract between us.
4. I/We understand that you are not bound to accept the lowest of any submitted Tender you may receive.
5. I/We further undertake that this offer will not be retracted or withdrawn for a period of ninety (90) days from the date fixed for receiving the same and it will remain binding upon me/us, and may be accepted or rejected at any time before the expiration of that period.
6. I/We understand that the Contract Period will commence within ninety (90) days of the Tender validity.
7. I/We understand that the actual commencement date will be stated accordingly in the Company's Letter of Acceptance.
8. I/We understand that if my/our Tender is accepted, I/We will provide insurance coverage to indemnify the Company against all liabilities or claims for damages and/or injuries to my/our workmen and public as follows :

Insurance Coverage

a) Public Liability Policy :

- i) In respect of any one accident, the sum of at least Singapore Dollars one million only (S\$1,000,000.00);
- ii) For any one accident and for an unlimited number of accidents;
- iii) Must be taken out and maintained at my/our cost and expense in the joint names of the Company and myself/ourselves with a reputable insurance company in Singapore;
- iv) Singapore Arts School Limited must be clearly specified as part of the covered party whilst the contract is still valid; and

- v) Coverage for damage to Persons and Property.
 - b) Workmen's Compensation Policy in accordance with Work Injury Compensation Act.
 - i) I/We shall at all times observe and ensure compliance with Workplace Safety and Health Act, Work Injury Compensation Act, including all other applicable laws, regulations and requirements of any government or regulatory authority relating to safety, and bear all costs and expenses connected with the observance and compliance of the same.
 - c) Industrial All Risks Insurance
 - i) Covering all physical loss or damage to the works, the school building, equipment, and related assets, including but not limited to materials, machinery, and temporary structures.
 - ii) Singapore Arts School Limited must be clearly specified as part of the covered party whilst the contract is still valid.
 - d) The insurance coverage is to be purchased from an insurance company approved by the Company within fourteen (14) days from the date of the Letter of Acceptance.
9. I/We warrant that I/We have obtained and will at all times during the subsistence of the Contract (including any renewal thereof) maintain all necessary licenses, approvals, permits, consents and/or other authorisation required by the Tender in order to fully perform and complete the works.
 10. I/We will at all times observe and ensure compliance with Workplace Safety and Health Act, Work Injury Compensation Act, including all other applicable laws, regulations and requirements of any government or regulatory authority relating to safety, and bear all costs and expenses connected with the observance and compliance of the same.
 11. I/We agreed that if my/our Tender offer is accepted, I/we undertake to commence the Services on the dates specified in the Company's Letter of Acceptance.
 12. I/We understand that the Contract Sum shall be paid to the Contractor based on the payment terms specified in Annex A - Conditions of Contract, COC/10, clause 4.
 13. I/We have not included any allowance in this Tender for payment to other Tenderers or to any Trade, Industry or Professional organisation acting independently or for or on behalf of any or all Tenderers.
 14. I/We have read and understood all Specification of Works (Annex B), Scope of Services (Annex C) and Statement of Compliance (Annex E) and their relation to the Schedule of Price (Schedule 3) and confirm that this Total Amount as quoted in the Form of Tender (FOT/1, Point 2) shall include all items related to the documents as stated above.
 15. I/We offer to provide the Works, Equipment, Products and Services at the prices submitted in the Tender based on the terms and conditions as stated in the Tender Documents.
 16. I/We agree, in the event of this Tender being accepted by the Company, until a formal Contract is prepared and executed between us, to be bound by and to observe and perform all the covenants and obligations on my/our part respectively contained in this Tender submission, together with the Company's written acceptance thereof and notification of award.
 17. The Company reserves the absolute right to amend the required item(s) before or during the Contract Period or to terminate this Contract by serving to the Tenderer, thirty (30) days prior notice in writing.

NAME AS in NRIC/FIN
AND SIGNATURE

NAME AND
SIGNATURE
(WITNESS)

(AUTHORISED
REPRESENTATIVE) : _____

: _____

DESIGNATION
(AUTHORISED
REPRESENTATIVE) : _____

DESIGNATION
(WITNESS) : _____

DATE : _____

DATE : _____

COMPANY NAME
AND
COMPANY STAMP : _____

Schedule 3:
SCHEDULE OF PRICE

SCHEDULE OF PRICE**PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT SCHOOL OF THE ARTS, SINGAPORE**

The tendered price shall cover the provision of insurance coverage, labour, tools, machinery, levies, fees, permits, equipment, materials and accessories required for the Works.

The correct details of my/our offer for the proposed Provision of Dehumidifier System and Installation Works, inclusive of preliminaries and profit, in accordance with the Conditions of Contract (Annex A), Specification of Works (Annex B), Scope of Services (Annex C) and Selection Criteria (Annex D), are as follows:

S/N	Description	Qty	Amount (S\$)
1.	Provision of Dehumidifier System and Installation Works for Level 7 and Level 9 (corridor areas serving music classrooms) at School of the Arts, Singapore Scope of Services: Engineering calculations and submission of detailed proposal; supply and installation of complete dehumidification system. Includes Builder's Works (wall openings, penetrations, fire-stopping, making good and reinstatement); Electrical Works (power supply, cabling, trunking, isolators, containment and connections); fabrication and installation of equipment housing with ventilation louvres; testing and commissioning, documentation, Operation & Maintenance (O&M) manuals, as-built drawings, training, Defects Liability Period (DLP) and quarterly preventive maintenance for the following (refer to SOS/3, Point 5.2, Table A, S/N 7):		
i	Supply and Installation - Phase 1: Level 7 - Electronic Music Studio (1 room)	1 lot	
ii	Supply and Installation - Phase 2: Level 9 - EPR1 to EPR3 (3 rooms)	1 lot	
iii	Supply and Installation - Phase 3: Level 9 - MPR1 to MPR9 and EPR4 to EPR9 (15 rooms)	1 lot	
Total Contract Sum (S\$) Excluding nine percent (9%) GST			
To be carried forward to Form of Tender FOT/1, Point 2			

IMPORTANT NOTES:

All prices submitted are in accordance to the corresponding Schedules, Annexes and Appendices. All details must be verified by the Tenderer before tender submission.

I/We fully understand and agree that the Contract Sum quoted herein is deemed to include all obligations applicable under the Conditions of Contract (Annex A), Specification of Works (Annex B), Scope of Services (Annex C) and Selection Criteria (Annex D).

Dated this _____ day of _____ 2026

NAME AND
SIGNATURE
(AUTHORISED
REPRESENTATIVE) : _____

NAME AND
SIGNATURE
(WITNESS) : _____

DESIGNATION
(AUTHORISED
REPRESENTATIVE) : _____

DESIGNATION
(WITNESS) : _____

DATE : _____

DATE : _____

COMPANY NAME
AND
COMPANY STAMP : _____

Annex A:
CONDITIONS OF CONTRACT

DATED THIS ____ DAY OF ____ 2026

BETWEEN

SINGAPORE ARTS SCHOOL LTD
(the "Company")

(the "Contractor")

CONTRACT

(Tender reference: SAS/OP/2026/001/T)

CONTENTS

1. DEFINITIONS AND INTERPRETATION
2. APPOINTMENT AND SCOPE OF CONTRACT
3. DUTIES AND OBLIGATIONS OF CONTRACTOR
4. CONTRACT SUM
5. COMMENCEMENT OF WORKS
6. POWER TO ENGAGE OTHER CONTRACTORS
7. COMPLETION DATE
8. DEFECTS LIABILITY PERIOD
9. INTELLECTUAL PROPERTY
10. TERMINATION
11. SUSPENSION
12. INDEMNITY AND INSURANCE
13. FORCE MAJEURE
14. NOTICES
15. WAIVER
16. SEVERABILITY
17. ENTIRE AGREEMENT AND MODIFICATION
18. NO PARTNERSHIP
19. SUB-CONTRACT AND ASSIGNMENT
20. COSTS
21. CONFIDENTIALITY
22. VARIATION
23. COUNTERPARTS
24. CONTRACTS (RIGHTS OF THIRD PARTIES) ACT
25. GOVERNING LAW AND JURISDICTION

SCHEDULE 1	:	INSTRUCTION TO TENDERERS
SCHEDULE 2	:	FORM OF TENDER
SCHEDULE 3	:	SCHEDULE OF PRICE
ANNEX A	:	CONDITIONS OF CONTRACT
ANNEX B	:	SPECIFICATION OF WORKS
ANNEX C	:	SCOPE OF SERVICES
ANNEX D	:	SELECTION CRITERIA
ANNEX E	:	STATEMENT OF COMPLIANCE
ANNEX F	:	NON-DISCLOSURE AGREEMENT TO SAFEGUARD OFFICIAL INFORMATION
APPENDIX 1	:	HOUSE RULES
APPENDIX 2	:	FLOOR PLAN FOR LEVEL 7 AND LEVEL 9
APPENDIX 3	:	TEMPERATURE AND HUMIDITY DATA LOGGER

THE CONTRACTOR'S TENDER DOCUMENT DATED _____
 THE COMPANY'S ITT DOCUMENT REF SAS/OP/2026/001/T

THIS CONTRACT ("**Contract**") is made on the ____ day of ____ 2026.

BETWEEN:

- (1) **SINGAPORE ARTS SCHOOL LTD.** (Company Registration No. 200500775C), a company incorporated in Singapore and having its registered address at 1 Zubir Said Drive, #05-01, Singapore 227968 (the "**Company**"); and
- (2) _____ (Company Registration No. _____), a company incorporated in Singapore and having its registered address at _____ (the "**Contractor**"),
(each a "**Party**" and together the "**Parties**").

WHEREAS:

- (A) The Company operates and manages the School of the Arts, Singapore (the "**Arts School**"), a specialised pre-tertiary arts school established by the Ministry of Culture, Community and Youth (MCCY).
- (B) On _____, the Company invited proposals for the Tender for the Provision of Dehumidifier System and Installation Works at School of the Arts, Singapore.
- (C) The Company has agreed to engage the Contractor to perform the Works (as defined below) based on the terms and conditions contained herein.
- (D) This Contract shall comprise of and, in the event of any conflict, inconsistency or discrepancy, shall be in the following order of precedence:
 - i) This Contract;
 - ii) The Contractor's Submission dated: _____;
 - iii) The Company's tender document ref: SAS/OP/2026/001/T.

THE PARTIES HEREBY agree as follows:

1. DEFINITIONS AND INTERPRETATION

1.1 In this Contract, the following words have the following meanings unless inconsistent with the context:

"Authorised Representatives"	Representatives of the Contractor who are authorised by the Company in writing from time to time.
"Authorities"	Relevant authorities who have jurisdiction over the Works whether temporarily or permanently.
"Business Day"	A day (excluding Saturdays, Sundays and public holidays) on which banks generally are open in Singapore for the transaction of normal banking business.
"Confidential Information"	All information of a confidential nature relating to the Company or the Arts School, including without limitation, marketing plans, business strategies, financial information and forecasts, personnel information and other information concerning the Company's and the Arts School's operations and plans. For the purpose of this definition, information which is regarded as confidential includes any document marked "confidential" or any information which the Contractor is told or is aware is confidential, or which the Company might reasonably regard as confidential.
"Contract"	Means the Contract Agreement, together with the tender documents referred to therein including the Instructions to Tenderers, Form of Tender, Conditions of Contract, Scope of Works, Specification of Works, Statement of Compliance, Letter of Acceptance and all these documents taken together shall be deemed to form the Contract.
"Materials"	Such software programs, equipment, system, hardware, apparatus, manuals and/or other goods to be delivered to the Company by the Contractor in connection with carrying out the Works.
"SAS Authorised Personnel"	Representative who shall be nominated by the Company to be in charge of supervising the Works.
"Site"	The site on the Company's premises where the Works are to be carried out.
"Works"	The Specification of Works as set out in Annex B.
"Services"	The Scope of Services as set out in Annex C.

- 1.2 The headings to the clauses of and schedules to this Contract are for convenience only and shall not affect the construction or interpretation thereof.
- 1.3 References to a statute or statutory provision shall, unless the context otherwise requires, include a reference to that statute or statutory provision as from time to time amended, modified, extended, re-enacted, consolidated and all statutory instruments or orders made pursuant to it whether replaced before or after the date of this Contract.
- 1.4 Any reference in this Contract to a "Clause", "Schedule", "Appendix" or "Annex" is a reference to a clause of or schedule to or annex to this Contract.
- 1.5 Unless the context otherwise requires, references to the singular number shall include references to the plural number and vice versa, references to natural persons shall include bodies corporate, and the use of any gender shall include all genders.

2. APPOINTMENT AND SCOPE OF CONTRACT

- 2.1 The Company hereby appoints the Contractor to carry out the Works and provide the Materials, and the Contractor hereby accepts such appointment, upon the terms and conditions hereinafter set forth.
- 2.2 The Contractor shall carry out and complete the Works in accordance with the directions and to the satisfaction of the SAS Authorised Personnel, and agrees that the SAS Authorised Personnel shall be entitled to order:
- (a) Any variation or modification of the design, quality or quantity of the Works and/or the addition or omission or substitution of any Works;
 - (b) The removal from the Site and replacement of any material brought thereon by the Contractor;
 - (c) The removal and/or re-execution of the Works or any part thereof executed by the Contractor; and
 - (d) The making good of any defects in the Works.
- 2.3 The Contractor shall be deemed to have ascertained for itself the nature and full extent of the Works comprised in this Contract and to have satisfied itself, at its own cost and expense, as to the correctness and sufficiency of its Proposal and Tender. The Company shall not be liable to the Contractor for any claims arising from the Contractor's default in ascertaining for itself any information with regard to its obligations or from any increase in costs and expenses as a result thereof.

3. DUTIES AND OBLIGATIONS OF CONTRACTOR

3.1 Performance of Works

- (a) The Contractor shall:
 - (i) Carry out the Works in a diligent and expeditious manner;
 - (ii) Ensure that the Materials provided are of a consistently high quality; and
 - (iii) At all times act with the utmost good faith towards the Company and use its best endeavours to anticipate the needs of the Company and the Arts School and be creative, responsive and proactive towards such needs.
- (b) The Contractor acknowledges that it is and shall remain personally liable for the consequences of any failure on its part, or the part of any third party appointed, to carry out the Works in accordance with the terms of this Contract.
- (c) The Contractor's representative will be required to attend all meetings as called by the Company from time to time to ensure the smooth carrying out of the Works.
- (d) The Contractor shall carry out the Works with the minimum of noise and no nuisance in any form shall be created.
- (e) The Contractor shall arrange for the conveyance of his materials, plant etc. so as to cause a minimum of damage to existing properties. The Contractor shall be held responsible for any damage caused by his lorries, agents, tools or plants to any property from whatsoever cause arising and shall maintain, repair and reinstate the same to its original condition to the satisfaction of the Company.

3.2 Compliance

- (a) The Contractor shall ensure that the execution of the Works complies with all relevant laws, regulations, rules, orders and bye-laws and shall give such notices as may be necessary to the authorities in connection with the Works.
- (b) The Contractor shall at its own cost ensure that all licences, authorisations and permits necessary to enable the Contractor to fulfil all its obligations under this Contract have been obtained and are in full force and effect for the duration of this Contract, and that all conditions applicable to any such licence, authorisation or permit have been and will be complied with. The Contractor shall indemnify and keep the Company indemnified from any penalties, fines or claims resulting from the failure by the Contractor to (i) obtain and maintain any such licences, authorisations and permits, or (ii) comply with the conditions applicable to such licences, authorisations and permits. The Contractor shall submit copies of all licences, authorisations and permits obtained to the Company for the Company's records.
- (c) The Contractor further undertakes to ensure that all statutory and regulatory requirements relating to, inter alia, the immigration status of the workers, employees

or agents conducting the Works shall be fully complied with. The Contractor shall be held fully and solely liable for and shall indemnify the Company and SAS Authorised Personnel in respect of all actions taken against the Company and SAS Authorised Personnel for employing foreign workers without valid permits.

- (d) In the event of default being made in the payment of any monies in respect of wages and/or Central Provident Fund contributions of any workmen employed by the Contractor in and for the performance of this Contract, and if a claim therefor is filed with the Ministry of Manpower, and proof thereof is furnished to the satisfaction of an officer of the said Ministry, the Company may, failing the payment of the said monies by the Contractor, make payment of such claim to the said Ministry out of any sums due or to become due to the Contractor.
- (e) The Contractor shall implement and comply with all rules and regulations, safety requirements and security requirements notified to it by the Company or any relevant authorities.

3.3 Safety

- (a) The Contractor shall comply with all relevant laws, regulations and requirements of all relevant authorities in relation to occupational health and safety, including but not limited to the Workplace Safety and Health Act (Cap. 354A), the Workplace Safety and Health (General Provisions) Regulations, the Environmental Protection and Management Act (Cap. 94A) and the Environmental Public Health Act (Cap. 95).
- (b) The Contractor shall take every reasonable precaution to ensure the safety of the Company and any other person at the Site or in the vicinity of the Site whilst the Works are being carried out, including but not limited to displaying warning and/or caution signs at prominent locations around the Site and cordoning off the Site whilst the Works are being carried out.
- (c) The Contractor shall put up suitable new closed-boarded perimeter twenty (20) millimetres thick plywood hoarding to ceiling height, temporary secure escape doors and exit signs to give sufficient protection and enclosure and ensure that rules and regulations relating to means of escapes are complied with.
- (d) The Contractor shall provide, maintain and remove such temporary hoardings and gantries when no longer required or directed by the Company and make good all areas affected by the temporary work.
- (e) All hoardings must be painted with two (2) coats of selected emulsion paint to the approval of the Company and with signs stating "Construction Work in Progress", "Sorry for the Inconvenience Caused" and "Expected Date of Completion" etc. to the approval of the Company.
- (f) The Contractor shall put up suitable warning signs in the four official languages of the Republic of Singapore at all access points to the site to safeguard against trespassing by unauthorised persons.

- (g) The Contractor shall prepare and submit a full risk management plan to the satisfaction of the Company. The Contractor shall monitor and update the plan on a regular basis.

3.4 Premises, Materials and Equipment

(a) Contractor to provide everything necessary

The Contractor shall provide and do everything necessary for the proper execution of the Works.

(b) Materials

- (i) All materials and equipment used in carrying out the Works shall be new and so far as procurable be of best of the respective kinds described in the Specifications and the Contractor shall upon the request of the SAS Authorised Personnel furnish him with vouchers to prove that the materials comply therewith. The Contractor shall arrange for and/or carry out any test of any materials or equipment which the SAS Authorised Personnel may in writing require and the cost thereof shall be added to the Contract Sum (as defined below) unless provided for in the Specifications by way of provisional sum or otherwise or unless the test shows that the said materials and/or equipment are not in accordance with the Specifications.
- (ii) The Contractor shall remain liable for any breach of clause 3.4(b)(i) notwithstanding that the Company has accepted the Works as having been satisfactorily executed or completed.
- (iii) Samples of materials are to be supplied free of charge to the Company at the Company's instruction for approval before such materials are built or incorporated into the Works.
- (iv) All materials shall be transported, handled and properly stored on site in such a manner as to minimise and prevent damage, deterioration or contamination etc.
- (v) All materials that are old, deteriorated, damaged, contaminated or not equal to approved sample or specification will be rejected and shall be removed from the Site at the Contractor's own expense.
- (vi) The Contractor shall place its orders for all materials at the earliest possible date after award of the Contract and shall be held responsible for any delay occasioned by its failure to do so.

(c) Unfixed materials

Where the Contractor has received payment in respect of any unfixed materials intended for incorporation in the Works and placed on or adjacent to the Site, such materials, the loss of or damage of which shall be the Contractor's responsibility, shall

not be removed (except for use in connection with the Works) without the prior written consent of the SAS Authorised Personnel.

(d) Protection of premises and property

The Contractor shall be responsible for any damage or loss that may occur to the premises of the Arts School and any property situated thereon or otherwise belonging to the occupiers of or visitors to the Arts School, which occurs as a result of, whether directly or indirectly, the carelessness, negligence, default or otherwise of the Contractor or persons employed by it in the performance of their duties. Any such damage or loss shall be made good or replaced by the Contractor to the satisfaction of the SAS Authorised Personnel or the occupiers or visitors concerned, whichever is applicable. If such damage or loss is not made good or replaced by the Contractor, the Company shall be entitled to deduct the cost of such remedying such damage or loss from any moneys due or which may become due to the Contractor.

(e) Protection of Works

The Contractor shall provide all things necessary for the protection of the Works and all unfixed materials and goods delivered upon the site of the Works, whether delivered by the Contractor or the Company for use upon the Works, and the Contractor shall assume full responsibility for any damage sustained to the foregoing from whatever cause arising.

(f) Protection of service media

The Contractor shall protect, uphold, maintain and seal off where necessary all existing water, gas, electricity and telephone lines, drains etc., unless earmarked for demolition, during the execution of the Works. The Contractor is to make good any damage due to any cause within his control at his own expense or pay any costs with charges in connection therewith. Where the services are to be temporarily terminated or diverted, the Contractor is to give the necessary notice to the Company and to arrange for the work to be carried out and pay all costs and charges in connection therewith.

(g) Water, electricity and temporary installations

(i) All water and electricity required for the proper and efficient execution of the Works will be provided free of charge by the Company, but the Contractor will be expected to exercise every effort to prevent the abuse of this privilege and to economise in the use of water and electricity, and to ensure that all rules and regulations applicable to the use of same are strictly complied with by the Contractor's workers.

(ii) The Contractor shall power and maintain (or arrange for the use of existing facilities) all wiring and accessories for the temporary installation of electric lighting and power necessary for the Works, and pay all charges connected therewith.

- (iii) The Contractor shall remove all temporary installations when directed by the Company and make good the Site thereafter.

(h) Scaffolding and staging

The Contractor shall provide and maintain all necessary temporary scaffolding together with planks, battens, catwalks, gangways, ladders, etc, and provide special staging where required in positions of unusual height or construction for the proper execution and completion of the Works, including those of sub-contractors, and pay all costs and charges in connection therewith.

(i) Cleaning up on completion

The Contractor shall remove all refuse from the site on completion of the Works. Should the Contractor fail to remove refuse from the site after reasonable notice in writing has been given by the Company, and if the progress of the Works is impeded by such failure, the Company reserves the right to employ outside labour to remove the refuse and deduct all costs and expenses thereby incurred from any money due or which may become due to the Contractor.

(j) Protection of plant and materials

- (i) The Contractor shall be fully responsible for all equipment, tools, apparatus and materials provided by him in connection with the Works, and special care shall be taken to protect all parts thereof in such a manner as may be necessary or as directed by the Company.
- (ii) This protection shall include covers, sheds, stores or other means to prevent water, dirt, grit, plaster or other foreign substances from entering the working parts of machinery and to protect the equipment and materials from the weather. Special care shall be taken to keep all open ends of pipes, ducts, etc., closed in storage or in the course of carrying out the Works.

(k) Use of lifts, loading bays and access areas

The Contractor shall comply with all directions given by the Company from time to time as to the use of lifts, loading bays and access areas within the Company's premises.

3.5 Site Staff

- (a) The Contractor shall take all reasonable precautions to ensure that all persons employed by it to carry out the Works are competent and have experience performing such Works.
- (b) The Contractor shall ensure that such persons employed shall comply with and observe all of the Company's internal rules and procedures which may be prescribed by the Company from time to time in connection with the performance of the Works and shall comply with any and all instructions given by the Company to the Contractor in connection therewith.

- (c) The Contractor shall be responsible for keeping all persons under its control or employ, including persons employed by sub-contractors, within the boundaries of the Site.

3.6 Security and Screening of Employees

- (a) Before the Contractor employs or engages any person in connection with the Works, the Contractor shall ensure that it has, in respect of that person:
 - (i) Obtained a police records check (if required by the Company); and
 - (ii) Investigated the person's employment history, and satisfied itself that based on the foregoing, the person is a suitable person to be so employed.
- (b) The Contractor shall provide to the Company all information relating to the screening process described in clause 3.6(a) above, and the Company shall provide the Contractor with the names of those persons (if any) that the Company has approved in relation to the screening process (the "**Approved Persons**").
- (c) The Company may at any time notify the Contractor that a person has ceased to be an Approved Person. Upon receipt of such notice, the Contractor shall ensure that such Approved Person shall no longer enter the Company's premises, and that such Approved Person shall cease to be engaged in connection with the Works.
- (d) The Contractor shall provide its own security guards, as necessary, to protect the Works and ensure that all the Company's fixtures, fittings and equipment are properly guarded and protected from theft, burglary, accidents and loss.

4. CONTRACT SUM

- 4.1 The Company shall pay the Contractor _____ (the "**Contract Sum**") for carrying out the Works and providing the Materials.
- 4.2 The Contract Sum is exclusive of Goods and Services Tax and shall be paid to the Contractor thirty (30) days upon acceptance and receipt of invoice after the satisfactory delivery of works.
- 4.3 The Company shall be entitled to deduct and set-off from any payments due to the Contractor under this Contract against any monies which may from time to time become due and owing to the Company by the Contractor.
- 4.4 This Contract is on a "fixed price" basis and no variations in the rates of labour, prices of any materials and schedule of unit rates bid shall be allowed unless specified and approved by the Company. Unless otherwise specifically stated, the following shall be deemed to be included in the Contract Sum:
 - (a) Labour and all costs in connection therewith;

- (b) Materials, goods and costs in connection therewith (e.g. conveyance, delivery, unloading, carrying in, storing, returning packages, handling, hoisting and placing or lowering);
- (c) Fitting and fixing materials and goods in position;
- (d) Removing existing fittings or fixtures where necessary for carrying out the Works;
- (e) Use of plant, tools and vehicles, including warranty, and supply of fuel, and other equipment necessary for the proper execution and completion of the Works;
- (f) Waste of materials;
- (g) Establishment charges, supervision attendance, overhead charges and profit; and
- (h) Complying with the requirements of the Contract and any other requirement necessary for the proper execution and completion of the Work.

5. COMMENCEMENT OF WORKS

5.1 Possession of Site

- (a) The Company shall give the Contractor possession of so much of the Site as may be required to enable the Contractor to commence carrying out the Works stated in Scope of Services (Annex C). The Contractor shall not be entitled to claim against the Company for any loss or damage whatsoever caused by or related to any delay in giving possession of the Site.
- (b) The Contractor shall be deemed to have visited and examined the Site before submitting the Proposal and Tender and warrants that it is satisfied that the Site is suitable and meets all requirements for the Works and that it is satisfied as to the means of access, facilities for the transport and movement of materials and goods and plan for any contingency which may affect its Tender.
- (c) The Contractor shall not conduct any activities on the Site other than carrying out the Works.

5.2 Commencement of Works

- (a) Subject to clause 6.2, upon receiving possession of the Site, the Contractor shall immediately commence carrying out the Works in a diligent and expeditious manner.
- (b) The Works shall be proceeded with in such order as the Company may direct, or in the absence of such instruction, in the most workmanlike manner.

5.3 Hours of Work

- (a) The following are the hours within which works can be carried out subject to the Company's approval with respect to school and venue operations:

Monday to Sundays
and Public Holidays - 0830hrs to 1800hrs

Remarks: - All noisy works must be declared and carried out only during the Company's approved dates and times.

- (b) The Company reserves the right to stop any works anytime if the works disturb the other occupiers in the Company premises or in the neighbouring buildings.
- (c) Notwithstanding the foregoing, the Company may direct the Contractor to carry out the Works on other days or at other times instead, at no extra charge. All Works must be carried out with due diligence and expedition as directed by the Company.

5.4 Access by SAS Authorised Personnel

The SAS Authorised Personnel and any person authorised by him shall at all reasonable times have access to the Site and all workshops and other places where the Works or preparations for the Works are being carried out. The Contractor shall use its best endeavours to facilitate the examination of the Works and/or Materials by the SAS Authorised Personnel and his authorised persons.

5.5 Drawings and Specifications

The Contractor shall be responsible for the proper and accurate setting out of the Works, and shall keep one copy of this Contract, which shall include all Schedules, Annexes and Appendices hereto, on the Site at all times, and the SAS Authorised Personnel shall have access to the same at all times. Any deviation from the setting out shown in the drawings shall be highlighted to the Company with sufficient notice.

5.6 Foreman and Assistants

The Contractor shall keep stationed on the Site an appropriately trained and competent general foreman and such assistants in each trade as may be necessary, each of whom must be capable of receiving verbal instructions in English, in default of which they may be supplied by the Company at the Company's sole discretion and all expenses in connection therewith shall be recoverable from the Contractor. The foreman and his assistants shall be deemed to have the full authority of the Contractor to receive and act upon the instructions of the SAS Authorised Personnel and any such instructions given to the foreman or his assistants shall be deemed to have been given to the Contractor.

5.7 Wage Book and Time Sheets

The Contractor shall:

- (a) Keep proper wage books and time sheets showing the wages paid to and the time worked by all workers employed in carrying out the Works;

- (b) Produce such wages books and time sheets on demand for inspection by any person duly authorised by the SAS Authorised Personnel or the relevant authorities; and
- (c) Furnish such information relating to the wages and conditions of the employment of such workers as any person duly authorised by the SAS Authorised Personnel or the relevant authorities may from time to time require.

5.8 Defects

- (a) Any defects, imperfections, shrinkage or other faults which may appear during the progress of the Works, arising in the opinion of the SAS Authorised Personnel from materials or workmanship not being in accordance with the Contract, shall upon the directions in writing of the SAS Authorised Personnel, and within such reasonable time as shall be specified therein, be amended and made good by the Contractor at its own cost.
- (b) Should any defective work have been done or material supplied by any approved contractor employed on the Works, the Contractor shall be liable to make good the work in the same manner as if such work or material had been done or supplied by the Contractor.

5.9 Account, Receipts and Vouchers

The Contractor shall upon request of the SAS Authorised Personnel furnish him with all invoices, accounts, receipts and other vouchers that he may require in connection with this Contract.

6. POWER TO ENGAGE OTHER CONTRACTORS

- 6.1 If the Contractor, after receipt of a written notice from the SAS Authorised Personnel requiring compliance with such instructions of the SAS Authorised Personnel within the time stipulated in the notice, fails to comply with such instructions, the Company may at its sole discretion on the expiry of the time stipulated in the notice employ and pay other persons to execute any work whatsoever which may be necessary to give effect thereto and all costs and expenses incurred in connection therewith shall be recoverable from the Contractor by the Company as a debt or may be deducted by the Company from any moneys due or becoming due to the Contractor.
- 6.2 The Company reserves the absolute right and power to engage other contractors to execute and/or perform any part of the Works and/or services relating to the Works which in its opinion are specialised in nature.

7. COMPLETION DATE

The Contractor shall complete the Works on or before the progressive completion dates stated in Purchase Order. Any requests to extend the Completion Date shall be in writing and must be received by the Company at least two (2) weeks before the Completion Date.

8. DEFECTS LIABILITY PERIOD

In the event that any defect, imperfection, shrinkage or other fault howsoever caused appears in the Works at any time within period stated from the completion of the Works, the Contractor shall, within a reasonable time after receipt of the SAS Authorised Personnel's written instructions, remedy such defect at its own cost and to the satisfaction of the SAS Authorised Personnel. (if applicable)

9. INTELLECTUAL PROPERTY

The Contractor agrees that any intellectual property rights that may arise out of or in connection with this Contract shall vest in the Company, and the Contractor shall, if so required by the Company at any time, execute a separate agreement (in such form as may be stipulated by the Company) to ensure that such intellectual property rights are fully and adequately vested in the Company. Notwithstanding the foregoing, the Contractor warrants that the Company's use of the Materials and/or the completed Works does not infringe the intellectual property rights of any third party and agrees to indemnify and keep the Company indemnified against any and all claims of infringement, save and except where such infringement is due solely to the use of any specifications or drawings provided by the Company for the purposes of this Contract.

10. TERMINATION

10.1 Termination for Breach

If at any time any of the following events shall occur:-

10.1.1 The Contractor is in breach of any of the terms or conditions of this Contract, (i) where such breach is capable of remedy, the Contractor fails to effect a remedy (at its own expense) within fourteen (14) days, then the Company may terminate this Contract without any liability with thirty (30) days termination written notice; or (ii) where such breach is not capable of remedy, then the Company may terminate this Contract without any liability with thirty (30) days termination written notice, or

10.1.2 The Contractor is unable to pay its debts generally as they become due, or any step or action is commenced against or by the Contractor for liquidation, dissolution, or if any judicial manager, trustee or receiver is appointed with respect to the Contractor's assets; or if the Contractor makes any form of compromise or scheme of arrangement with its creditors, or ceases to carry on business, then the Company may terminate this Contract without any liability with immediate notice.

10.2 Termination by Notice

10.2.1 Without prejudice to clause 10.1 above, either Party may terminate this Contract on giving not less than thirty (30) days written notice to the other Party, without any requirement to furnish reasons for the termination and without any liability.

10.2.2 Termination of this Contract (whether under clause 10.1, 10.2, 13 or otherwise) shall not affect any rights, remedies, obligations or liabilities of the Parties that have accrued up to the date of termination, including the right to claim damages in respect of any breach of the Contract which existed at or before the date of termination.

11. SUSPENSION

The Company is entitled to suspend this Contract either wholly or partially, upon giving three (3) days' notice in writing to the Contractor. The Contractor shall resume its full obligations under the Contract upon the cessation of the suspension period.

12. INDEMNITY AND INSURANCE

12.1 The Contractor undertakes to duly insure all workers engaged in the performance of the Works against any liability and further undertakes to indemnify and keep the Company and SAS Authorised Personnel indemnified against any and all loss, damage or liability (whether criminal or civil) suffered, together with legal costs on a full indemnity basis, as a result of the breach of this Contract by the Contractor, including but not limited to:

- (a) Any act of neglect or default of the Contractor's employees, agents and/or permitted sub-contractors;
- (b) Any breach in respect of any matter arising from the non-performance of the Works resulting in any claim by any third party; and
- (c) Any breach of the Contractor's undertakings or warranties set out in this Contract.

12.2 The indemnities given by the Contractor under this clause shall not be defeated or prejudiced by reason of any negligence or omission of the Company or SAS Authorised Personnel in (i) supervising or controlling the Contractor's methods of performing the Works, (ii) detecting, preventing, remedying or mitigating defective Works, or (iii) ensuring the proper performance of any obligation of the Contractor under this Contract.

12.3 The contractor shall apply for and obtain all necessary insurances to safeguard the Company from unmitigated risks, accidents and unforeseeable elements, such as

- (a) Workmen compensation insurance [minimum of Singapore Dollars one million (S\$1,000,000.00)];
- (b) Public liability insurance [minimum of Singapore Dollars one million (S\$1,000,000.00)];
- (c) Industrial all risks Insurance;
- (d) Any other applicable insurance as may be fit and justifiable as an expense to mitigate risks.

13. FORCE MAJEURE

Neither Party shall be liable for any failure or delay in performing its obligations under this Contract if the failure or delay is due to acts of God, acts of civil or military authority, wars, riots, civil commotions, strikes, lock-outs, fires or other catastrophes.

14. NOTICES

14.1 Any notice or other communication given to a Party under or in connection with this Contract shall be in writing and shall be:

14.1.1 Delivered by hand or by pre-paid post or other next Business Day delivery service at its address as set out in clause 14.2; or

14.1.2 Sent by email to the address specified in clause 14.2.

14.2 The addresses and email addresses for service of notices are as follows:

The Company	Singapore Arts School Ltd. 1 Zubir Said Drive Administration Office #05-01 Singapore 227968 Email: procurement@sota.edu.sg
The Contractor	[]

14.3 Any notice or communication shall be deemed to have been received:

14.3.1 If delivered by hand, on signature of a delivery receipt;

14.3.2 If sent by pre-paid post or other next Business Day delivery service, at 0830hrs on the second Business Day after posting or at the time recorded by the delivery service; and

14.3.3 If sent by email, at the time of transmission, or, if this time falls outside business hours in the place of receipt, when business hours resume. In this clause 14.3, business hours means 0830hrs to 1800hrs Monday to Friday on a day that is a Business Day.

14.4 This clause does not apply to the service of any proceedings or other documents in any legal action or, where applicable, any arbitration or other method of dispute resolution.

15. WAIVER

No failure or delay on the part of any Party hereto in exercising any power or right hereunder shall operate as a waiver thereof nor shall any single or partial exercise of any right or power preclude any other or further exercise of any right or power hereunder.

16. SEVERABILITY

If any one or more of the provisions contained in this Contract or any documents executed in connection herewith shall be invalid, illegal or unenforceable in any respect under any applicable law, the validity, legality and enforceability of the remaining provisions contained herein shall not in any way be affected or impaired.

17. ENTIRE AGREEMENT AND MODIFICATION

This Contract embodies and sets forth the entire agreement and understanding of the Parties and supersedes all prior oral or written agreements, understandings or arrangements relating to the subject matter of this Contract. Neither Party shall be entitled to rely on any agreement, understanding or arrangement which is not expressly set forth in this Contract.

18. NO PARTNERSHIP

Nothing in this Contract shall be deemed to constitute a partnership between the Parties nor constitute one Party the general agent of the other Party. It is hereby expressly agreed and declared that the Contractor shall in the performance of the Works and for all other purposes be deemed to be an independent consultant.

19. SUB-CONTRACT AND ASSIGNMENT

- 19.1 Subject to clause 19.3, neither Party shall without the prior written consent of the other Party transfer or assign (legally, equitably or otherwise) all or any of its rights, obligations or benefits hereunder to any third party or parties.
- 19.2 Without prejudice to clause 19.1, the Contractor shall be responsible and liable to the Company for all acts, defaults and omissions of (i) any sub-contractor appointed by the Contractor; (ii) any assignee; and (iii) any employees or agents of any subcontractor or assignee, and shall fully indemnify and keep the Company fully indemnified against all loss and damage suffered by the Company arising out of or in connection with such acts, defaults or omissions.
- 19.3 Notwithstanding clause 19.1, the Company shall have the sole right and discretion at any time to assign or transfer this Contract whether in whole or in part to any of its subsidiaries or associated companies.
- 19.4 The Contractor shall not have the right to require the Company to deal or communicate with or make any payment or give any certificate to any agent or attorney of the Contractor. If the

Company shall so deal or communicate with or make any payment or give any certificate to any such agent or attorney whether on one occasion or on any number of occasions, the same shall not be or be deemed to be a waiver of the provisions of this clause 19.4 either as regards any specific agent or attorney or otherwise.

20. COSTS

Each of the Parties shall bear its own legal and other costs and expenses incurred in connection with the negotiation, preparation and execution of this Contract.

21. CONFIDENTIALITY

21.1 The Contractor undertakes:

- (a) To keep confidential all Confidential Information (whether written or oral) which it has obtained or received as a result of the discussions leading up to or the entering into, or obtains or receives in performance of, this Contract;
- (b) Not to disclose the Confidential Information in whole or in part to any person without the Company's prior written consent, save to those of its employees or such third parties appointed in the performance of this Contract and who need to know the same and who shall be directed by the Contractor to observe the same obligations of confidentiality with respect thereto;
- (c) To use the Confidential Information solely in connection with the performance of this Contract and not otherwise or for its own benefit; and
- (d) Not to write, contribute or publish any article or news or make any presentation or public statement through whatever medium in respect of the Works or this Contract without the prior written approval of the Company.

21.2 The provisions of clause 21.1 shall not apply to the whole or any part of the Confidential Information which is:

- (a) Already in the Contractor's possession which the Contractor can show from written records other than as a result of a breach of clause 21.1;
- (b) In the public domain other than as a result of a breach of clause 21.1;
- (c) Required to be disclosed pursuant to a statutory obligation or by any court or tribunal;
or
- (d) Disclosed with prior written consent of the Company.

21.3 The restrictions contained in this clause 21 shall continue to apply after the termination of this Contract without limit in time.

- 21.4 Upon termination of this Contract for whatever reason and at all other times when requested to do so by the Company, the Contractor shall deliver up to the Company all copies of Confidential Information (in whatever format) that are its possession.

22 VARIATION

This Contract shall not be altered, amended or modified except by written instruments signed by the Parties.

23 COUNTERPARTS

This Contract may be executed in any number of counterparts, all of which when taken together shall constitute one and the same instrument, and the Parties may execute this Contract by signing on separate counterparts.

24 CONTRACTS (RIGHTS OF THIRD PARTIES) ACT

A person who is not a party to this Agreement shall have no right under the Contracts (Rights of Third Parties) Act (Cap. 53B) to enforce any of its terms.

25 GOVERNING LAW AND JURISDICTION

- 25.1 This Contract shall be governed by and construed in accordance with the laws of the Republic of Singapore.
- 25.2 In respect of any legal action or proceedings arising out of or in connection with this Agreement, the parties irrevocably submit to the jurisdiction of the courts of Singapore.

IN WITNESS WHEREOF the Parties hereto have hereunto set their respective hands the day and year first above written.

SIGNED BY)
DIRECTOR, CORPORATE)
PLANNING AND SERVICES)
for and on behalf of)
SINGAPORE ARTS SCHOOL LTD) _____

in the presence of:)
SENIOR MANAGER)
OFFICE OF PROPERTY MANAGEMENT) _____

SIGNED BY
(Contractor's Authorised Representative)
for and on behalf of [Contractor Name]
[Name / Designation]) _____
)

in the presence of:)
)
_____) _____
[Name / Designation])

Annex B:
SPECIFICATION OF WORKS

ANNEX B - SPECIFICATION OF WORKS

INVITATION TO TENDER (ITT) FOR THE PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT SCHOOL OF THE ARTS, SINGAPORE

The objective of this Tender is to engage services for which the Contractor must design, supply, install, test, and commission a complete dehumidification system for Level 7 and Level 9 corridor areas serving the Music Classrooms.

1 Scope of Works

1.1 The Project

- 1.1.1 The objective of this project is to design, supply, install, test, and commission a **dehumidification system capable of continuously maintaining indoor Relative Humidity (RH) between forty-five percent (45%) and fifty-five percent (55%) under normal occupied operating conditions*** in all Music Classrooms located at Level 7 and Level 9.
- 1.1.2 **The system shall be designed for continuous twenty-four (24)-hour operation without interruption, inclusive of automatic humidity control functionality,*** with a maximum noise level not more than fifty (50) dB(A),* measured at one (1) metre from the unit along the corridor or ceiling area.
- 1.1.3 System sizing and selection shall be based on Singapore tropical ambient conditions and actual site heat/moisture load assessment conducted by the Contractor.
- 1.1.4 The Contractor shall provide complete condensate drainage piping, insulation, supports, and discharge connections necessary for proper system operation without water leakage.
- 1.1.5 The specification defines required performance outcomes. The Contractor must be fully responsible for system design, equipment selection, installation and integration necessary to achieve the stated performance.
- 1.1.6 All penetrations through walls, slabs, ceilings, or fire-rated elements shall be properly sealed and fire-stopped in accordance with Fire Safety Code requirements.
- 1.1.7 The Contractor shall conduct testing and commissioning to verify humidity control performance, system functionality, drainage operation, electrical safety, and control operation.
- 1.1.8 Pre-installation and post-installation humidity measurements shall be conducted and submitted to the Company for verification.
- 1.1.9 Post-installation humidity monitoring shall be conducted continuously for a minimum period of seven (7) consecutive days unless otherwise approved by the Company.

1.2 Contractor's Obligations

- 1.2.1 The Contractor must comply with this Annex and complete all works in accordance with **Annex C - Scope of Services** and the stipulated timeline.
- 1.2.2 Contractor must submit a **detailed work programme within two (2) weeks*** from the date of Letter of Acceptance.
- 1.2.3 The Contractor must be deemed to have:
- Attended the compulsory Site-show session;*
 - Fully familiarised with site conditions;
 - Included all associated costs in the tender.
- 1.2.4 The Contractor must provide all materials and execute all works necessary for proper completion of the Works, including any works not explicitly stated but deemed necessary in compliance with applicable Singapore Standards.
- 1.2.5 The Contractor shall submit equipment catalogues, technical specifications, control schematics, and proposed system layout drawings for approval prior to commencement of installation works.
- 1.2.6 The Contractor must purchase Insurance (refer to COC/15, clause 12.3).
- 1.2.7 If lifting equipment to the replacement works is required, all safety endorsement and certification are deemed to be inclusive in the price quoted / tendered.
- 1.2.8 Site visit is compulsory for site condition verification. Only Tenderers that attend the Site-show session will be given Appendix 2: Floor Plan for Level 7 and Level 9, upon submission of Appendix F: Non-Disclosure Agreement to Safeguard Official Information.

2 Requirement Specifications

2.1 Work Design

- 2.1.1 The Requirements Specifications are intended to outline the minimum requirements to ensure compliance with the school and relevant statutory authorities and to ensure that the most cost-effective solutions are achieved for the proposed project.
- 2.1.2 It is the Contractor's responsibility to ensure that the workmanship of the replacement, installation and upgrading works is carried out to the satisfaction of the Company.
- 2.1.3 The Contractor must perform evaluation and provide qualitative solutions to confirm design intent and compliance with all design objectives and performance criteria requirements described herein.

2.1.4 The Contractor shall conduct site visits and undertake thorough site investigation to confirm existing site conditions and existing base building connection points.

2.1.5 The Contractor must complete the required on-site works during normal working hours or approved working hours (i.e. after school, weekends) during school terms.

Mondays to Sundays and Public Holidays - 0830hrs to 1800hrs

Remarks:

All noisy works must be declared and carried out only during the Company's approved dates and times.

2.1.6 The Contractor shall comply with all applicable Singapore Standards, Fire Safety Code requirements, Workplace Safety and Health Act requirements, and all relevant statutory regulations and authorities' requirements.

2.2 Work Execution

2.2.1 The Contractor must perform a pre-handover inspection document, showing timestamped photos or videos that document the state of the project (before and after) to reflect the final state of the project, indicating that it is ready for handover.

2.2.2 The Contractor must provide electrical protection devices such as Earth Leakage Circuit Breaker and Overcurrent Protection Circuit Breaker to isolate the building's electrical/power source from the Contractor's tools and equipment, if necessary.

2.2.3 Any dimensions or specifications shown on documents or drawings provided by the Company will only serve as guides. The Contractor is to take exact measurements of the site.

2.2.4 All materials and workmanship shall be of good quality and fit for purpose. Any change in designs, materials, construction methods or workmanship must be subjected to the Company's approval in writing.

2.2.5 The Contractor must be **fully responsible for all sub-contractors*** selected and employed by and under the control of the Contractor. In addition, the Contractor must make good any damage or loss suffered by the building by reason of default or failure, whether total or partial, on the part of any sub-contractor engaged by the Contractor, and must indemnify the Company against any damage, liability, claim or loss arising therefrom.

2.2.6 The Contractor must not be allowed to do noisy, dusty, vibration prone and gas or odour-generating types of work during any hours, unless specified and approved by the Company.

2.2.7 The Contractor must take the necessary safety precautions not to weaken any structures of the building during the entire work process including, but not restricted to dismantling and installation.

- 2.2.8 Upon completion, the Contractor is to remove all stains from floors, walls, etc, and clear all debris and superfluous materials upon completion of work and get the premises **fit and ready for immediate handover**.*
- 2.2.9 The Contractor must ensure that all site work complies with relevant safety standards and practices and follow all statutory school requirements.
- 2.2.10 The Contractor must provide Manufacturer's Warranty Certificates for all new system and material components installed under this Contract.

Upon completion of the Works, the Contractor must provide:

- a. Manufacturer's Warranty Certificates for all new system and material components with a minimum warranty period of five (5) years.
- b. Defects Liability Period (DLP) for workmanship warranty of one (1) year for all installation works.
- c. Both warranty periods must commence from the date of Final Completion. For phased completion, the commencement date must be the last date of completion.
- d. During the warranty period, the Contractor must rectify, at no additional cost to the Company, any defects arising from faulty materials, equipment, or workmanship.
- e. Submission of Operation and Maintenance (O&M) Manuals and as-built drawings (hardcopy and softcopy) upon completion of works.

2.3 Preliminaries

- 2.3.1 Preliminaries will include the following items as specified in this document:
 - 2.3.1.1 Insurance (refer to COC/15, clause 12.3),
 - 2.3.1.2 Transportation, labour and disposal of construction debris off-site,
 - 2.3.1.3 Hoarding, protection to ceiling, wall and floor, warning signs, storage of materials and equipment, cleaning, disposal of debris at government dumping sites, and handing over,
 - 2.3.1.4 All safety equipment e.g., fire extinguishers, personnel protection equipment, etc.
 - 2.3.1.5 Submission of relevant as-built drawings.
 - 2.3.1.6 Necessary protection works before commencement of work.

3 Cleanliness of Work Area

- 3.1 The Contractor must be responsible for the cleanliness of the work area. All debris must be promptly and properly cleared by the Contractor. All waste materials and scrap metals removed from the installation work, under this tender, must be disposed from the school premises on daily basis* by the Contractor to a NEA-approved disposal area.
- 3.2 **Housekeeping shall be carried out at the end of the daily work.***

4 Others

- 4.1 All works are to be carried out by relevant tradesmen.
- 4.1.1 To provide a competent Project Manager who shall manage all aspects of work, including attending project meetings, providing progress updates and co-ordinating where necessary.
- 4.1.2 To produce photos of before and after installation of works with job completion details.
- 4.1.3 The works must be **completed within the agreed timeline, as stated in Annex C - Scope of Services, Point 5.2, Table A.**

Annex C:
SCOPE OF SERVICES

ANNEX C - SCOPE OF SERVICES

INVITATION TO TENDER (ITT) FOR THE PROVISION OF DEHUMIDIFIER SYSTEM AND INSTALLATION WORKS AT SCHOOL OF THE ARTS, SINGAPORE

1 Note on Critical Requirements

The Scope of Services provided herein is for reference only and **is not exhaustive**. For clarity and ease of evaluation, **critical requirements** are explicitly indicated using an **asterisk (*)** and/or keywords such as **"Must"** or **"Mandatory"**, to distinguish them from general or advisory requirements. Contractors are expected to comply fully with all marked critical requirements.

2 General Requirement

- 2.1 This tender covers the design, supply, installation, testing, and commissioning of a dehumidification system to maintain indoor RH between **forty-five percent (45%) and fifty-five percent (55%)** under normal operating conditions. Normal operating conditions shall mean classroom doors closed except for transient ingress/egress, representative occupancy, and normal Heating, Ventilation, and Air Conditioning (HVAC) operation.
- 2.2 Temporary excursions due to door openings are permitted above **fifty-five percent (55%) RH spike event for a maximum of thirty (30) minutes** per event. The system must include **RH sensors and door-status sensors** with automatic control logic to respond to door openings. If RH exceeds or remains above **fifty-five percent (55%) for more than thirty (30) minutes, visual alarm indicators** must be triggered, and **documented corrective action must be taken within twenty-four (24) hours**. Acceptance testing must verify system performance under normal and simulated door-opening conditions, including the ability to **restore RH to forty-five percent (45%) to fifty-five percent (55%) within 30 minutes** after each event.
- 2.3 The installed **dehumidification system shall remain continuously available for automatic operation on a twenty-four (24)-hour basis,*** with a **noise compliance requirement not exceeding fifty (50) dB(A) under all operating conditions,*** measured at one (1) metre from the dehumidifier unit installed along the corridor or ceiling area.
- 2.4 **The system must incorporate energy-efficient control logic (e.g., variable speed control, staged operation, or demand-based control) to minimise energy consumption while maintaining the specified RH range.***
- 2.5 **The system must be designed to ensure stable humidity control suitable for music classroom environments, while maintaining minimal operational noise to avoid disruption to teaching and learning activities.***

- 2.6 The Contractor must include all necessary builder's works, including but not limited to:
- a. Hacking and forming of wall openings for service penetrations;
 - b. Provision of proper fire-stopping to all penetrations, subject to relevant authority endorsement;
 - c. Formation of openings for electrical cabling and trunking works;
 - d. Supply and installation of all necessary tools, supports, and brackets and associated accessories;
 - e. Making good to all affected finishes, including reinstatement of existing wall paintwork to match original condition.
- 2.7 The Contractor must fabricate and install a suitable housing enclosure complete with ventilation louvers to box up the dehumidifier units, ensuring:
- a. Adequate ventilation for proper equipment operation;
 - b. Sufficient accessibility must be **provided for all serviceable dehumidifier units, with a minimum maintenance clearance of six hundred (600) millimetres*** to allow for safe and effective inspection and maintenance.

3 Preliminaries

- 3.1 Procurement and submission of preliminaries, inclusive of Risk Assessments, workers' particulars, work schedule, Method of Statement, necessary insurance, and adequate protection according to Appendix 1: House Rules are to be included.
- 3.2 O&M Manuals and as-built drawings must be submitted as part of the project handover upon completion of works.

4 Schedule of Works and Operation Hours

- 4.1 Schedule of works needs to be reviewed on a regular basis to avoid disruption of School and Building Operations.
- 4.2 Work that creates noise that could potentially disrupt ongoing lessons, such as hacking and drilling, must be carried out only on Saturdays, during school holidays, or after 1400 hrs up to 2000 hrs on school weekdays.
- 4.3 The Contractor must not carry out noisy, dusty, vibration prone and gas or odour-generating types of work during any hours, unless specified and approved by the Company.

5 Project Timeline

5.1 Project must commence upon issuance of Letter of Acceptance.

5.2 Contractor may propose **minor adjustment** to the timeline below, whilst adhering to the completion date.

Table A: Estimated Project Timeline

S/N	Project Milestones	Timeline	Cumulative Timeline (from Letter of Acceptance)
1	Submission of detailed design proposal (All Phases) <ul style="list-style-type: none"> Phase 1: Level 7 - Electronic Music Studio (1 room) Phase 2: Level 9 - EPR1 to EPR3 (3 rooms) Phase 3: Level 9 - MPR1 to MPR9 and EPR4 to EPR9 (15 rooms) 	Within two (2) weeks from issuance of Letter of Acceptance	Week 2
2	Review and approval of design proposal	Within two (2) weeks from submission	Week 4
3A	Phase 1 Installation (Level 7)	Within two (2) weeks from design approval	Week 6
3B	Phase 1 Monitoring, Testing and Commissioning (T&C)	One (1) week continuous monitoring	Week 7
3C	Approval to proceed to Phase 2	Within one (1) week after submission of monitoring report	Week 8 [One (1) week from completion of Phase 1]
4A	Phase 2 Installation (Level 9 - EPR1 to EPR3)	Within two (2) weeks	Week 10
4B	Phase 2 Monitoring, T&C	One (1) week continuous monitoring	Week 11
4C	Approval to proceed to Phase 3	Within one (1) week	Week 12 [One (1) week from completion of Phase 2]
5A	Phase 3 Installation (Remaining Level 9)	Within four (4) weeks	Week 16
5B	Phase 3 Monitoring and Full System Stabilisation	Two (2) weeks continuous monitoring	Week 18 [Two (2) weeks from completion of Phase 3]

6	Final T&C (Full System)	Within one (1) week	Week 19
7	Final Completion (All Works)	On or before 31 December 2026 (or agreed revised completion date)	Final

Note:

All timelines stated above must be sequential and subject to formal written approval at each stage before proceeding to the next phase. The Contractor must not commence subsequent phases without prior written approval from the Company's Authorised Representative.

6 Protection and Safety Barricades

- 6.1 Adequate protection and safety barricades bearing Contractor's company logo must be provided at lift lobby during the course of work, subject to the satisfaction of the School. Should there be a break in between such as lunch hour, safety barricades bearing Contractor's company logo must be present and fully barricade the affected area.
- 6.2 All Contractor's workers are to report to the Security Guards (with their identification documents) for sign in and sign out daily.
- 6.3 All workers must always be in their company attire, and/or must always display the visitors' passes when within the premises.
- 6.4 The Contractor must ensure that all safety precautions have been taken to ensure a safe working environment for workers and occupants of the premises. Work area should be cordoned off or temporary hoarding installed where necessary. Any debris should be removed from work area daily.

7 Scope of Services

- 7.1 The Contractor must provide all necessary design, supply, installation, testing and commissioning services for the dehumidification system at Level 7 and Level 9 corridor areas serving the Music Classrooms.
- 7.2 Design and Engineering
- a. Conduct site study and assessment of existing environmental conditions, including humidity levels and airflow conditions;
 - b. Perform necessary calculations to determine equipment capacity and system sizing to maintain indoor RH within a range of forty-five percent (45%) to fifty-five percent (55%) in all Music Classrooms located at Level 7 and Level 9;
 - c. **One (1) dehumidifier unit shall serve a maximum of three (3) classrooms only where engineering calculations demonstrate adequate humidity control under**

all operating conditions. The Company reserves the right to require additional units if performance validation is unsatisfactory.*

- d. The design must take into consideration existing building constraints, corridor configuration, occupancy pattern and integration with existing Mechanical and Electrical (M&E) systems.
- e. All equipment and material supplied must be new, of current manufacture, and suitable for continuous operation in an institutional environment;
- f. Prepare and submit detailed shop drawings, layout plans, control schematics and technical specifications for approval prior to commencement of works;
- g. Coordinate with other trades to ensure compatibility with existing M&E systems and building constraints.

7.3 Supply and Installation

- a. Supply and install ceiling/wall mounting dehumidifier units complete with all necessary accessories and control systems;
- b. An individual condensate pump must be provided for each dehumidifier unit installed, complete with discharge piping connected to the nearest approved drainage point.
- c. All condensate discharge piping shall be insulated and installed with proper gradient to prevent sweating, backflow, stagnant water accumulation, and microbial growth. Secondary containment trays shall be provided where leakage may damage ceilings, walls, finishes, or occupied spaces.
- d. Each condensate pump must be equipped with a high-level alarm and automatic shutoff function to prevent overflow and potential water damage. The system must include visual alarm indicators, to alert users when the high-level condition is triggered.***
- e. Provide necessary electrical connections, isolators, containment and cabling works;
- f. Carry out all builder's works required for installation, including wall openings, fire-stopping and making good;
- g. Fabricate and install suitable enclosures with ventilation louvers to house the dehumidifier units.

7.4 Alarms, Reporting and Acceptance

- a. The system must provide **visual alarm indicators (Blue Alarm Light signals)** if RH exceeds fifty-five percent (55%) for more than thirty (30) minutes, or upon any sensor failure.
- b. **Sensor failure**, sensor communication loss, invalid readings, or missing monitoring data shall be **deemed a non-compliant condition** until rectified.

- c. Continuous data logging of RH, temperature, door status, and equipment operation must be carried out at five (5)-minute intervals, with records stored for a minimum one (1) year.
- d. All logged data shall be exportable in open format (CSV or equivalent) without proprietary software restrictions.***
- e. Acceptance tests must demonstrate the system's ability to maintain forty-five percent (45%) to fifty-five percent (55%) RH during representative occupancy and with simulated door-opening events, including recovery from thirty (30)-minute spike, with submission of test reports and sensor calibration certificates.

7.5 Alarms Classification and Visual Indication System

- a. The dehumidification system must incorporate a standardised visual alarm classification system for all monitoring and fault conditions as follows:
 - i. Blue Alarm Light (Environmental Deviation Alarm):**
Triggered when indoor RH exceeds fifty-five percent (55%) for more than thirty (30) minutes, or upon failure of RH sensors.
 - ii. Red Alarm Light (Equipment Fault/Water Risk Alarm):**
Triggered upon condensate system abnormality, including condensate pump high-level alarm, pump failure, blockage, or overflow risk.

7.6 Environmental Performance Requirements

- a. The dehumidification system must maintain indoor RH levels within forty-five percent (45%) to fifty-five percent (55%) under normal operating conditions serving the Music Classrooms at Level 7 and Level 9.
- b. The system must automatically respond to fluctuations in ambient humidity and occupancy conditions.
- c. Humidity sensors must be installed at appropriate locations to ensure accurate monitoring and effective control of the environment. Each sensor must have an accuracy of plus or minus two percent ($\pm 2\%$) RH or better and must be of industrial-grade quality suitable for continuous operation.
- d. The Contractor must conduct pre-installation and post-installation humidity measurements to verify compliance with the specified humidity range. The Contractor shall also verify actual room-level RH performance during the monitoring period.
- e. Compliance with the specified RH performance requirements shall take precedence over equipment quantity assumptions, zoning concepts, or preliminary design submissions. The Contractor shall remain fully responsible for achieving the required environmental conditions regardless of proposed configuration.

7.7 Coverage Area

- a. The system must adequately cover;
 - Level 7 serving Electronic Music Studio (1 room);

- Level 9 serving EPR1 to EPR3 (3 rooms);
 - Level 9 serving MPR1 to MPR9 and EPR4 to EPR9 (15 rooms).
- b. The Contractor must determine the appropriate number, capacity and distribution of units to achieve uniform humidity control.

7.8 Equipment Requirements

- a. Dehumidifier units must be of proven design and suitable capacity based on detailed engineering calculations.
- b. Units must be energy efficient and designed for low noise operation.
- c. The maximum operational noise level must not exceed fifty (50) dB(A). Noise measurements shall be conducted under full operating condition using a calibrated sound level metre, measured at one (1) metre from the equipment enclosure, with ambient background correction in accordance with recognised acoustic standards.
- d. The Contractor must be fully responsible for ensuring compliance with the specified noise limits, including provision of acoustic insulation, lining, or silencers where necessary.
- e. Dehumidifier units must be provided with appropriate control panels, humidity sensors and automatic control features.
- f. All equipment must be installed in locations that allow safe and convenient maintenance access without the need for major dismantling of surrounding structures.

7.9 Enclosure and Ventilation

- a. The Contractor must fabricate and install suitable housing enclosures to conceal the dehumidifier units.
- b. The enclosure must:
- Provide adequate ventilation for proper operation;
 - Allow sufficient access for inspection, servicing and maintenance;
 - Be aesthetically compatible with existing corridor finishes.
- c. All power supplies must be properly labelled and provided with local isolators for maintenance safety.

7.10 Reliability and Continuous Operation

- a. Equipment must be suitable for continuous operation in an institutional environment.
- b. The system must incorporate automatic controls for stable operation.
- c. Units must be accessible for maintenance without major dismantling works.

7.11 Integration and Compliance

- a. The dehumidification system must be compatible with existing building electrical infrastructure.

- b. All electrical works shall include proper circuit protection, local isolators, overload protection, and shall comply with prevailing Singapore electrical regulations.
- c. All electrical and builder's works must comply with prevailing Singapore codes and standards.
- d. All penetrations must be properly sealed and fire-stopped where required.

7.12 Builder's Works

- a. The Contractor must carry out all required builder's works including wall openings, penetrations and reinstatement works.
- b. All service penetrations must be properly sealed and provided with approved fire-stopping materials where required.
- c. All affected finishes must be made good and reinstated to match existing conditions.

7.13 For the purpose of this Contract, the following terms must have the meanings assigned below:

- a. **"RH Spike Event"** means a temporary increase in indoor RH above fifty-five percent (55%) lasting not more than thirty (30) minutes due to transient conditions such as door opening or occupancy changes.
- b. **"Monitoring Period"** means the continuous post-installation period of system operation used to verify compliance with specified performance requirements prior to approval of the next project phase or final acceptance.
- c. **"Stabilisation Period"** means the post-installation period for system balancing, commissioning adjustments, and sensor calibration prior to commencement of formal monitoring.

7.14 Performance Guarantee

- a. **The Contractor must be fully responsible for the design, supply, installation, testing and commissioning of the dehumidification system to achieve and maintain the specified indoor RH level of forty-five percent (45%) to fifty-five percent (55%) in all designated Music Classrooms at Level 7 and Level 9, based on reasonable assumptions of building envelope performance and normal occupancy patterns.***
- b. **Transient allowance: Single-event spike exceeding fifty-five percent (55%) RH permitted for a maximum of thirty (30) continuous minutes. Any RH Spike Event exceeding thirty (30) minutes must trigger an alarm/escalation and corrective action.***
- c. Recovery behaviour: On detection of spike or door-induced disturbance, control systems must prioritise rapid safe recovery using available dehumidification systems.

- d. Door/opening events: Install door-status sensors (magnetic or contact) on classroom doors and configure control logic to:
 - i. Flag an "open-door" event and temporarily adjust expectations (allow spike timer to run while door open).
 - ii. Enable local dehumidification after the door closes if RH exceeds more than fifty-five percent (55%) until restored.
- e. The Contractor must ensure that the proposed system capacity, equipment selection and installation arrangement are adequate to achieve the required performance under normal operating conditions. Any modification, additional equipment or rectification works required to achieve the specified performance must be carried out by the Contractor **at no additional cost to the Company.**

7.15 Testing and Verification

- a. Upon completion of installation, the Contractor must conduct **T&C** to verify that the dehumidification system is capable of achieving the specified **RH range of forty-five percent (45%) to fifty-five percent (55%)** and the required **noise level limits**.
- b. Performance testing must be carried out in the presence of the Company's representative, using **calibrated instruments**, and the results must be documented and submitted as part of the **T&C report**.
- c. The Company reserves the right to require extended monitoring or re-testing during representative high humidity conditions if environmental conditions during testing are deemed non-representative.
- d. **All performance testing must be conducted under representative occupancy and operational conditions, including doors closed and typical HVAC operation.***
- e. **Acceptance must be based on a minimum continuous eight (8)-hour monitoring period.***
- f. Should the system fail to meet the specified performance requirements, the Contractor must undertake the necessary rectification works and repeat the testing until compliance is achieved.
- g. RH sensors with an accuracy of plus or minus two percent ($\pm 2\%$) RH must be installed in each classroom at representative locations, positioned from one point two (1.2) metres to one point five (1.5) metres above finished floor level and away from supply diffusers, doors, windows and walls to ensure accurate readings.
- h. Each zone must be provided with a **minimum requirement of one (1) primary + one (1) verification sensor per zone, multiple sensors with averaging only allowed for large zones with approval*** must be implemented for larger spaces to ensure measurement reliability and redundancy.

- i. All sensors must be **calibrated upon commissioning**, and thereafter **recalibrated at intervals not exceeding one (1) year**,* or in accordance with the manufacturer's recommendations.
- j. In the event that the installed system fails to achieve the specified humidity performance after T&C, the Contractor must carry out all necessary rectification works including modification of equipment capacity, additional units, relocation of sensors or system adjustments at no additional cost to the Company.
- k. **Testing must also verify condensate drainage performance, control system response, and continuous operation stability.***

7.16 Maintenance and Warranty

- a. Preventive maintenance during the Defects Liability Period (DLP) shall include quarterly inspections of sensors, dehumidifiers, drain lines, controls, and door sensors. All defects identified shall be rectified promptly, and corrective actions shall be properly recorded.
- b. The Contractor shall provide parts and labour warranty, and comply with the Liquidated Damages (LD) provisions stated in Annex C, Point 7.23 for humidity-related faults.
- c. The Contractor shall comply with the response obligations stated in Table B below.

Table B: Response Obligation

S/N	Fault Type	Response Time
1	Critical humidity	Four (4) hours
2	Condensate overflow alarm	Two (2) hours
3	Non-critical fault	One (1) business day

7.17 Documentation and Handover

Upon completion of the Works, the Contractor must provide:

- a. **Manufacturer's Warranty Certificates** for all new system and material components with a minimum warranty period of five (5) years.
- b. **DLP for workmanship warranty** of one (1) year for all installation works.
- c. Both warranty periods must commence from the **date of Final Completion**. For phased completion, the commencement date must be the **last date of completion**.
- d. During the warranty period, the Contractor must rectify, at no additional cost to the Company, any defects arising from faulty materials, equipment, or workmanship.
- e. **Quarterly preventive maintenance must be included during the one (1) year DLP.*** (refer to SOS/4, Point 5.2, Table A, S/N 7)
- f. Submission of O&M Manuals and **as-built drawings** (hardcopy and softcopy) upon completion of works.

- g. Pre-handover inspection documentation, including timestamped photos or videos, reflecting the final state of the project.

h. The Contractor shall provide a recommended spare parts list and confirm availability of spare parts for a minimum five (5) years after handover.*

7.18 Additional Technical Requirements

- a. All dehumidifier equipment proposed must be of established make with a proven track record and must have been successfully installed and operated in similar institutional, commercial or educational environments.
- b. The Contractor must submit product catalogues, technical specifications, performance data and manufacturer details for approval prior to installation.
- c. The Company reserves the right to reject any equipment deemed unsuitable, excessively noisy, or of insufficient performance capability.

7.19 Equipment Capacity and System Adequacy

- a. The Contractor must be fully responsible for determining the appropriate dehumidifier equipment sizing to maintain target RH at design conditions plus margin for door ingress events. Include latent load calculations that account for infiltration/door openings and occupancy.
- b. Submission of tender must be deemed to indicate that the Contractor has reviewed the site conditions, floor plans and humidity data provided, and has allowed for sufficient equipment capacity.
- c. No additional claims or variation costs must be entertained due to insufficient equipment capacity or incorrect system sizing.

7.20 Site Inspection

- a. Contractor must be deemed to have visited the site and familiarised themselves with the existing site conditions, including corridor layout, access limitations, electrical provisions and building constraints prior to submission of tender.
- b. Any failure to inspect the site must not relieve the Contractor from responsibility for the proper execution and completion of the Works.

7.21 Supporting Information:

- a. Appendix 2: Floor Plan for Level 7 and Level 9;
- b. Appendix 3: Temperature and Humidity Data logger for the selected Music Rooms, provided for reference based on existing room condition. The rooms include:
 - i. Level 7: Electronic Music Studio
 - ii. Level 9: MPR2, MPR8, EPR1, EPR3, EPR5 and EPR9.

7.22 Tender Submission Requirements:

- a. **Contractor must submit only one (1) proposal,*** including preliminary design drawings and supporting documents, to demonstrate their proposed dehumidification system design.

The submission must include, but not be limited to, the following:

- i. Proposed layout drawings indicating the location and quantity of dehumidifier units.
 - ii. Equipment arrangement and installation details (ceiling/wall mounting, enclosure concept, etc.).
 - iii. Schematic diagram showing system configuration and condensate drainage routing;
 - iv. Indicative control strategy and sensor locations;
 - v. Preliminary equipment sizing calculations or design basis;
 - vi. Contractor must clearly indicate equipment model, capacity, and quantity in tabulated format.
- b. Failure to submit the above information may render the tender incomplete and subject to disqualification.

7.23 Liquidated Damages (LD) Schedule

- a. LD may be imposed for project delays and non-compliance with performance requirements.

Table C: LD Schedule

S/N	Scenario	Description	LD Rate	Remarks
1	Overall Project Delay	Failure to complete the Works by Final Completion Date (31 December 2026) .	Singapore Dollars five hundred (S\$500.00) per calendar day	Applies from the day after contractual completion date until actual completion certified.
2	Phase Delay (Phase 1/2/3)	Delay in completion of any approved project phase (Level 7 or Level 9 phases).	Singapore Dollars three hundred (S\$300.00) per calendar day per phase	Applicable per delayed phase until approval is granted.
3	Failure to Meet RH Performance (Post T&C)	Failure to achieve indoor RH forty-five percent (45%) to fifty-five percent (55%) or noise limit less than or equal to fifty (≤50) dB(A) during T&C.	Singapore Dollars five hundred (S\$500.00) per calendar day	Applies from date of failed T&C until successful re-testing and acceptance. Compliance shall be assessed based on continuous sensor recordings. Any RH reading exceeding fifty-five percent (55%) RH for more than thirty (30) continuous minutes within any monitored classroom shall constitute non-compliance.
4	Failure of Night-Time Performance Guarantee	Failure to maintain RH forty-five percent (45%) to fifty-five percent (55%) between 1900 hrs and 0700hrs after handover.	Singapore Dollars three hundred (S\$300.00) per calendar day	Applies after written notification and expiry of agreed rectification period.
5	Rectification Delay After Failed T&C	Delay in rectifying system defects identified during T&C or warranty period.	Singapore Dollars three hundred (S\$300.00) per calendar day	Applies until full compliance is achieved.

Note:

- Maximum total LD must be capped at **ten percent (10%) of Contract Sum**.

2. Only one LD category shall apply to the same underlying default event unless the breach results in distinct and independently measurable impacts.
3. Applicability - LD must only apply where delay is not covered by approved Extension of Time (EOT).
4. Certification - All LD deductions must be certified by the Company's Authorised Representative.
5. Notice Requirement - Contractor must be notified in writing prior to imposition of LD.
6. EOT may be granted for justified delays including client instructions, force majeure events, and unforeseen site conditions, subject to approval.
7. LD under different categories must not be applied concurrently for the same underlying breach unless expressly stated.

7.24 Relationship Between LD and Retention Sum

- a. LD and Retention Sum are separate contractual mechanisms and must operate independently (refer to SOS/17, Table E, Point 7).
- b. The Retention Sum is intended to secure:
 - i. Defects rectification
 - ii. Warranty obligations
 - iii. Minor non-conformance during DLP
- c. LD are intended to compensate the Company for:
 - i. Delay in completion
 - ii. Failure to meet performance requirements
 - iii. Non-compliance during T&C or operational verification
- d. The Company reserves the right to deduct LD from any monies due to the Contractor, including progress payments, without prejudice to the Retention Sum mechanism.

7.25 Company's Right of Set-Off (refer to COC/10, clause 4.3)

- a. The Company must have the right to set off any LD, costs, or losses against:
 - i. Progress payments, and/or
 - ii. Retention monies, and/or
 - iii. Final payment due to the Contractor
- b. Such set-off must not relieve the Contractor from continuing liability where damages exceed amounts recovered.

7.26 Monitoring Period and Progression to Subsequent Phases

- a. Upon completion of installation works for each phase (Phase 1, Phase 2, and Phase 3), the Contractor must undertake a **continuous monitoring and stabilisation period** prior to application for approval to proceed to the next phase.

Table D: Minimum Monitoring Period Requirement

Phase	Scope	Minimum Monitoring Period	Requirement Before Next Phase
Phase 1	Level 7 - Electronic Music Studio	One (1) week continuous monitoring	Stable RH performance within forty-five percent (45%) to fifty-five percent (55%) and compliance with noise requirement less than or equal to fifty (≤ 50) dB(A).
Phase 2	Level 9 - EPR1 to EPR3	One (1) week continuous monitoring	Stable RH performance within forty-five percent (45%) to fifty-five percent (55%) and compliance with noise requirement less than or equal to fifty (≤ 50) dB(A), across Phase 2 areas and verified readings.
Phase 3	Level 9 - MPR1 to MPR9 and EPR4 to EPR9	Two (2) weeks continuous monitoring	Full system stabilisation across all installed zones.

7.27 Monitoring Requirements

- a. During the monitoring period, the **dehumidification system shall remain continuously available for automatic operation on a twenty-four (24)-hour basis.***
- b. Humidity readings must be:
- i. Recorded at **minimum five (5)-minute intervals** (or approved interval); and
 - ii. Logged using calibrated sensors approved by the Company;
- c. The system must be deemed **compliant only if RH remains within forty-five percent (45%) to fifty-five percent (55%) subjected to permitted transient excursions under Point 2.1.**

7.28 Progression Approval Condition

- a. The Contractor must not proceed to the next phase unless:
- i. The full monitoring period has been completed; and
 - ii. A **Monitoring Compliance Report** has been submitted; and
 - iii. Written approval has been granted by the Company's Authorised Representative.

- b. The Monitoring Compliance Report must include:
 - i. Time-stamped RH trend data
 - ii. Sensor calibration records
 - iii. Summary of system performance stability
 - iv. Any corrective actions undertaken during the monitoring period

7.29 Rejection and Re-Monitoring

- a. If the system fails to demonstrate stable compliance during the monitoring period, the Contractor must:
 - i. Carry out rectification works at no additional cost; and
 - ii. Restart the full monitoring period upon completion of rectification.
- b. Any failure during the Monitoring Period shall invalidate the entire monitoring cycle, and the full monitoring duration shall recommence upon completion of rectification works.
- c. Repeated failures must not entitle the Contractor to claim EOT unless formally approved under the EOT provisions.

7.30 System Accessibility and Non-Proprietary Requirement

- a. The dehumidification system must be designed to allow **operation, servicing, and maintenance by third-party contractors** without restriction.
- b. All equipment and control systems must be **non-proprietary** and must not require:
 - i. Manufacturer-exclusive tools, software, or access;
 - ii. OEM-only servicing or authorised agents.
- c. The Contractor must provide all necessary **manuals, drawings, control information, and access credentials** at handover to enable independent maintenance.
- d. Any system found to be proprietary or restricted must be **rejected or replaced at the Contractor's cost**.

7.31 Power Failure Recovery Requirement

- a. Upon restoration of power supply after interruption, the system shall automatically resume operation without manual intervention and restore humidity control automatically.

7.32 Standalone Dehumidifier System

- a. The dehumidification system shall be standalone and independent, and shall not require integration with the existing Building Automation System (BAS) or Building Management System (BMS) for operation, monitoring, control, alarms, or data logging. All functions necessary to maintain the specified humidity performance shall be self-contained within the system.

8 Payment Terms

- 8.1 Payment must be made progressively based on the phased completion of the Works, in accordance with the approved project milestones and subject to certification by the Company's Authorised Representative.
- 8.2 The Company's decision on compliance acceptance shall be final for purposes of progression approval and payment certification.
- 8.3 The proposed payment schedule must be as follows:

Table E: Proposed Payment Schedule

S/N	Payment Milestone	Description	Milestone (%)
1	Initial Payment	Upon Letter of Acceptance, submission of performance bond, insurance, drawings, and preliminaries.	Five percent (5%)
2	Phase 1 Completion	Completion of installation works for Level 7 (Electronic Music Studio), duly inspected and approved by the Company.	Fifteen percent (15%)
3	Phase 2 Completion	Completion of installation works for Level 9 (EPR1 to EPR3), duly inspected and approved by the Company.	Twenty percent (20%)
4	Phase 3 Completion	Completion of remaining Level 9 works (MPR1 to MPR9, EPR4 to EPR9), duly inspected and approved by the Company.	Forty percent (40%)
5	T&C, Final Completion	Upon successful testing, commissioning, and verification of system performance. Submission of O&M manuals, as-built drawings, and final acceptance.	Fifteen percent (15%)
6	Sub-Total		Ninety five percent (95%)
7	Upon expiry of the one (1) year DLP (including completing of quarterly maintenance)	Release of retained sum upon expiry of DLP.	Five percent (5%)
8	Grand Total		Hundred percent (100%)

8.4 Retention Release

- a. The total Retention Sum of **five percent (5%)** must be **released in full upon expiry of the one (1) year DLP**, subject to satisfactory rectification of all defects and fulfilment of contractual obligations.

Annex D:
SELECTION CRITERIA

SELECTION CRITERIA

1.1 Singapore Arts School Limited (the Company) is seeking to enter into a contractual agreement with a Contractor who best addresses the Company's objective to obtain the best value from the Contractor's services. In line with this principle, the Company will adopt the following criteria for the selection of a Contractor.

The tender for Provision of Dehumidifier System and Installation Works at School of the Arts, Singapore shall be evaluated based on the following criteria:

- ✓ a) Submission of Tender on/before the Tender Closing Date and Time;
- ✓ b) Mandatory attendance at Tender Briefing and Site-show;
- ✓ c) Signing of Non-Disclosure Agreement (NDA) to obtain Tender document, Appendix 2: Floor Plan for Level 7 and Level 9 at Site-show;
- d) Compliance with Registration of Tenderers with BCA and Financial Grade:

BCA Registration	Financial Grade	Tendering Limit
ME01 – Air-Conditioning, Refrigeration & Ventilation Works	L1	S\$0.8million
- e) Valid certifications before the Tender registration open date (where applicable);
- f) Compliance with list of required Tender Documents submission (refer to Schedule 1 - Instruction to Tenderers, Point 1);
- ✓ g) Completeness and proper submission of Schedule 3 - Schedule of Price;
- ✓ h) Compliance with all requirements in Annex B (Specification of Works) and Annex C (Scope of Services). Requirements marked with (*) and/or indicated as "Must" or "Mandatory" in Annex B and Annex C are critical and non-compliance may result in disqualification;
- ✓ i) Contractor must submit only one (1) proposal,* including preliminary design drawings and supporting documents, to demonstrate their proposed dehumidification system design (refer to SOS/11, Point 7.22);
- j) Financial capabilities of the Tenderer;
- k) Record of past and current contracts/ projects;
- l) Other relevant certifications (if any).

1.2 The Company is not bound to award to the lowest quotation.

Note: Criteria marked with ✓ are critical.

Annex E:
STATEMENT OF COMPLIANCE

STATEMENT OF COMPLIANCE

* The indication of Compliance (C) or Non-compliance (NC) will be deemed to be applicable to each **main** section, unless it is clearly stated to be otherwise.

** Please indicate the specific items/points of non-compliance where applicable and proposed equivalent customisation or/and workable solutions.

Specification	Compliance (C/NC)*	Explanatory Remark**
ANNEX A - CONDITIONS OF CONTRACT		
1.		
1.1		
1.2		
1.3		
1.4		
1.5		
2.		
2.1		
2.2		
2.2 (a)		
2.2 (b)		
2.2 (c)		
2.2 (d)		
2.3		
3.		
3.1		
3.1 (a)(i)		
3.1 (a)(ii)		
3.1 (a)(iii)		
3.1 (b)		
3.1 (c)		
3.1 (d)		
3.1 (e)		
3.2		
3.2 (a)		
3.2 (b)		
3.2 (c)		
3.2 (d)		
3.2 (e)		
3.3		
3.3 (a)		
3.3 (b)		
3.3 (c)		
3.3 (d)		
3.3 (e)		
3.3 (f)		
3.3 (g)		
3.4		
3.4 (a)		
3.4 (b)(i)		
3.4 (b)(ii)		
3.4 (b)(iii)		
3.4 (b)(iv)		
3.4 (b)(v)		
3.4 (b)(vi)		

Specification	Compliance (C/NC)*	Explanatory Remark**
3.4 (c)		
3.4 (d)		
3.4 (e)		
3.4 (f)		
3.4 (g)(i)		
3.4 (g)(ii)		
3.4 (g)(iii)		
3.4 (h)		
3.4 (i)		
3.4 (j)(i)		
3.4 (j)(ii)		
3.4 (k)		
3.5		
3.5 (a)		
3.5 (b)		
3.5 (c)		
3.6		
3.6 (a)(i)		
3.6 (a)(ii)		
3.6 (b)		
3.6 (c)		
3.6 (d)		
4.		
4.1		
4.2		
4.3		
4.4		
4.4 (a)		
4.4 (b)		
4.4 (c)		
4.4 (d)		
4.4 (e)		
4.4 (f)		
4.4 (g)		
4.4 (h)		
5.		
5.1		
5.1 (a)		
5.1 (b)		
5.1 (c)		
5.2		
5.2 (a)		
5.2 (b)		
5.3		
5.3 (a)		
5.3 (b)		
5.3 (c)		
5.4		
5.5		
5.6		
5.7		
5.7 (a)		
5.7 (b)		

Specification	Compliance (C/NC)*	Explanatory Remark**
5.7 (c)		
5.8		
5.8 (a)		
5.8 (b)		
5.9		
6.		
6.1		
6.2		
7.		
8.		
9.		
10.		
10.1		
10.1.1		
10.1.2		
10.2		
10.2.1		
10.2.2		
11.		
12.		
12.1		
12.1 (a)		
12.1 (b)		
12.1 (c)		
12.2		
12.3		
12.3 (a)		
12.3 (b)		
12.3 (c)		
12.3 (d)		
13.		
14.		
14.1		
14.1.1		
14.1.2		
14.2		
14.3		
14.3.1		
14.3.2		
14.3.3		
14.4		
15.		
16.		
17.		
18.		
19.		
19.1		
19.2		
19.3		
19.4		
20.		
21.		
21.1		

Specification	Compliance (C/NC)*	Explanatory Remark**
21.1 (a)		
21.1 (b)		
21.1 (c)		
21.1 (d)		
21.2		
21.2 (a)		
21.2 (b)		
21.2 (c)		
21.2 (d)		
21.3		
21.4		
22.		
23.		
24.		
25.		
25.1		
25.2		
ANNEX B - SPECIFICATIONS OF WORKS		
1		
1.1		
1.1.1		
1.1.2		
1.1.3		
1.1.4		
1.1.5		
1.1.6		
1.1.7		
1.1.8		
1.1.9		
1.2		
1.2.1		
1.2.2		
1.2.3		
1.2.4		
1.2.5		
1.2.6		
1.2.7		
1.2.8		
2		
2.1		
2.1.1		
2.1.2		
2.1.3		
2.1.4		
2.1.5		
2.1.6		
2.2		
2.2.1		
2.2.2		
2.2.3		
2.2.4		
2.2.5		
2.2.6		

Specification	Compliance (C/NC)*	Explanatory Remark**
2.2.7		
2.2.8		
2.2.9		
2.2.10		
2.2.10 a.		
2.2.10 b.		
2.2.10 c.		
2.2.10 d.		
2.2.10 e.		
2.3		
2.3.1		
2.3.1.1		
2.3.1.2		
2.3.1.3		
2.3.1.4		
2.3.1.5		
2.3.1.6		
3		
3.1		
3.2		
4		
4.1		
4.1.1		
4.1.2		
4.1.3		
ANNEX C - SCOPE OF SERVICES		
1		
2		
2.1		
2.2		
2.3		
2.4		
2.5		
2.6		
2.6 a.		
2.6 b.		
2.6 c.		
2.6 d.		
2.6 e.		
2.7		
2.7 a.		
2.7 b.		
3		
3.1		
3.2		
4		
4.1		
4.2		
4.3		
5		
5.1		
5.2		
6		

Specification	Compliance (C/NC)*	Explanatory Remark**
6.1		
6.2		
6.3		
6.4		
7		
7.1		
7.2		
7.2 a.		
7.2 b.		
7.2 c.		
7.2 d.		
7.2 e.		
7.2 f.		
7.2 g.		
7.3		
7.3 a.		
7.3 b.		
7.3 c.		
7.3 d.		
7.3 e.		
7.3 f.		
7.3 g.		
7.4		
7.4 a.		
7.4 b.		
7.4 c.		
7.4 d.		
7.4 e.		
7.5		
7.5 a. i.		
7.5 a. ii.		
7.6		
7.6 a.		
7.6 b.		
7.6 c.		
7.6 d.		
7.6 e.		
7.7		
7.7 a.		
7.7 b.		
7.8		
7.8 a.		
7.8 b.		
7.8 c.		
7.8 d.		
7.8 e.		
7.8 f.		
7.9		
7.9 a.		
7.9 b.		
7.9 c.		
7.10		
7.10 a.		

Specification	Compliance (C/NC)*	Explanatory Remark**
7.10 b.		
7.10 c.		
7.11		
7.11 a.		
7.11 b.		
7.11 c.		
7.11 d.		
7.12		
7.12 a.		
7.12 b.		
7.12 c.		
7.13		
7.13 a.		
7.13 b.		
7.13 c.		
7.14		
7.14 a.		
7.14 b.		
7.14 c.		
7.14 d. i.		
7.14 d. ii.		
7.14 e.		
7.15		
7.15 a.		
7.15 b.		
7.15 c.		
7.15 d.		
7.15 e.		
7.15 f.		
7.15 g.		
7.15 h.		
7.15 i.		
7.15 j.		
7.15 k.		
7.16		
7.16 a.		
7.16 b.		
7.16 c.		
7.17		
7.17 a.		
7.17 b.		
7.17 c.		
7.17 d.		
7.17 e.		
7.17 f.		
7.17 g.		
7.17 h.		
7.18		
7.18 a.		
7.18 b.		
7.18 c.		
7.19		
7.19 a.		

Specification	Compliance (C/NC)*	Explanatory Remark**
7.19 b.		
7.19 c.		
7.20		
7.20 a.		
7.20 b.		
7.21		
7.21 a.		
7.21 b. i.		
7.21 b. ii.		
7.22		
7.22 a. i.		
7.22 a. ii.		
7.22 a. iii.		
7.22 a. iv.		
7.22 a. v.		
7.22 a. vi.		
7.22 b.		
7.23		
7.23 a.		
7.24		
7.24 a.		
7.24 b. i.		
7.24 b. ii.		
7.24 b. iii.		
7.24 c. i.		
7.24 c. ii.		
7.24 c. iii.		
7.24 d.		
7.25		
7.25 a. i.		
7.25 a. ii.		
7.25 a. iii.		
7.25 b.		
7.26		
7.26 a.		
7.27		
7.27 a.		
7.27 b. i.		
7.27 b. ii.		
7.27 c.		
7.28		
7.28 a. i.		
7.28 a. ii.		
7.28 a. iii.		
7.28 b. i.		
7.28 b. ii.		
7.28 b. iii.		
7.28 b. iv.		
7.29		
7.29 a. i.		
7.29 a. ii.		
7.29 b.		
7.29 c.		

Specification	Compliance (C/NC)*	Explanatory Remark**
7.30		
7.30 a.		
7.30 b. i.		
7.30 b. ii.		
7.30 c.		
7.30 d.		
7.31		
7.31 a.		
7.32		
7.32 a.		
8		
8.1		
8.2		
8.3		
8.4		
8.4 a.		

We fully understand and agree that notwithstanding the fact that the Statement of Compliance as herein declared is subjected to the Company's acceptance.

Dated this _____ day of _____ 202_.

NAME AND SIGNATURE :
(AUTHORISED REPRESENTATIVE) _____

NAME :
(WITNESS) _____

DESIGNATION :
(AUTHORISED REPRESENTATIVE) _____

DESIGNATION :
(WITNESS) _____

DATE : _____

DATE : _____

COMPANY STAMP :
(AUTHORISED REPRESENTATIVE) _____

COMPANY STAMP :
(WITNESS) _____

COMPANY NAME :
(AUTHORISED REPRESENTATIVE) _____

COMPANY NAME :
(WITNESS) _____

Annex F:
**NON-DISCLOSURE AGREEMENT TO
SAFEGUARD OFFICIAL INFORMATION**

To obtain Appendix 2 upon signing of Non-Disclosure Agreement (NDA) at Site-show.

*More information will be provided at Tender Briefing session.

NON-DISCLOSURE AGREEMENT TO SAFEGUARD OFFICIAL INFORMATION**NON-DISCLOSURE AGREEMENT TO SAFEGUARD OFFICIAL INFORMATION**

1. My attention has been drawn to the *Official Secrets Act* (Chapter 213) and in particular to Section 5 thereof which related to the safeguarding of official information.
2. I understand and agree that all official information acquired by me in the course of my work in connection with this project is of a strictly secret and confidential nature, and is not to be published or communicated by me to any other person in any form whatsoever except in the course of my official duties on a strictly "need-to-know" basis.
3. I shall ensure that any other person who is authorised by me to have access to any official information shall similarly sign an undertaking to safeguard official information.
4. I undertake to return any document received from the SAS, any other copies made or reproduced from such document or part thereof whenever required by the SAS.
5. I further understand and agree that any breach or neglect of this undertaking may render me liable to prosecution under the Official Secrets Act.

Signature_____
Full Name in BLOCKS
(Authorised Representative)_____
Designation_____
Company Name and Company Stamp_____
Date_____
Signature of Witness_____
Full Name in BLOCKS_____
Address_____
Date

Appendix 1: **HOUSE RULES**

SINGAPORE ARTS SCHOOL LTD

H O U S E R U L E S

FOR

**AUTHORISED EXTERNAL PARTY
PROVIDING SERVICES TO SOTA**

Updated February 2025

HOUSE RULES

1. ACCESS ROUTE

- 1.1 Access to the works area is only via the **approved route** as directed by the **Singapore Arts School Limited**, hereinafter referred to as **SAS**.
- 1.2 There shall not be any obstruction to any access area / route.
- 1.3 All loading and unloading of materials shall be at designated access points as directed by the SAS.
- 1.4 Closure of access route, if necessary, shall be subject to the SAS's approval.
- 1.5 Temporary lightings and power supply, if necessary, shall be provided to the Authorised External Party (i.e. Contractors / Vendors and/or Lessees) at a fee.
- 1.6 All areas, finishes and installed Mechanical and Electrical (M&E) items along the access routes and other areas should be well protected from any damages, wherever applicable.
- 1.7 2-metre wide dust mat carpet taped to the floor shall be provided to all the access routes as deemed necessary.
- 1.8 All temporary protection on floor and wall shall be removed after practical completion and any damages to be made good to the satisfaction of the SAS.

2 USE OF LIFT CARS AND LANDINGS

- 2.1 The period of use and location of lift / lift landings shall be subject to the SAS's approval.
- 2.2 Only the designated lift shall be used for the transportation of both workers and materials.
- 2.3 All affected lift car walls and floors, landings, architrave, shall be protected by carpet on plywood for floors and padded canvas sheet for vertical surfaces to the satisfaction of the SAS.
- 2.4 All temporary protective linings shall be removed after practical completion and any damages to be made good to the satisfaction of the SAS.
- 2.5 The SAS shall impose a cleaning fee of \$300/- per occasion if any of the Authorised External Party's workers are found using lifts other than the approved lift. In addition, the Authorised External Party would be required to make good any damages found in the lifts used.

3 APPROVED WORK NOTICE

- 3.1 Approved Work Notice must be put up prominently at the work site to the satisfaction of the SAS, to inform the staff and visitors of:
 - the nature of work
 - duration of work including the commencement date of work and estimated date of completion

4 DUMPING OF DEBRIS

- 4.1 Debris to be removed from site daily in an orderly manner.
- 4.2 There will be no dumping anywhere within the SAS premises other than the SAS approved dumping site. All debris shall be disposed in approved dumping sites as directed by the SAS.

- 4.3 The SAS shall impose a clearance fee of S\$500/- on each occasion of illegal dumping by the Authorised External Party, as reimbursement for clearance by the SAS.
- 4.4 Bulk bins are to be placed at designated lots approved by the SAS giving five (5) working days prior notice from the date of use.

5 ROUTINE CLEANING

- 5.1 The dust mat carpeted areas surrounding the working areas are to be vacuumed frequently to keep the dust around the area to its minimum.
- 5.2 Any staircase, corridor and wall at the access routes are to be kept clean at all times.
- 5.3 Any stains, scratches or markings, shall be made good to the SAS's satisfaction.

6 SECURITY PASS

- 6.1 The Authorised External Party is required to submit the list of workers including their Operation Managers with their NRIC Numbers or Work Permit Numbers at least five (5) working days before the commencement date of the works.
- 6.2 Security passes for the workers should be obtained from the Level 2 Security Pass Counter.
- 6.3 Workers including Foreman and Site Supervisor must wear the security passes at all times while working within SAS premises.
- 6.4 While applying for security passes, original documentary proof, i.e. any photo identity cards for Singaporeans, Passport and valid Work Permits for foreign workers must be presented to the Security for checking and verification purposes. Identity cards will not be collected.
- 6.5 The SAS shall conduct regular checks in order to ensure that all workers are in possession of their security passes.
- 6.6 No illegal worker shall be allowed to work within SAS premises. If any illegal worker is found to be in the SAS premises, the SAS as well as the Authorised External Party shall refer the worker to the relevant authorities. The SAS reserves the rights for the immediate removal of the illegal worker from the SAS premises. A penalty of S\$500 will be imposed per person per occasion.

7 SAFETY MATTERS

- 7.1 All works involving drilling, hacking or continuous loud noises are only to be done during approved hours.
- 7.2 The Authorised External Party is required to apply for the approval of any Hot Work (Welding Work) in a separate form to be requested from the SAS Office of Property Management (OPM) . This form has to be submitted to the OPM for approval prior to the commencement of any hot work; Fire Extinguisher must be in place at the site of the hot work, visible to all and can be used in time of emergency;
- 7.3 All High rise and Scaffolding works to be provided with the relevant safety gears (e.g. safety belt/safety helmet/ropes & etc) and the workers must put on the safety gears prior to the work commencement. Work will be stopped immediately upon discovery of breaching of this safety rules and a fine of S\$500 will be imposed.

8 UTILITIES FOR FITTING OUT WORKS

- 8.1 The Authorised External Party shall obtain the SAS's prior written approval for tapping of Power Supply to the premises.
- 8.2 The SAS prior written approval must be obtain to gain access to the relevant M&E services (e.g. main electrical supply etc).
- 8.3 All Authorised External Party is to install electrical protective devices such as Miniature Circuit Breakers (MCBs) or Earth Leakage Circuit Breakers (ELCBs) to all their power supply.
- 8.4 All utilities to be turned off/switched off after use and before leaving the SAS premises.
- 8.5 No Authorised External Party shall be allowed to tap power from any point outside other than the approved tapping point.
- 8.6 Any temporary electricity supply shall be terminated upon completion of the construction work and amount for electricity consumed shall be paid fully to SAS by the Authorised External Party.
- 8.7 Fire Hose reels are not to be used for washing or fitting out work. The Authorised External Party shall obtain SAS's prior approval for tapping water supply.

9 Code of Conduct

All Authorised External Party is expected to:-

- 9.1 display the security pass prominently;
- 9.2 use trolleys or wheel barrows with rubber castors only;
- 9.3 use only designated toilet for Authorised External Party and to observe proper usage of all common facilities like lifts, toilets, car park etc to avoid inconvenience to other users;
- 9.4 use only facilities designated by the OPM for transportation of materials. All Authorised External Party is not permitted to use the passenger's lifts;
- 9.5 keep all building materials and equipment from public areas and not block the corridors and passage ways with building materials and construction / fitting-out debris;
- 9.6 deliver bulky items or equipment at the agreed delivery date and time;
- 9.7 provide appropriate protection to the common areas and equipment wherever necessary to prevent direct damages on it;
- 9.8 take the appropriate measures to ensure safety of workers on site. Due care must be taken so as not to cause damage or injury to persons or property;
- 9.9 give prior written notice of at least five (5) working days to OPM if works done will create excessive dust/smoke and to produce work plan and method statement;
- 9.10 inform and liaise with OPM on the intended means of hoisting or erection of scaffolding;
- 9.11 ensure that no sleeping is allowed in common areas within SAS premises;
- 9.12 ensure that no eating of meals in common areas within SAS premises;
- 9.13 keep the work area in an acceptable hygiene condition and free from food debris;
- 9.14 ensure that no worker is allowed to wash himself / herself in the non-designated toilets;
- 9.15 ensure that no residing in the work area after working hours;
- 9.16 ensure that strictly **"NO SMOKING"** within SAS premises . (will be referred to NEA):

9.17 ensure that any other instructions or rules will be imposed by SAS at the SAS's discretion at any time.

All Authorised External Party should observe proper discipline whilst at SAS Premises. This includes but not limited to the following items listed below.

9.18 Gambling, littering, spitting and any unruly behaviors and creation of public nuisance are strictly prohibited. Any workers found not abiding to the rules shall be ordered to leave SAS premises and the Security Pass shall be withdrawn with immediate effect.

9.19 All workers are to be properly attired at all times while within SAS premises.

9.20 Authorised External Party's vehicles must at all times be parked at prescribed area (i.e. Loading Bay for loading and unloading of goods, materials or equipment) or at the car park of which will be incurred with the hourly car park rates. Vehicles that are found illegally parked in SAS premises will be wheel-clamped. Wheel unclamping fee applies.

9.21 Work safely and responsibly and be aware of responsibility for their actions and behavior. It is the responsibility of all adults to safeguard and promote the welfare of students.

9.22 Avoid contact or interaction with students. Authorised External Party should never give their personal contact details to any student.

9.23 Those Authorised External Party that may need to have contact with students in line with the nature of their work should limit their contact to them within the bounds of their profession or nature of work (e.g. Canteen, Café and Bookshop Vendors, Cleaners and Security Officers).

9.24 Never be in contact with students or befriend them unnecessarily without Office of Property Management Representative's supervision.

9.25 Stay within the agreed work area and access routes, obtain permission if you need to go outside these areas.

9.26 Do not use profane or inappropriate language.

9.27 Observe the Code of Conduct at all times.

10 PENALTY

The SAS shall impose the following amounts being reimbursement of costs for attending to disruption of services caused by the Authorised External Party.

Type of Disruption False fire alarm activation.	Reimbursement S\$500/- for the first occasion S\$1,000/- for subsequent occasions
Type of Disruption Tripping or shutting without prior approval from the SAS or causing breakdown of any services such as Electrical, Plumbing, Gas, etc.	Reimbursement S\$500/- for the first occasion S\$1,000/- for subsequent occasions
Lift breakdown (Jamming of lifts due to poor material handling, etc.)	S\$500/- for the first occasion S\$1,000/- for subsequent occasions
Vandalism	S\$150/- per occasion
Smoking within SAS premises	S\$100/- for the first occasion S\$200/- for subsequent occasions
Workers unauthorised use of passenger lift	S\$150/- for the first occasion S\$300/- for subsequent occasions
Others	

Failure to remove bulky debris	S\$500/- per occasion with an additional clearance fee of S\$500 to clear the debris off-site.
Failure to dispose of rubbish in designated area	S\$200/- per occasion with an additional clearance fee of S\$500 to clear the debris off-site.
Failure to comply with any of the Code of Conduct	S\$100/- per occasion
Failure to inform SAS for any works carried out within SAS premises	S\$100/- per day
Failure to comply with Safety Matters	S\$500/- per occasion
Deploying illegal worker SAS premises	S\$500/- per occasion with immediate removal of the illegal worker from SAS premises. SAS will also lodge a report to Ministry of Manpower (MOM).

11 PERMITTED HOURS FOR WORKS

11.1 The following are the hours within which works can be carried out subject to the SAS's approval with respect to school and venue operations.:

Mondays to Sundays & Public Holidays - 9.00am to 5.30pm

Remarks: - All noisy works to be declared to OPM and carried out during the SAS approved date and time.

11.2 The SAS reserves the right to stop any works anytime if the works disturb the other occupiers in SAS premises or in the neighbouring buildings.

12 ASSISTANCE

If you have queries, please contact Office of Property Management (OPM) at 6338-9663.

The SAS would like to take this opportunity to thank you for your full co-operation.

Thank you.

I have read and agreed to comply with all of the aforementioned House Rules. I further agree that if I do not comply with any of the house rules, the SAS has the right to make deductions from any monies or deposits that are due you.

Name of Authorised External Party's Person-in-charge

Name of Company

Signature / Company Stamp

Date

Appendix 2: **FLOOR PLAN FOR** **LEVEL 7 AND LEVEL 9**

To obtain Appendix 2 upon signing of Non-Disclosure Agreement (NDA) at Site-show.

***More information will be provided at Tender Briefing session.**

Appendix 3:
TEMPERATURE
AND
HUMIDITY DATA LOGGER

Summary of Humidity Readings**(04 Mar 2026 to 09 Mar 2026)**

	Phase 1	Phase 2		Phase 3			
Readings	L7 EMS	L9 EPR1 (24 hours Aircon)	L9 EPR3	L9 MPR2	L9 MPR8	L9 EPR5	L9 EPR9 (24 hours Aircon with Dehumidifier)
04 Mar 2026 15:30hr	22.9°C 66%	23.5°C 73%	19.8°C 81%	26.3°C 79%	26.2°C 70%	20.6°C 88%	20.4°C 61%
05 Mar 2026 11:00hr	22.4°C 70%	22.8°C 70%	23.1°C 76%	27.0°C 81%	26.5°C 71%	19.2°C 73%	18.3°C 79%
05 Mar 2026 23:00hr	23.2°C 66%	24.6°C 81%	22.8°C 75%	26.1°C 78%	23.3°C 67%	21.3°C 96%	22.3°C 36%
06 Mar 2026 03:00hr	23.2°C 66%	25.0°C 82%	23.3°C 78%	26.3°C 78%	24.2°C 70%	24.3°C 89%	21.4°C 35%
06 Mar 2026 11:00hr	22.5°C 70%	24.1°C 65%	24.5°C 78%	23.4°C 71%	25.2°C 71%	19.8°C 89%	20.3°C 59%
06 Mar 2026 23:00hr	23.1°C 67%	24.3°C 81%	18.1°C 86%	19.8°C 92%	25.6°C 66%	23.4°C 84%	21.8°C 35%
07 Mar 2026 03:00hr	23.2°C 66%	24.5°C 81%	23.2°C 89%	23.9°C 91%	25.9°C 68%	23.6°C 84%	21.6°C 40%
07 Mar 2026 11:00hr	22.5°C 70%	25.2°C 82%	19.1°C 86%	18.3°C 85%	26.2°C 67%	24.3°C 84%	20.9°C 59%
07 Mar 2026 23:00hr	23.5°C 67%	25.9°C 82%	17.8°C 87%	18.2°C 76%	26.5°C 65%	24.9°C 81%	21.9°C 39%
08 Mar 2026 03:00hr	23.5°C 66%	25.9°C 82%	23.0°C 90%	24.0°C 91%	26.8°C 68%	25.0°C 81%	21.0°C 36%

Summary of Humidity Readings
(04 Mar 2026 to 09 Mar 2026)

	Phase 1	Phase 2		Phase 3			
Readings	L7 EMS	L9 EPR1 (24 hours Aircon)	L9 EPR3	L9 MPR2	L9 MPR8	L9 EPR5	L9 EPR9 (24 hours Aircon with Dehumidifier)
08 Mar 2026 11:00hr	23.6°C 71%	26.3°C 82%	18.8°C 85%	19.9°C 95%	26.9°C 67%	25.2°C 81%	20.6°C 57%
08 Mar 2026 23:00hr	23.8°C 68%	26.6°C 82%	17.8°C 87%	19.9°C 93%	27.1°C 65%	25.6°C 79%	21.9°C 35%
09 Mar 2026 03:00hr	23.6°C 66%	26.8°C 82%	22.9°C 90%	24.0°C 91%	27.1°C 67%	25.8°C 80%	22.1°C 37%
09 Mar 2026 11:00hr	23.0°C 67%	26.8°C 81%	19.1°C 86%	18.4°C 86%	23.6°C 65%	25.9°C 79%	20.2°C 58%
09 Mar 2026 14:00hr	23.2°C 67%	22.8°C 75%	20.9°C 84%	19.8°C 95%	25.5°C 65%	20.6°C 60%	18.6°C 67%

1. L7_EMS_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	0:00	-	-
04/03/2026	0:15	-	-
04/03/2026	0:30	-	-
04/03/2026	0:45	-	-
04/03/2026	1:00	-	-
04/03/2026	1:15	-	-
04/03/2026	1:30	-	-
04/03/2026	1:45	-	-
04/03/2026	2:00	-	-
04/03/2026	2:15	-	-
04/03/2026	2:30	-	-
04/03/2026	2:45	-	-
04/03/2026	3:00	-	-
04/03/2026	3:15	-	-
04/03/2026	3:30	-	-
04/03/2026	3:45	-	-
04/03/2026	4:00	-	-
04/03/2026	4:15	-	-
04/03/2026	4:30	-	-
04/03/2026	4:45	-	-
04/03/2026	5:00	-	-
04/03/2026	5:15	-	-
04/03/2026	5:30	-	-
04/03/2026	5:45	-	-
04/03/2026	6:00	-	-
04/03/2026	6:15	-	-
04/03/2026	6:30	-	-
04/03/2026	6:45	-	-
04/03/2026	7:00	-	-
04/03/2026	7:15	-	-
04/03/2026	7:30	-	-
04/03/2026	7:45	-	-

04/03/2026	8:00	-	-
04/03/2026	8:15	-	-
04/03/2026	8:30	-	-
04/03/2026	8:45	-	-
04/03/2026	9:00	-	-
04/03/2026	9:15	-	-
04/03/2026	9:30	-	-
04/03/2026	9:45	-	-
04/03/2026	10:00	-	-
04/03/2026	10:15	-	-
04/03/2026	10:30	-	-
04/03/2026	10:45	25.2	68
04/03/2026	11:00	25.5	69
04/03/2026	11:15	26.0	65
04/03/2026	11:30	26.1	65
04/03/2026	11:45	25.5	66
04/03/2026	12:00	25.2	67
04/03/2026	12:15	25.4	69
04/03/2026	12:30	25.6	66
04/03/2026	12:45	25.2	67
04/03/2026	13:00	25.1	67
04/03/2026	13:15	24.8	67
04/03/2026	13:30	24.8	69
04/03/2026	13:45	25.2	69
04/03/2026	14:00	25.2	67
04/03/2026	14:15	25.2	67
04/03/2026	14:30	25.4	69
04/03/2026	14:45	25.5	67
04/03/2026	15:00	25.6	62
04/03/2026	15:15	23.5	65
04/03/2026	Temp & Humidity Data Logger Start 15:30	22.9	66
04/03/2026	15:45	22.8	67
04/03/2026	16:00	22.6	67
04/03/2026	16:15	22.5	70
04/03/2026	16:30	22.5	70
04/03/2026	16:45	22.5	70

04/03/2026	17:00	22.4	70
04/03/2026	17:15	22.6	69
04/03/2026	17:30	22.8	69
04/03/2026	17:45	23.1	69
04/03/2026	18:00	23.2	69
04/03/2026	18:15	23.3	69
04/03/2026	18:30	23.4	68
04/03/2026	18:45	23.5	68
04/03/2026	19:00	23.3	67
04/03/2026	19:15	23.1	68
04/03/2026	19:30	23.2	68
04/03/2026	19:45	23.3	68
04/03/2026	20:00	23.2	67
04/03/2026	20:15	23.2	67
04/03/2026	20:30	23.2	67
04/03/2026	20:45	23.2	67
04/03/2026	21:00	23.2	67
04/03/2026	21:15	23.2	67
04/03/2026	21:30	23.2	67
04/03/2026	21:45	23.2	67
04/03/2026	22:00	23.2	67
04/03/2026	22:15	23.3	67
04/03/2026	22:30	23.2	67
04/03/2026	22:45	23.2	67
04/03/2026	23:00	23.2	67
04/03/2026	23:15	23.2	67
04/03/2026	23:30	23.2	67
04/03/2026	23:45	23.2	67
05/03/2026	0:00	23.2	67
05/03/2026	0:15	23.2	67
05/03/2026	0:30	23.2	66
05/03/2026	0:45	23.2	66
05/03/2026	1:00	23.2	66
05/03/2026	1:15	23.2	66
05/03/2026	1:30	23.2	66
05/03/2026	1:45	23.2	66

05/03/2026	2:00	23.2	66
05/03/2026	2:15	23.2	66
05/03/2026	2:30	23.2	66
05/03/2026	2:45	23.2	66
05/03/2026	3:00	23.2	66
05/03/2026	3:15	23.2	66
05/03/2026	3:30	23.1	66
05/03/2026	3:45	23.2	66
05/03/2026	4:00	23.2	66
05/03/2026	4:15	23.2	66
05/03/2026	4:30	23.1	66
05/03/2026	4:45	23.1	66
05/03/2026	5:00	23.1	66
05/03/2026	5:15	23.1	66
05/03/2026	5:30	23.1	66
05/03/2026	5:45	23.1	66
05/03/2026	6:00	23.1	66
05/03/2026	6:15	23.1	65
05/03/2026	6:30	23.1	65
05/03/2026	6:45	23.1	65
05/03/2026	7:00	23.1	65
05/03/2026	7:15	23.1	65
05/03/2026	7:30	22.8	65
05/03/2026	7:45	22.3	67
05/03/2026	8:00	22.3	68
05/03/2026	8:15	22.3	68
05/03/2026	8:30	22.3	69
05/03/2026	8:45	22.4	69
05/03/2026	9:00	22.4	69
05/03/2026	9:15	22.5	69
05/03/2026	9:30	22.4	69
05/03/2026	9:45	22.5	70
05/03/2026	10:00	22.5	70
05/03/2026	10:15	22.5	70
05/03/2026	10:30	22.4	69
05/03/2026	10:45	22.4	70

05/03/2026	11:00	22.4	70
05/03/2026	11:15	22.5	70
05/03/2026	11:30	22.5	70
05/03/2026	11:45	22.5	70
05/03/2026	12:00	22.3	70
05/03/2026	12:15	22.5	70
05/03/2026	12:30	22.4	70
05/03/2026	12:45	22.4	70
05/03/2026	13:00	22.5	70
05/03/2026	13:15	22.4	70
05/03/2026	13:30	22.5	70
05/03/2026	13:45	22.4	70
05/03/2026	14:00	22.5	70
05/03/2026	14:15	22.5	70
05/03/2026	14:30	22.5	70
05/03/2026	14:45	22.5	70
05/03/2026	15:00	22.5	70
05/03/2026	15:15	22.5	70
05/03/2026	15:30	22.5	70
05/03/2026	15:45	22.8	69
05/03/2026	16:00	23.0	69
05/03/2026	16:15	23.2	69
05/03/2026	16:30	23.4	69
05/03/2026	16:45	23.6	69
05/03/2026	17:00	23.8	68
05/03/2026	17:15	23.9	68
05/03/2026	17:30	23.9	68
05/03/2026	17:45	23.9	67
05/03/2026	18:00	23.6	67
05/03/2026	18:15	23.3	67
05/03/2026	18:30	23.3	67
05/03/2026	18:45	23.1	67
05/03/2026	19:00	23.1	67
05/03/2026	19:15	23.1	68
05/03/2026	19:30	23.2	68
05/03/2026	19:45	23.2	68

05/03/2026	20:00	23.2	67
05/03/2026	20:15	23.2	67
05/03/2026	20:30	23.2	67
05/03/2026	20:45	23.2	67
05/03/2026	21:00	23.2	67
05/03/2026	21:15	23.2	67
05/03/2026	21:30	23.3	67
05/03/2026	21:45	23.3	67
05/03/2026	22:00	23.2	67
05/03/2026	22:15	23.2	67
05/03/2026	22:30	23.2	67
05/03/2026	22:45	23.2	67
05/03/2026	23:00	23.2	66
05/03/2026	23:15	23.3	66
05/03/2026	23:30	23.2	66
05/03/2026	23:45	23.3	66
06/03/2026	0:00	23.2	66
06/03/2026	0:15	23.2	66
06/03/2026	0:30	23.2	66
06/03/2026	0:45	23.2	66
06/03/2026	1:00	23.2	66
06/03/2026	1:15	23.2	66
06/03/2026	1:30	23.2	66
06/03/2026	1:45	23.2	66
06/03/2026	2:00	23.2	66
06/03/2026	2:15	23.2	66
06/03/2026	2:30	23.1	66
06/03/2026	2:45	23.3	66
06/03/2026	3:00	23.2	66
06/03/2026	3:15	23.1	66
06/03/2026	3:30	23.2	66
06/03/2026	3:45	23.2	66
06/03/2026	4:00	23.1	66
06/03/2026	4:15	23.1	66
06/03/2026	4:30	23.1	66
06/03/2026	4:45	23.1	65

06/03/2026	5:00	23.1	65
06/03/2026	5:15	23.1	65
06/03/2026	5:30	23.1	65
06/03/2026	5:45	23.1	65
06/03/2026	6:00	23.1	65
06/03/2026	6:15	23.1	65
06/03/2026	6:30	23.2	65
06/03/2026	6:45	23.1	65
06/03/2026	7:00	23.1	65
06/03/2026	7:15	23.1	65
06/03/2026	7:30	22.8	65
06/03/2026	7:45	22.5	67
06/03/2026	8:00	22.5	67
06/03/2026	8:15	22.4	67
06/03/2026	8:30	22.4	68
06/03/2026	8:45	22.4	68
06/03/2026	9:00	22.5	69
06/03/2026	9:15	22.4	69
06/03/2026	9:30	22.6	67
06/03/2026	9:45	22.5	69
06/03/2026	10:00	22.4	70
06/03/2026	10:15	22.5	69
06/03/2026	10:30	22.6	67
06/03/2026	10:45	22.6	67
06/03/2026	11:00	22.5	70
06/03/2026	11:15	22.6	67
06/03/2026	11:30	22.6	68
06/03/2026	11:45	22.5	70
06/03/2026	12:00	22.6	68
06/03/2026	12:15	22.6	68
06/03/2026	12:30	22.6	68
06/03/2026	12:45	22.6	68
06/03/2026	13:00	22.6	67
06/03/2026	13:15	22.6	67
06/03/2026	13:30	22.6	68
06/03/2026	13:45	22.8	68

06/03/2026	14:00	22.6	68
06/03/2026	14:15	22.6	68
06/03/2026	14:30	22.6	67
06/03/2026	14:45	22.8	68
06/03/2026	15:00	22.8	67
06/03/2026	15:15	22.6	67
06/03/2026	15:30	22.6	68
06/03/2026	15:45	22.8	68
06/03/2026	16:00	22.8	68
06/03/2026	16:15	22.6	67
06/03/2026	16:30	22.8	67
06/03/2026	16:45	22.8	68
06/03/2026	17:00	22.8	68
06/03/2026	17:15	22.6	68
06/03/2026	17:30	22.6	68
06/03/2026	17:45	22.8	69
06/03/2026	18:00	22.6	69
06/03/2026	18:15	22.6	68
06/03/2026	18:30	22.6	69
06/03/2026	18:45	22.6	69
06/03/2026	19:00	22.6	69
06/03/2026	19:15	22.6	69
06/03/2026	19:30	22.8	69
06/03/2026	19:45	22.9	69
06/03/2026	20:00	22.9	68
06/03/2026	20:15	23.0	68
06/03/2026	20:30	23.1	68
06/03/2026	20:45	23.1	67
06/03/2026	21:00	23.1	68
06/03/2026	21:15	23.1	68
06/03/2026	21:30	23.1	67
06/03/2026	21:45	23.1	67
06/03/2026	22:00	23.1	67
06/03/2026	22:15	23.1	67
06/03/2026	22:30	23.1	67
06/03/2026	22:45	23.1	67

06/03/2026	23:00	23.1	67
06/03/2026	23:15	23.1	67
06/03/2026	23:30	23.2	67
06/03/2026	23:45	23.1	67
07/03/2026	0:00	23.1	66
07/03/2026	0:15	23.1	66
07/03/2026	0:30	23.1	66
07/03/2026	0:45	23.1	66
07/03/2026	1:00	23.1	66
07/03/2026	1:15	23.1	66
07/03/2026	1:30	23.1	66
07/03/2026	1:45	23.1	66
07/03/2026	2:00	23.1	66
07/03/2026	2:15	23.2	66
07/03/2026	2:30	23.1	66
07/03/2026	2:45	23.1	66
07/03/2026	3:00	23.2	66
07/03/2026	3:15	23.2	66
07/03/2026	3:30	23.2	66
07/03/2026	3:45	23.2	66
07/03/2026	4:00	23.1	66
07/03/2026	4:15	23.1	66
07/03/2026	4:30	23.1	66
07/03/2026	4:45	23.2	66
07/03/2026	5:00	23.1	66
07/03/2026	5:15	23.1	66
07/03/2026	5:30	23.1	66
07/03/2026	5:45	23.1	66
07/03/2026	6:00	23.1	66
07/03/2026	6:15	23.1	66
07/03/2026	6:30	23.1	66
07/03/2026	6:45	23.1	66
07/03/2026	7:00	23.1	66
07/03/2026	7:15	23.1	65
07/03/2026	7:30	22.6	65
07/03/2026	7:45	22.5	67

07/03/2026	8:00	22.4	69
07/03/2026	8:15	22.5	69
07/03/2026	8:30	22.6	67
07/03/2026	8:45	22.6	67
07/03/2026	9:00	22.6	67
07/03/2026	9:15	22.5	70
07/03/2026	9:30	22.6	67
07/03/2026	9:45	22.6	68
07/03/2026	10:00	22.6	68
07/03/2026	10:15	22.5	70
07/03/2026	10:30	22.6	68
07/03/2026	10:45	22.6	68
07/03/2026	11:00	22.5	70
07/03/2026	11:15	22.8	68
07/03/2026	11:30	22.6	68
07/03/2026	11:45	22.6	68
07/03/2026	12:00	22.6	69
07/03/2026	12:15	22.6	69
07/03/2026	12:30	22.6	69
07/03/2026	12:45	22.8	69
07/03/2026	13:00	22.8	69
07/03/2026	13:15	22.6	69
07/03/2026	13:30	22.8	69
07/03/2026	13:45	22.6	69
07/03/2026	14:00	22.8	68
07/03/2026	14:15	22.6	68
07/03/2026	14:30	22.6	68
07/03/2026	14:45	22.8	68
07/03/2026	15:00	22.8	68
07/03/2026	15:15	22.8	69
07/03/2026	15:30	22.8	69
07/03/2026	15:45	22.8	69
07/03/2026	16:00	22.6	69
07/03/2026	16:15	22.8	69
07/03/2026	16:30	22.8	69
07/03/2026	16:45	22.8	69

07/03/2026	17:00	22.8	69
07/03/2026	17:15	22.8	68
07/03/2026	17:30	22.8	68
07/03/2026	17:45	22.8	68
07/03/2026	18:00	22.9	69
07/03/2026	18:15	22.8	69
07/03/2026	18:30	22.8	69
07/03/2026	18:45	22.9	69
07/03/2026	19:00	22.8	69
07/03/2026	19:15	22.9	69
07/03/2026	19:30	23.0	69
07/03/2026	19:45	23.1	68
07/03/2026	20:00	23.2	68
07/03/2026	20:15	23.2	68
07/03/2026	20:30	23.3	68
07/03/2026	20:45	23.3	69
07/03/2026	21:00	23.3	68
07/03/2026	21:15	23.4	68
07/03/2026	21:30	23.3	68
07/03/2026	21:45	23.4	67
07/03/2026	22:00	23.4	67
07/03/2026	22:15	23.5	67
07/03/2026	22:30	23.4	67
07/03/2026	22:45	23.4	67
07/03/2026	23:00	23.5	67
07/03/2026	23:15	23.5	67
07/03/2026	23:30	23.5	67
07/03/2026	23:45	23.5	67
08/03/2026	0:00	23.5	67
08/03/2026	0:15	23.4	67
08/03/2026	0:30	23.4	67
08/03/2026	0:45	23.4	67
08/03/2026	1:00	23.4	67
08/03/2026	1:15	23.3	66
08/03/2026	1:30	23.4	66
08/03/2026	1:45	23.5	67

08/03/2026	2:00	23.5	66
08/03/2026	2:15	23.4	66
08/03/2026	2:30	23.5	66
08/03/2026	2:45	23.5	67
08/03/2026	3:00	23.5	66
08/03/2026	3:15	23.5	66
08/03/2026	3:30	23.4	66
08/03/2026	3:45	23.5	66
08/03/2026	4:00	23.4	66
08/03/2026	4:15	23.4	66
08/03/2026	4:30	23.4	66
08/03/2026	4:45	23.4	66
08/03/2026	5:00	23.4	66
08/03/2026	5:15	23.3	66
08/03/2026	5:30	23.3	66
08/03/2026	5:45	23.5	66
08/03/2026	6:00	23.3	66
08/03/2026	6:15	23.3	66
08/03/2026	6:30	23.3	66
08/03/2026	6:45	23.4	66
08/03/2026	7:00	23.4	66
08/03/2026	7:15	23.3	65
08/03/2026	7:30	23.0	65
08/03/2026	7:45	22.6	65
08/03/2026	8:00	22.6	66
08/03/2026	8:15	22.8	67
08/03/2026	8:30	23.0	69
08/03/2026	8:45	23.2	69
08/03/2026	9:00	23.2	70
08/03/2026	9:15	23.5	71
08/03/2026	9:30	23.5	71
08/03/2026	9:45	23.5	71
08/03/2026	10:00	23.5	71
08/03/2026	10:15	23.6	71
08/03/2026	10:30	23.5	71
08/03/2026	10:45	23.6	71

08/03/2026	11:00	23.6	71
08/03/2026	11:15	23.6	71
08/03/2026	11:30	23.8	71
08/03/2026	11:45	23.8	71
08/03/2026	12:00	23.8	71
08/03/2026	12:15	23.5	70
08/03/2026	12:30	23.3	70
08/03/2026	12:45	23.3	70
08/03/2026	13:00	23.2	70
08/03/2026	13:15	23.2	69
08/03/2026	13:30	23.1	69
08/03/2026	13:45	23.1	69
08/03/2026	14:00	23.1	69
08/03/2026	14:15	23.1	69
08/03/2026	14:30	23.1	69
08/03/2026	14:45	23.1	69
08/03/2026	15:00	23.1	69
08/03/2026	15:15	23.1	69
08/03/2026	15:30	23.1	69
08/03/2026	15:45	23.1	68
08/03/2026	16:00	23.1	68
08/03/2026	16:15	23.1	68
08/03/2026	16:30	23.1	68
08/03/2026	16:45	23.1	68
08/03/2026	17:00	23.1	68
08/03/2026	17:15	23.1	68
08/03/2026	17:30	23.1	69
08/03/2026	17:45	23.1	69
08/03/2026	18:00	23.1	69
08/03/2026	18:15	23.1	69
08/03/2026	18:30	23.1	69
08/03/2026	18:45	23.1	69
08/03/2026	19:00	23.1	69
08/03/2026	19:15	23.1	69
08/03/2026	19:30	23.3	69
08/03/2026	19:45	23.4	69

08/03/2026	20:00	23.4	69
08/03/2026	20:15	23.6	69
08/03/2026	20:30	23.6	69
08/03/2026	20:45	23.5	69
08/03/2026	21:00	23.6	69
08/03/2026	21:15	23.6	68
08/03/2026	21:30	23.6	68
08/03/2026	21:45	23.8	68
08/03/2026	22:00	23.6	68
08/03/2026	22:15	23.8	68
08/03/2026	22:30	23.8	68
08/03/2026	22:45	23.8	68
08/03/2026	23:00	23.8	68
08/03/2026	23:15	23.8	67
08/03/2026	23:30	23.6	67
08/03/2026	23:45	23.8	67
09/03/2026	0:00	23.6	67
09/03/2026	0:15	23.8	67
09/03/2026	0:30	23.8	67
09/03/2026	0:45	23.8	67
09/03/2026	1:00	23.8	67
09/03/2026	1:15	23.6	66
09/03/2026	1:30	23.6	66
09/03/2026	1:45	23.6	66
09/03/2026	2:00	23.6	66
09/03/2026	2:15	23.6	67
09/03/2026	2:30	23.8	66
09/03/2026	2:45	23.6	66
09/03/2026	3:00	23.6	66
09/03/2026	3:15	23.6	66
09/03/2026	3:30	23.6	66
09/03/2026	3:45	23.6	66
09/03/2026	4:00	23.6	66
09/03/2026	4:15	23.6	66
09/03/2026	4:30	23.6	66
09/03/2026	4:45	23.6	66

09/03/2026	5:00	23.5	66
09/03/2026	5:15	23.5	66
09/03/2026	5:30	23.5	66
09/03/2026	5:45	23.6	66
09/03/2026	6:00	23.5	65
09/03/2026	6:15	23.5	65
09/03/2026	6:30	23.5	65
09/03/2026	6:45	23.5	65
09/03/2026	7:00	23.5	65
09/03/2026	7:15	23.5	65
09/03/2026	7:30	23.1	65
09/03/2026	7:45	22.9	65
09/03/2026	8:00	22.8	66
09/03/2026	8:15	22.9	66
09/03/2026	8:30	22.9	66
09/03/2026	8:45	22.9	66
09/03/2026	9:00	22.9	66
09/03/2026	9:15	22.9	66
09/03/2026	9:30	22.9	67
09/03/2026	9:45	22.9	67
09/03/2026	10:00	22.9	67
09/03/2026	10:15	23.0	67
09/03/2026	10:30	23.0	67
09/03/2026	10:45	23.0	67
09/03/2026	11:00	23.0	67
09/03/2026	11:15	23.0	67
09/03/2026	11:30	23.0	67
09/03/2026	11:45	23.0	67
09/03/2026	12:00	22.9	67
09/03/2026	12:15	23.0	67
09/03/2026	12:30	22.9	67
09/03/2026	12:45	23.0	67
09/03/2026	13:00	22.9	67
09/03/2026	13:15	22.9	67
09/03/2026	13:30	22.9	67
09/03/2026	13:45	23.2	67

09/03/2026	Temp & Humidity Data Logger Ends	14:00	23.2	67
09/03/2026		14:15	23.2	67
09/03/2026		14:30	23.2	67
09/03/2026		14:45	23.3	67
09/03/2026		15:00	23.5	68
09/03/2026		15:15	25.6	67
09/03/2026		15:30	25.3	67
09/03/2026		15:45	25.2	67
09/03/2026		16:00	25.0	67

2. L9_MPR2_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	10:45	25.3	67
04/03/2026	11:00	25.2	66
04/03/2026	11:15	25.2	65
04/03/2026	11:30	25.6	67
04/03/2026	11:45	25.2	67
04/03/2026	12:00	25.0	69
04/03/2026	12:15	25.2	69
04/03/2026	12:30	25.3	66
04/03/2026	12:45	25.2	66
04/03/2026	13:00	25.0	66
04/03/2026	13:15	24.9	66
04/03/2026	13:30	24.9	66
04/03/2026	13:45	25.0	66
04/03/2026	14:00	25.1	66
04/03/2026	14:15	25.2	67
04/03/2026	14:30	25.3	66
04/03/2026	14:45	25.3	66
04/03/2026	15:00	25.9	75
04/03/2026	15:15	26.4	79
04/03/2026	Temp & Humidity Data Logger Start 15:30	26.3	79
04/03/2026	15:45	26.5	80
04/03/2026	16:00	26.5	80
04/03/2026	16:15	26.5	80
04/03/2026	16:30	26.5	80
04/03/2026	16:45	26.5	80
04/03/2026	17:00	26.5	80
04/03/2026	17:15	26.5	81
04/03/2026	17:30	26.4	81
04/03/2026	17:45	26.5	81
04/03/2026	18:00	26.5	81
04/03/2026	18:15	26.5	81
04/03/2026	18:30	26.5	81

04/03/2026	18:45	26.5	81
04/03/2026	19:00	26.5	81
04/03/2026	19:15	26.5	81
04/03/2026	19:30	26.5	81
04/03/2026	19:45	26.5	81
04/03/2026	20:00	26.5	81
04/03/2026	20:15	26.5	81
04/03/2026	20:30	26.5	81
04/03/2026	20:45	26.6	81
04/03/2026	21:00	26.5	81
04/03/2026	21:15	26.6	81
04/03/2026	21:30	26.6	81
04/03/2026	21:45	26.5	81
04/03/2026	22:00	26.6	81
04/03/2026	22:15	26.6	81
04/03/2026	22:30	26.6	81
04/03/2026	22:45	26.6	81
04/03/2026	23:00	26.8	81
04/03/2026	23:15	26.6	81
04/03/2026	23:30	26.8	81
04/03/2026	23:45	26.8	81
05/03/2026	0:00	26.6	81
05/03/2026	0:15	26.6	81
05/03/2026	0:30	26.8	81
05/03/2026	0:45	26.8	81
05/03/2026	1:00	26.8	81
05/03/2026	1:15	26.8	81
05/03/2026	1:30	26.8	81
05/03/2026	1:45	26.8	81
05/03/2026	2:00	26.8	81
05/03/2026	2:15	26.8	81
05/03/2026	2:30	26.8	81
05/03/2026	2:45	26.8	81
05/03/2026	3:00	26.8	81
05/03/2026	3:15	26.9	81
05/03/2026	3:30	26.9	81

05/03/2026	3:45	26.9	81
05/03/2026	4:00	26.9	81
05/03/2026	4:15	26.9	81
05/03/2026	4:30	26.9	81
05/03/2026	4:45	26.9	81
05/03/2026	5:00	26.9	81
05/03/2026	5:15	26.9	81
05/03/2026	5:30	26.8	81
05/03/2026	5:45	26.9	81
05/03/2026	6:00	26.9	81
05/03/2026	6:15	26.9	81
05/03/2026	6:30	26.9	81
05/03/2026	6:45	26.9	81
05/03/2026	7:00	26.9	81
05/03/2026	7:15	26.9	81
05/03/2026	7:30	27.0	81
05/03/2026	7:45	27.0	81
05/03/2026	8:00	27.0	81
05/03/2026	8:15	26.9	81
05/03/2026	8:30	26.9	81
05/03/2026	8:45	27.0	81
05/03/2026	9:00	27.0	81
05/03/2026	9:15	27.0	81
05/03/2026	9:30	27.0	81
05/03/2026	9:45	26.9	81
05/03/2026	10:00	27.0	81
05/03/2026	10:15	27.0	81
05/03/2026	10:30	27.0	81
05/03/2026	10:45	27.0	81
05/03/2026	11:00	27.0	81
05/03/2026	11:15	26.9	81
05/03/2026	11:30	27.1	81
05/03/2026	11:45	26.9	81
05/03/2026	12:00	26.9	74
05/03/2026	12:15	23.1	51
05/03/2026	12:30	23.2	67

05/03/2026	12:45	23.8	73
05/03/2026	13:00	24.2	75
05/03/2026	13:15	24.6	77
05/03/2026	13:30	24.9	78
05/03/2026	13:45	25.1	78
05/03/2026	14:00	25.1	78
05/03/2026	14:15	25.2	78
05/03/2026	14:30	25.4	78
05/03/2026	14:45	25.5	79
05/03/2026	15:00	25.5	79
05/03/2026	15:15	25.6	79
05/03/2026	15:30	25.8	79
05/03/2026	15:45	25.9	79
05/03/2026	16:00	25.9	79
05/03/2026	16:15	25.9	79
05/03/2026	16:30	25.9	78
05/03/2026	16:45	26.0	78
05/03/2026	17:00	26.0	78
05/03/2026	17:15	25.9	78
05/03/2026	17:30	26.0	78
05/03/2026	17:45	26.0	78
05/03/2026	18:00	26.0	78
05/03/2026	18:15	26.0	78
05/03/2026	18:30	26.0	78
05/03/2026	18:45	26.1	78
05/03/2026	19:00	26.0	78
05/03/2026	19:15	26.1	78
05/03/2026	19:30	26.1	78
05/03/2026	19:45	26.1	78
05/03/2026	20:00	26.1	78
05/03/2026	20:15	26.1	78
05/03/2026	20:30	26.1	78
05/03/2026	20:45	26.2	78
05/03/2026	21:00	26.2	78
05/03/2026	21:15	26.2	78
05/03/2026	21:30	26.2	78

05/03/2026	21:45	26.1	78
05/03/2026	22:00	26.2	78
05/03/2026	22:15	26.2	78
05/03/2026	22:30	26.2	78
05/03/2026	22:45	26.2	78
05/03/2026	23:00	26.1	78
05/03/2026	23:15	26.2	78
05/03/2026	23:30	26.2	78
05/03/2026	23:45	26.2	78
06/03/2026	0:00	26.2	78
06/03/2026	0:15	26.2	78
06/03/2026	0:30	26.2	78
06/03/2026	0:45	26.3	78
06/03/2026	1:00	26.2	78
06/03/2026	1:15	26.2	78
06/03/2026	1:30	26.3	78
06/03/2026	1:45	26.2	78
06/03/2026	2:00	26.3	78
06/03/2026	2:15	26.3	78
06/03/2026	2:30	26.3	78
06/03/2026	2:45	26.3	78
06/03/2026	3:00	26.3	78
06/03/2026	3:15	26.3	78
06/03/2026	3:30	26.3	78
06/03/2026	3:45	26.4	78
06/03/2026	4:00	26.4	78
06/03/2026	4:15	26.4	78
06/03/2026	4:30	26.4	78
06/03/2026	4:45	26.4	78
06/03/2026	5:00	26.4	78
06/03/2026	5:15	26.5	78
06/03/2026	5:30	26.4	78
06/03/2026	5:45	26.5	78
06/03/2026	6:00	26.4	78
06/03/2026	6:15	26.5	78
06/03/2026	6:30	26.5	78

06/03/2026	6:45	26.5	78
06/03/2026	7:00	26.5	78
06/03/2026	7:15	26.5	78
06/03/2026	7:30	26.5	78
06/03/2026	7:45	26.5	78
06/03/2026	8:00	26.5	78
06/03/2026	8:15	26.5	78
06/03/2026	8:30	26.5	78
06/03/2026	8:45	26.5	78
06/03/2026	9:00	26.5	79
06/03/2026	9:15	26.6	79
06/03/2026	9:30	26.1	51
06/03/2026	9:45	21.6	48
06/03/2026	10:00	21.4	61
06/03/2026	10:15	22.1	66
06/03/2026	10:30	22.6	66
06/03/2026	10:45	23.1	69
06/03/2026	11:00	23.4	71
06/03/2026	11:15	23.6	73
06/03/2026	11:30	23.9	74
06/03/2026	11:45	24.0	74
06/03/2026	12:00	24.3	74
06/03/2026	12:15	24.3	74
06/03/2026	12:30	24.5	74
06/03/2026	12:45	24.6	75
06/03/2026	13:00	24.6	75
06/03/2026	13:15	24.8	75
06/03/2026	13:30	24.9	75
06/03/2026	13:45	25.0	75
06/03/2026	14:00	25.1	75
06/03/2026	14:15	25.2	75
06/03/2026	14:30	25.2	75
06/03/2026	14:45	25.2	75
06/03/2026	15:00	25.3	75
06/03/2026	15:15	25.5	76
06/03/2026	15:30	22.0	49

06/03/2026	15:45	19.2	53
06/03/2026	16:00	17.5	59
06/03/2026	16:15	16.5	63
06/03/2026	16:30	17.6	87
06/03/2026	16:45	19.3	94
06/03/2026	17:00	19.1	75
06/03/2026	17:15	17.6	72
06/03/2026	17:30	18.2	89
06/03/2026	17:45	19.6	94
06/03/2026	18:00	19.6	87
06/03/2026	18:15	18.1	71
06/03/2026	18:30	17.5	86
06/03/2026	18:45	18.8	92
06/03/2026	19:00	19.8	95
06/03/2026	19:15	19.4	84
06/03/2026	19:30	18.0	74
06/03/2026	19:45	17.8	84
06/03/2026	20:00	18.5	91
06/03/2026	20:15	19.6	95
06/03/2026	20:30	20.3	96
06/03/2026	20:45	18.8	70
06/03/2026	21:00	17.6	85
06/03/2026	21:15	18.8	93
06/03/2026	21:30	19.9	96
06/03/2026	21:45	20.3	96
06/03/2026	22:00	18.3	69
06/03/2026	22:15	17.9	87
06/03/2026	22:30	18.9	94
06/03/2026	22:45	20.1	96
06/03/2026	23:00	19.8	92
06/03/2026	23:15	19.3	90
06/03/2026	23:30	20.1	95
06/03/2026	23:45	20.6	96
07/03/2026	0:00	21.2	96
07/03/2026	0:15	21.5	96
07/03/2026	0:30	21.9	96

07/03/2026	0:45	22.2	96
07/03/2026	1:00	22.4	96
07/03/2026	1:15	22.6	93
07/03/2026	1:30	22.8	92
07/03/2026	1:45	23.1	92
07/03/2026	2:00	23.2	92
07/03/2026	2:15	23.3	91
07/03/2026	2:30	23.6	91
07/03/2026	2:45	23.8	91
07/03/2026	3:00	23.9	91
07/03/2026	3:15	24.1	91
07/03/2026	3:30	24.2	91
07/03/2026	3:45	24.4	90
07/03/2026	4:00	24.5	90
07/03/2026	4:15	24.6	90
07/03/2026	4:30	24.8	90
07/03/2026	4:45	24.9	89
07/03/2026	5:00	25.0	89
07/03/2026	5:15	25.1	89
07/03/2026	5:30	25.3	89
07/03/2026	5:45	25.2	89
07/03/2026	6:00	25.4	89
07/03/2026	6:15	25.5	88
07/03/2026	6:30	25.8	88
07/03/2026	6:45	25.8	87
07/03/2026	7:00	25.8	87
07/03/2026	7:15	23.2	58
07/03/2026	7:30	20.3	60
07/03/2026	7:45	18.8	73
07/03/2026	8:00	17.6	62
07/03/2026	8:15	17.3	85
07/03/2026	8:30	19.1	92
07/03/2026	8:45	20.0	94
07/03/2026	9:00	18.6	73
07/03/2026	9:15	17.9	81
07/03/2026	9:30	18.3	86

07/03/2026	9:45	18.5	86
07/03/2026	10:00	18.5	85
07/03/2026	10:15	18.4	85
07/03/2026	10:30	18.5	85
07/03/2026	10:45	18.4	85
07/03/2026	11:00	18.3	85
07/03/2026	11:15	18.4	85
07/03/2026	11:30	18.3	85
07/03/2026	11:45	18.2	85
07/03/2026	12:00	18.6	90
07/03/2026	12:15	19.8	94
07/03/2026	12:30	20.5	95
07/03/2026	12:45	19.9	80
07/03/2026	13:00	18.1	76
07/03/2026	13:15	18.6	91
07/03/2026	13:30	19.8	95
07/03/2026	13:45	20.3	95
07/03/2026	14:00	18.9	75
07/03/2026	14:15	18.2	86
07/03/2026	14:30	19.3	94
07/03/2026	14:45	20.2	95
07/03/2026	15:00	19.2	77
07/03/2026	15:15	18.2	83
07/03/2026	15:30	19.1	93
07/03/2026	15:45	20.0	95
07/03/2026	16:00	20.2	92
07/03/2026	16:15	18.1	72
07/03/2026	16:30	18.2	89
07/03/2026	16:45	19.3	94
07/03/2026	17:00	20.3	96
07/03/2026	17:15	19.3	79
07/03/2026	17:30	17.9	81
07/03/2026	17:45	18.8	92
07/03/2026	18:00	19.9	95
07/03/2026	18:15	20.3	95
07/03/2026	18:30	18.1	72

07/03/2026	18:45	18.5	90
07/03/2026	19:00	19.6	95
07/03/2026	19:15	20.3	96
07/03/2026	19:30	18.8	74
07/03/2026	19:45	18.3	88
07/03/2026	20:00	19.3	94
07/03/2026	20:15	20.3	96
07/03/2026	20:30	19.3	83
07/03/2026	20:45	17.9	81
07/03/2026	21:00	18.8	92
07/03/2026	21:15	19.9	95
07/03/2026	21:30	20.3	96
07/03/2026	21:45	18.8	76
07/03/2026	22:00	18.1	86
07/03/2026	22:15	19.1	94
07/03/2026	22:30	20.1	96
07/03/2026	22:45	20.0	94
07/03/2026	23:00	18.2	76
07/03/2026	23:15	18.3	89
07/03/2026	23:30	19.4	95
07/03/2026	23:45	20.2	96
08/03/2026	0:00	20.9	96
08/03/2026	0:15	21.3	97
08/03/2026	0:30	21.6	97
08/03/2026	0:45	22.1	97
08/03/2026	1:00	22.3	97
08/03/2026	1:15	22.5	96
08/03/2026	1:30	22.8	93
08/03/2026	1:45	23.0	92
08/03/2026	2:00	23.2	92
08/03/2026	2:15	23.3	91
08/03/2026	2:30	23.5	91
08/03/2026	2:45	23.8	91
08/03/2026	3:00	24.0	91
08/03/2026	3:15	24.1	91
08/03/2026	3:30	24.2	90

08/03/2026	3:45	24.4	90
08/03/2026	4:00	24.5	90
08/03/2026	4:15	24.5	90
08/03/2026	4:30	24.6	89
08/03/2026	4:45	24.9	89
08/03/2026	5:00	25.0	89
08/03/2026	5:15	25.1	89
08/03/2026	5:30	25.2	88
08/03/2026	5:45	25.2	88
08/03/2026	6:00	25.3	87
08/03/2026	6:15	25.4	87
08/03/2026	6:30	25.5	87
08/03/2026	6:45	25.6	87
08/03/2026	7:00	25.6	86
08/03/2026	7:15	23.1	57
08/03/2026	7:30	20.1	59
08/03/2026	7:45	18.1	61
08/03/2026	8:00	17.1	77
08/03/2026	8:15	18.5	90
08/03/2026	8:30	20.0	95
08/03/2026	8:45	19.5	77
08/03/2026	9:00	18.0	76
08/03/2026	9:15	18.0	86
08/03/2026	9:30	19.1	93
08/03/2026	9:45	20.1	95
08/03/2026	10:00	20.4	94
08/03/2026	10:15	18.3	72
08/03/2026	10:30	17.8	83
08/03/2026	10:45	18.8	92
08/03/2026	11:00	19.9	95
08/03/2026	11:15	20.6	96
08/03/2026	11:30	19.6	78
08/03/2026	11:45	17.9	81
08/03/2026	12:00	18.9	92
08/03/2026	12:15	19.9	95
08/03/2026	12:30	20.3	95

08/03/2026	12:45	18.6	73
08/03/2026	13:00	18.5	89
08/03/2026	13:15	19.5	94
08/03/2026	13:30	20.5	96
08/03/2026	13:45	19.3	75
08/03/2026	14:00	18.2	86
08/03/2026	14:15	19.2	94
08/03/2026	14:30	20.2	95
08/03/2026	14:45	20.2	91
08/03/2026	15:00	18.2	72
08/03/2026	15:15	18.4	89
08/03/2026	15:30	19.5	95
08/03/2026	15:45	20.5	96
08/03/2026	16:00	19.1	74
08/03/2026	16:15	18.1	85
08/03/2026	16:30	19.2	94
08/03/2026	16:45	20.2	96
08/03/2026	17:00	20.8	96
08/03/2026	17:15	18.9	69
08/03/2026	17:30	18.3	87
08/03/2026	17:45	19.3	94
08/03/2026	18:00	20.2	96
08/03/2026	18:15	19.6	86
08/03/2026	18:30	17.9	80
08/03/2026	18:45	18.8	92
08/03/2026	19:00	19.9	95
08/03/2026	19:15	20.3	96
08/03/2026	19:30	18.6	75
08/03/2026	19:45	18.3	89
08/03/2026	20:00	19.4	94
08/03/2026	20:15	20.3	96
08/03/2026	20:30	19.9	90
08/03/2026	20:45	17.8	76
08/03/2026	21:00	18.3	91
08/03/2026	21:15	19.5	95
08/03/2026	21:30	20.3	96

08/03/2026	21:45	20.2	94
08/03/2026	22:00	18.1	76
08/03/2026	22:15	18.5	91
08/03/2026	22:30	19.5	95
08/03/2026	22:45	20.4	96
08/03/2026	23:00	19.9	93
08/03/2026	23:15	19.5	91
08/03/2026	23:30	20.2	95
08/03/2026	23:45	20.8	96
09/03/2026	0:00	21.2	96
09/03/2026	0:15	21.6	96
09/03/2026	0:30	22.0	96
09/03/2026	0:45	22.3	97
09/03/2026	1:00	22.5	96
09/03/2026	1:15	22.6	93
09/03/2026	1:30	22.9	92
09/03/2026	1:45	23.2	92
09/03/2026	2:00	23.3	92
09/03/2026	2:15	23.3	91
09/03/2026	2:30	23.6	91
09/03/2026	2:45	23.8	91
09/03/2026	3:00	24.0	91
09/03/2026	3:15	24.1	90
09/03/2026	3:30	24.3	90
09/03/2026	3:45	24.5	90
09/03/2026	4:00	24.6	89
09/03/2026	4:15	24.6	89
09/03/2026	4:30	24.9	89
09/03/2026	4:45	24.9	89
09/03/2026	5:00	25.0	89
09/03/2026	5:15	25.1	88
09/03/2026	5:30	25.2	88
09/03/2026	5:45	25.3	87
09/03/2026	6:00	25.4	87
09/03/2026	6:15	25.5	87
09/03/2026	6:30	25.5	87

09/03/2026	6:45	25.6	87
09/03/2026	7:00	25.6	86
09/03/2026	7:15	23.2	60
09/03/2026	7:30	20.4	65
09/03/2026	7:45	19.1	75
09/03/2026	8:00	17.8	65
09/03/2026	8:15	17.1	83
09/03/2026	8:30	18.6	92
09/03/2026	8:45	20.1	95
09/03/2026	9:00	19.5	79
09/03/2026	9:15	18.1	79
09/03/2026	9:30	18.0	84
09/03/2026	9:45	18.2	86
09/03/2026	10:00	18.3	86
09/03/2026	10:15	18.4	86
09/03/2026	10:30	18.5	86
09/03/2026	10:45	18.4	86
09/03/2026	11:00	18.4	86
09/03/2026	11:15	18.8	90
09/03/2026	11:30	19.8	94
09/03/2026	11:45	20.5	96
09/03/2026	12:00	19.5	79
09/03/2026	12:15	18.1	82
09/03/2026	12:30	19.1	92
09/03/2026	12:45	20.0	95
09/03/2026	13:00	20.3	94
09/03/2026	13:15	18.9	76
09/03/2026	13:30	17.9	80
09/03/2026	13:45	18.6	91
09/03/2026 Temp & Humidity Data Logger Ends	14:00	19.8	95
09/03/2026	14:15	20.6	96
09/03/2026	14:30	19.8	81
09/03/2026	14:45	19.9	84
09/03/2026	15:00	20.4	86
09/03/2026	15:15	24.8	79
09/03/2026	15:30	24.9	77

09/03/2026	15:45	24.8	76
09/03/2026	16:00	24.9	76

3. L9_MPR8_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	10:45	25.5	69
04/03/2026	11:00	25.5	67
04/03/2026	11:15	25.3	66
04/03/2026	11:30	25.3	66
04/03/2026	11:45	25.2	67
04/03/2026	12:00	25.1	68
04/03/2026	12:15	25.2	67
04/03/2026	12:30	25.2	66
04/03/2026	12:45	25.0	67
04/03/2026	13:00	24.9	67
04/03/2026	13:15	24.9	67
04/03/2026	13:30	24.9	68
04/03/2026	13:45	25.0	68
04/03/2026	14:00	25.1	67
04/03/2026	14:15	25.2	68
04/03/2026	14:30	25.2	68
04/03/2026	14:45	25.3	67
04/03/2026	15:00	25.9	74
04/03/2026	15:15	26.4	70
04/03/2026	Temp & Humidity Data Logger Start 15:30	26.2	70
04/03/2026	15:45	26.2	70
04/03/2026	16:00	26.2	70
04/03/2026	16:15	26.2	70
04/03/2026	16:30	26.2	71
04/03/2026	16:45	26.2	70
04/03/2026	17:00	26.2	70
04/03/2026	17:15	26.2	70
04/03/2026	17:30	26.2	70
04/03/2026	17:45	26.2	70
04/03/2026	18:00	26.2	69
04/03/2026	18:15	26.1	69
04/03/2026	18:30	26.1	69

04/03/2026	18:45	26.2	69
04/03/2026	19:00	26.1	69
04/03/2026	19:15	26.1	69
04/03/2026	19:30	26.1	69
04/03/2026	19:45	26.1	68
04/03/2026	20:00	26.1	68
04/03/2026	20:15	26.1	68
04/03/2026	20:30	26.0	68
04/03/2026	20:45	26.1	68
04/03/2026	21:00	26.1	68
04/03/2026	21:15	26.1	68
04/03/2026	21:30	26.0	67
04/03/2026	21:45	26.1	67
04/03/2026	22:00	26.1	67
04/03/2026	22:15	26.1	67
04/03/2026	22:30	26.1	67
04/03/2026	22:45	26.1	67
04/03/2026	23:00	26.1	67
04/03/2026	23:15	26.1	67
04/03/2026	23:30	26.0	68
04/03/2026	23:45	26.1	68
05/03/2026	0:00	26.1	68
05/03/2026	0:15	26.1	69
05/03/2026	0:30	26.1	69
05/03/2026	0:45	26.2	69
05/03/2026	1:00	26.1	69
05/03/2026	1:15	26.2	69
05/03/2026	1:30	26.2	70
05/03/2026	1:45	26.2	70
05/03/2026	2:00	26.2	70
05/03/2026	2:15	26.2	70
05/03/2026	2:30	26.3	70
05/03/2026	2:45	26.3	71
05/03/2026	3:00	26.2	71
05/03/2026	3:15	26.3	71
05/03/2026	3:30	26.2	71

05/03/2026	3:45	26.4	71
05/03/2026	4:00	26.3	71
05/03/2026	4:15	26.3	71
05/03/2026	4:30	26.4	72
05/03/2026	4:45	26.4	72
05/03/2026	5:00	26.4	72
05/03/2026	5:15	26.4	72
05/03/2026	5:30	26.4	72
05/03/2026	5:45	26.5	73
05/03/2026	6:00	26.5	73
05/03/2026	6:15	26.5	73
05/03/2026	6:30	26.5	73
05/03/2026	6:45	26.6	74
05/03/2026	7:00	26.5	74
05/03/2026	7:15	26.6	74
05/03/2026	7:30	26.5	74
05/03/2026	7:45	26.5	74
05/03/2026	8:00	26.8	74
05/03/2026	8:15	26.6	74
05/03/2026	8:30	26.6	74
05/03/2026	8:45	26.6	74
05/03/2026	9:00	26.6	74
05/03/2026	9:15	26.6	73
05/03/2026	9:30	26.8	73
05/03/2026	9:45	26.5	73
05/03/2026	10:00	26.6	73
05/03/2026	10:15	26.6	73
05/03/2026	10:30	26.6	72
05/03/2026	10:45	26.6	72
05/03/2026	11:00	26.5	71
05/03/2026	11:15	26.5	71
05/03/2026	11:30	26.5	71
05/03/2026	11:45	26.5	71
05/03/2026	12:00	26.5	66
05/03/2026	12:15	24.4	61
05/03/2026	12:30	22.5	64

05/03/2026	12:45	21.9	67
05/03/2026	13:00	22.6	66
05/03/2026	13:15	23.3	67
05/03/2026	13:30	23.6	68
05/03/2026	13:45	23.9	69
05/03/2026	14:00	24.1	69
05/03/2026	14:15	24.3	69
05/03/2026	14:30	24.3	69
05/03/2026	14:45	23.1	65
05/03/2026	15:00	21.6	69
05/03/2026	15:15	20.8	71
05/03/2026	15:30	20.3	71
05/03/2026	15:45	19.9	72
05/03/2026	16:00	19.9	74
05/03/2026	16:15	20.8	77
05/03/2026	16:30	21.3	75
05/03/2026	16:45	21.6	75
05/03/2026	17:00	22.1	74
05/03/2026	17:15	21.9	71
05/03/2026	17:30	20.6	72
05/03/2026	17:45	19.9	74
05/03/2026	18:00	20.2	74
05/03/2026	18:15	20.9	73
05/03/2026	18:30	21.3	73
05/03/2026	18:45	21.5	72
05/03/2026	19:00	21.6	72
05/03/2026	19:15	21.9	71
05/03/2026	19:30	21.9	71
05/03/2026	19:45	22.2	71
05/03/2026	20:00	22.2	71
05/03/2026	20:15	22.3	71
05/03/2026	20:30	22.5	71
05/03/2026	20:45	22.6	69
05/03/2026	21:00	22.8	69
05/03/2026	21:15	22.8	69
05/03/2026	21:30	22.8	68

05/03/2026	21:45	22.9	68
05/03/2026	22:00	23.0	68
05/03/2026	22:15	23.1	68
05/03/2026	22:30	23.2	68
05/03/2026	22:45	23.2	68
05/03/2026	23:00	23.3	67
05/03/2026	23:15	23.3	68
05/03/2026	23:30	23.3	68
05/03/2026	23:45	23.5	68
06/03/2026	0:00	23.5	68
06/03/2026	0:15	23.6	69
06/03/2026	0:30	23.6	69
06/03/2026	0:45	23.8	69
06/03/2026	1:00	23.8	69
06/03/2026	1:15	23.8	69
06/03/2026	1:30	23.9	69
06/03/2026	1:45	23.9	69
06/03/2026	2:00	24.0	70
06/03/2026	2:15	24.1	70
06/03/2026	2:30	24.1	70
06/03/2026	2:45	24.1	70
06/03/2026	3:00	24.2	70
06/03/2026	3:15	24.3	70
06/03/2026	3:30	24.2	70
06/03/2026	3:45	24.3	70
06/03/2026	4:00	24.3	70
06/03/2026	4:15	24.3	70
06/03/2026	4:30	24.3	70
06/03/2026	4:45	24.3	70
06/03/2026	5:00	24.4	70
06/03/2026	5:15	24.5	70
06/03/2026	5:30	24.5	70
06/03/2026	5:45	24.6	71
06/03/2026	6:00	24.6	71
06/03/2026	6:15	24.6	71
06/03/2026	6:30	24.8	71

06/03/2026	6:45	24.8	71
06/03/2026	7:00	24.8	71
06/03/2026	7:15	24.8	71
06/03/2026	7:30	24.9	71
06/03/2026	7:45	24.9	71
06/03/2026	8:00	24.9	71
06/03/2026	8:15	24.9	70
06/03/2026	8:30	24.9	70
06/03/2026	8:45	24.9	70
06/03/2026	9:00	25.0	70
06/03/2026	9:15	25.0	70
06/03/2026	9:30	25.1	70
06/03/2026	9:45	25.0	69
06/03/2026	10:00	25.1	70
06/03/2026	10:15	25.1	70
06/03/2026	10:30	25.2	70
06/03/2026	10:45	25.1	70
06/03/2026	11:00	25.2	71
06/03/2026	11:15	25.2	71
06/03/2026	11:30	25.2	71
06/03/2026	11:45	25.2	71
06/03/2026	12:00	25.2	71
06/03/2026	12:15	25.3	70
06/03/2026	12:30	25.3	70
06/03/2026	12:45	25.3	70
06/03/2026	13:00	25.3	70
06/03/2026	13:15	25.3	69
06/03/2026	13:30	25.4	69
06/03/2026	13:45	25.4	69
06/03/2026	14:00	25.4	69
06/03/2026	14:15	25.5	69
06/03/2026	14:30	25.4	69
06/03/2026	14:45	25.5	69
06/03/2026	15:00	25.5	69
06/03/2026	15:15	25.5	67
06/03/2026	15:30	25.5	67

06/03/2026	15:45	25.5	67
06/03/2026	16:00	25.5	67
06/03/2026	16:15	25.5	67
06/03/2026	16:30	25.5	67
06/03/2026	16:45	25.5	67
06/03/2026	17:00	25.6	67
06/03/2026	17:15	25.5	66
06/03/2026	17:30	25.6	67
06/03/2026	17:45	25.6	67
06/03/2026	18:00	25.6	66
06/03/2026	18:15	25.6	66
06/03/2026	18:30	25.5	67
06/03/2026	18:45	25.5	67
06/03/2026	19:00	25.6	66
06/03/2026	19:15	25.6	66
06/03/2026	19:30	25.5	66
06/03/2026	19:45	25.5	66
06/03/2026	20:00	25.5	66
06/03/2026	20:15	25.5	66
06/03/2026	20:30	25.6	66
06/03/2026	20:45	25.6	66
06/03/2026	21:00	25.6	66
06/03/2026	21:15	25.6	66
06/03/2026	21:30	25.6	66
06/03/2026	21:45	25.6	65
06/03/2026	22:00	25.8	66
06/03/2026	22:15	25.6	66
06/03/2026	22:30	25.6	65
06/03/2026	22:45	25.8	66
06/03/2026	23:00	25.6	66
06/03/2026	23:15	25.8	65
06/03/2026	23:30	25.8	65
06/03/2026	23:45	25.8	66
07/03/2026	0:00	25.8	66
07/03/2026	0:15	25.8	66
07/03/2026	0:30	25.8	66

07/03/2026	0:45	25.8	66
07/03/2026	1:00	25.8	66
07/03/2026	1:15	25.8	66
07/03/2026	1:30	25.9	67
07/03/2026	1:45	25.8	67
07/03/2026	2:00	25.9	67
07/03/2026	2:15	25.9	67
07/03/2026	2:30	25.9	67
07/03/2026	2:45	25.9	67
07/03/2026	3:00	25.9	68
07/03/2026	3:15	25.9	68
07/03/2026	3:30	25.9	68
07/03/2026	3:45	25.9	68
07/03/2026	4:00	26.0	69
07/03/2026	4:15	26.0	69
07/03/2026	4:30	26.1	69
07/03/2026	4:45	26.0	69
07/03/2026	5:00	26.0	69
07/03/2026	5:15	26.0	69
07/03/2026	5:30	26.0	69
07/03/2026	5:45	26.1	69
07/03/2026	6:00	26.1	69
07/03/2026	6:15	26.0	69
07/03/2026	6:30	26.1	69
07/03/2026	6:45	26.1	69
07/03/2026	7:00	26.1	70
07/03/2026	7:15	26.1	70
07/03/2026	7:30	26.1	69
07/03/2026	7:45	26.1	69
07/03/2026	8:00	26.1	69
07/03/2026	8:15	26.1	69
07/03/2026	8:30	26.1	69
07/03/2026	8:45	26.2	69
07/03/2026	9:00	26.1	68
07/03/2026	9:15	26.1	68
07/03/2026	9:30	26.2	68

07/03/2026	9:45	26.2	68
07/03/2026	10:00	26.1	67
07/03/2026	10:15	26.2	67
07/03/2026	10:30	26.2	68
07/03/2026	10:45	26.1	67
07/03/2026	11:00	26.2	67
07/03/2026	11:15	26.2	66
07/03/2026	11:30	26.2	67
07/03/2026	11:45	26.2	66
07/03/2026	12:00	26.2	67
07/03/2026	12:15	26.2	66
07/03/2026	12:30	26.1	66
07/03/2026	12:45	26.2	66
07/03/2026	13:00	26.2	66
07/03/2026	13:15	26.2	66
07/03/2026	13:30	26.2	66
07/03/2026	13:45	26.2	66
07/03/2026	14:00	26.2	67
07/03/2026	14:15	26.2	66
07/03/2026	14:30	26.3	66
07/03/2026	14:45	26.2	66
07/03/2026	15:00	26.3	66
07/03/2026	15:15	26.3	66
07/03/2026	15:30	26.3	66
07/03/2026	15:45	26.3	66
07/03/2026	16:00	26.3	66
07/03/2026	16:15	26.4	66
07/03/2026	16:30	26.5	66
07/03/2026	16:45	26.3	66
07/03/2026	17:00	26.5	66
07/03/2026	17:15	26.4	66
07/03/2026	17:30	26.5	65
07/03/2026	17:45	26.5	66
07/03/2026	18:00	26.5	66
07/03/2026	18:15	26.5	66
07/03/2026	18:30	26.5	66

07/03/2026	18:45	26.5	66
07/03/2026	19:00	26.5	65
07/03/2026	19:15	26.6	65
07/03/2026	19:30	26.5	65
07/03/2026	19:45	26.5	66
07/03/2026	20:00	26.5	65
07/03/2026	20:15	26.5	65
07/03/2026	20:30	26.5	65
07/03/2026	20:45	26.5	65
07/03/2026	21:00	26.6	66
07/03/2026	21:15	26.6	66
07/03/2026	21:30	26.6	66
07/03/2026	21:45	26.6	65
07/03/2026	22:00	26.6	65
07/03/2026	22:15	26.6	66
07/03/2026	22:30	26.6	65
07/03/2026	22:45	26.6	65
07/03/2026	23:00	26.5	65
07/03/2026	23:15	26.6	65
07/03/2026	23:30	26.6	65
07/03/2026	23:45	26.6	66
08/03/2026	0:00	26.8	66
08/03/2026	0:15	26.6	66
08/03/2026	0:30	26.6	66
08/03/2026	0:45	26.6	66
08/03/2026	1:00	26.6	67
08/03/2026	1:15	26.6	67
08/03/2026	1:30	26.6	67
08/03/2026	1:45	26.6	67
08/03/2026	2:00	26.8	67
08/03/2026	2:15	26.8	67
08/03/2026	2:30	26.6	67
08/03/2026	2:45	26.8	68
08/03/2026	3:00	26.8	68
08/03/2026	3:15	26.8	68
08/03/2026	3:30	26.6	69

08/03/2026	3:45	26.9	69
08/03/2026	4:00	26.8	69
08/03/2026	4:15	26.8	69
08/03/2026	4:30	26.8	69
08/03/2026	4:45	26.9	69
08/03/2026	5:00	26.9	69
08/03/2026	5:15	26.8	69
08/03/2026	5:30	26.9	69
08/03/2026	5:45	26.9	69
08/03/2026	6:00	26.9	69
08/03/2026	6:15	26.9	69
08/03/2026	6:30	26.8	69
08/03/2026	6:45	26.9	70
08/03/2026	7:00	26.8	70
08/03/2026	7:15	26.9	70
08/03/2026	7:30	26.9	69
08/03/2026	7:45	26.9	69
08/03/2026	8:00	26.9	69
08/03/2026	8:15	26.8	69
08/03/2026	8:30	26.8	68
08/03/2026	8:45	26.9	68
08/03/2026	9:00	26.8	68
08/03/2026	9:15	26.9	68
08/03/2026	9:30	26.9	68
08/03/2026	9:45	26.9	68
08/03/2026	10:00	26.8	67
08/03/2026	10:15	26.9	67
08/03/2026	10:30	26.8	67
08/03/2026	10:45	26.9	67
08/03/2026	11:00	26.9	67
08/03/2026	11:15	26.9	67
08/03/2026	11:30	26.9	67
08/03/2026	11:45	26.8	66
08/03/2026	12:00	26.9	67
08/03/2026	12:15	26.8	66
08/03/2026	12:30	26.8	66

08/03/2026	12:45	26.9	66
08/03/2026	13:00	26.9	66
08/03/2026	13:15	26.9	66
08/03/2026	13:30	26.8	66
08/03/2026	13:45	26.8	66
08/03/2026	14:00	26.9	66
08/03/2026	14:15	26.9	66
08/03/2026	14:30	26.8	66
08/03/2026	14:45	26.9	65
08/03/2026	15:00	26.9	66
08/03/2026	15:15	26.9	66
08/03/2026	15:30	26.9	66
08/03/2026	15:45	26.9	66
08/03/2026	16:00	26.9	65
08/03/2026	16:15	26.9	65
08/03/2026	16:30	27.0	65
08/03/2026	16:45	26.9	65
08/03/2026	17:00	27.0	65
08/03/2026	17:15	26.9	65
08/03/2026	17:30	26.9	65
08/03/2026	17:45	27.0	65
08/03/2026	18:00	27.0	65
08/03/2026	18:15	27.0	65
08/03/2026	18:30	27.0	65
08/03/2026	18:45	26.9	65
08/03/2026	19:00	26.9	65
08/03/2026	19:15	26.9	65
08/03/2026	19:30	26.9	65
08/03/2026	19:45	26.9	65
08/03/2026	20:00	26.9	65
08/03/2026	20:15	26.9	65
08/03/2026	20:30	26.9	65
08/03/2026	20:45	26.9	65
08/03/2026	21:00	26.9	65
08/03/2026	21:15	26.9	65
08/03/2026	21:30	27.1	65

08/03/2026	21:45	27.0	65
08/03/2026	22:00	27.1	65
08/03/2026	22:15	27.1	65
08/03/2026	22:30	27.1	65
08/03/2026	22:45	27.0	65
08/03/2026	23:00	27.1	65
08/03/2026	23:15	27.0	65
08/03/2026	23:30	27.0	65
08/03/2026	23:45	27.0	65
09/03/2026	0:00	27.1	65
09/03/2026	0:15	27.0	65
09/03/2026	0:30	27.1	66
09/03/2026	0:45	27.1	66
09/03/2026	1:00	27.1	66
09/03/2026	1:15	27.1	66
09/03/2026	1:30	27.1	66
09/03/2026	1:45	27.1	66
09/03/2026	2:00	27.0	66
09/03/2026	2:15	27.1	66
09/03/2026	2:30	27.1	66
09/03/2026	2:45	27.1	66
09/03/2026	3:00	27.1	67
09/03/2026	3:15	27.1	67
09/03/2026	3:30	27.1	67
09/03/2026	3:45	27.1	67
09/03/2026	4:00	27.1	67
09/03/2026	4:15	27.1	67
09/03/2026	4:30	27.1	67
09/03/2026	4:45	27.2	67
09/03/2026	5:00	27.1	68
09/03/2026	5:15	27.2	68
09/03/2026	5:30	27.1	68
09/03/2026	5:45	27.1	68
09/03/2026	6:00	27.2	68
09/03/2026	6:15	27.1	68
09/03/2026	6:30	27.2	68

09/03/2026	6:45	27.2	68
09/03/2026	7:00	27.2	69
09/03/2026	7:15	27.2	69
09/03/2026	7:30	27.2	68
09/03/2026	7:45	27.2	68
09/03/2026	8:00	27.2	67
09/03/2026	8:15	27.2	67
09/03/2026	8:30	27.1	67
09/03/2026	8:45	27.2	67
09/03/2026	9:00	27.2	66
09/03/2026	9:15	27.2	66
09/03/2026	9:30	27.1	66
09/03/2026	9:45	27.1	65
09/03/2026	10:00	27.1	61
09/03/2026	10:15	24.8	60
09/03/2026	10:30	23.0	63
09/03/2026	10:45	22.8	65
09/03/2026	11:00	23.6	65
09/03/2026	11:15	24.2	65
09/03/2026	11:30	24.5	65
09/03/2026	11:45	24.6	65
09/03/2026	12:00	24.9	65
09/03/2026	12:15	24.9	64
09/03/2026	12:30	25.1	64
09/03/2026	12:45	25.2	64
09/03/2026	13:00	25.2	64
09/03/2026	13:15	25.3	64
09/03/2026	13:30	25.3	64
09/03/2026	13:45	25.5	65
09/03/2026 Temp & Humidity Data Logger Ends	14:00	25.5	65
09/03/2026	14:15	25.5	64
09/03/2026	14:30	25.5	64
09/03/2026	14:45	25.6	64
09/03/2026	15:00	25.8	70
09/03/2026	15:15	25.1	65
09/03/2026	15:30	24.9	66

09/03/2026	15:45	24.9	66
09/03/2026	16:00	24.9	66

4. L9_EPR1_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	10:45	26.3	70
04/03/2026	11:00	-	-
04/03/2026	11:15	-	-
04/03/2026	11:30	-	-
04/03/2026	11:45	-	-
04/03/2026	12:00	-	-
04/03/2026	12:15	25.9	70
04/03/2026	12:30	25.4	70
04/03/2026	12:45	25.0	71
04/03/2026	13:00	25.0	71
04/03/2026	13:15	25.0	71
04/03/2026	13:30	24.9	72
04/03/2026	13:45	24.9	72
04/03/2026	14:00	25.1	71
04/03/2026	14:15	25.2	71
04/03/2026	14:30	25.2	72
04/03/2026	14:45	25.3	71
04/03/2026	15:00	26.2	79
04/03/2026	15:15	25.4	71
04/03/2026	Temp & Humidity Data Logger Start 15:30	23.5	73
04/03/2026	15:45	22.6	74
04/03/2026	16:00	22.3	79
04/03/2026	16:15	22.1	80
04/03/2026	16:30	22.3	82
04/03/2026	16:45	22.5	82
04/03/2026	17:00	22.6	80
04/03/2026	17:15	22.8	80
04/03/2026	17:30	22.9	80
04/03/2026	17:45	23.0	80
04/03/2026	18:00	23.0	80
04/03/2026	18:15	23.1	81
04/03/2026	18:30	23.1	81

04/03/2026	18:45	23.2	81
04/03/2026	19:00	23.2	81
04/03/2026	19:15	23.3	81
04/03/2026	19:30	23.3	81
04/03/2026	19:45	23.5	81
04/03/2026	20:00	23.4	81
04/03/2026	20:15	23.5	81
04/03/2026	20:30	23.5	81
04/03/2026	20:45	23.5	81
04/03/2026	21:00	23.5	81
04/03/2026	21:15	23.6	81
04/03/2026	21:30	23.6	81
04/03/2026	21:45	23.6	82
04/03/2026	22:00	23.6	82
04/03/2026	22:15	23.8	82
04/03/2026	22:30	23.8	82
04/03/2026	22:45	23.9	82
04/03/2026	23:00	23.9	82
04/03/2026	23:15	23.9	82
04/03/2026	23:30	23.9	82
04/03/2026	23:45	23.9	82
05/03/2026	0:00	23.9	82
05/03/2026	0:15	24.1	82
05/03/2026	0:30	24.0	82
05/03/2026	0:45	24.1	82
05/03/2026	1:00	24.1	82
05/03/2026	1:15	24.1	82
05/03/2026	1:30	24.1	82
05/03/2026	1:45	24.2	83
05/03/2026	2:00	24.1	83
05/03/2026	2:15	24.1	83
05/03/2026	2:30	24.2	83
05/03/2026	2:45	24.2	83
05/03/2026	3:00	24.3	83
05/03/2026	3:15	24.1	83
05/03/2026	3:30	24.2	83

05/03/2026	3:45	24.3	83
05/03/2026	4:00	24.4	83
05/03/2026	4:15	24.4	83
05/03/2026	4:30	24.3	83
05/03/2026	4:45	24.4	83
05/03/2026	5:00	24.4	83
05/03/2026	5:15	24.4	83
05/03/2026	5:30	24.4	83
05/03/2026	5:45	24.5	83
05/03/2026	6:00	24.5	83
05/03/2026	6:15	24.5	83
05/03/2026	6:30	24.5	83
05/03/2026	6:45	24.5	83
05/03/2026	7:00	24.6	83
05/03/2026	7:15	24.6	83
05/03/2026	7:30	24.6	84
05/03/2026	7:45	24.8	84
05/03/2026	8:00	24.8	84
05/03/2026	8:15	24.8	84
05/03/2026	8:30	24.4	75
05/03/2026	8:45	23.5	69
05/03/2026	9:00	22.6	67
05/03/2026	9:15	22.2	73
05/03/2026	9:30	22.5	77
05/03/2026	9:45	22.8	76
05/03/2026	10:00	23.1	76
05/03/2026	10:15	23.1	76
05/03/2026	10:30	23.3	77
05/03/2026	10:45	23.3	76
05/03/2026	11:00	22.8	70
05/03/2026	11:15	22.5	74
05/03/2026	11:30	22.6	73
05/03/2026	11:45	22.8	74
05/03/2026	12:00	23.1	75
05/03/2026	12:15	23.2	75
05/03/2026	12:30	23.2	76

05/03/2026	12:45	23.3	76
05/03/2026	13:00	23.5	76
05/03/2026	13:15	22.9	70
05/03/2026	13:30	22.5	75
05/03/2026	13:45	22.4	79
05/03/2026	14:00	22.6	77
05/03/2026	14:15	22.8	77
05/03/2026	14:30	22.9	77
05/03/2026	14:45	23.1	78
05/03/2026	15:00	23.3	78
05/03/2026	15:15	23.3	79
05/03/2026	15:30	23.5	79
05/03/2026	15:45	23.6	79
05/03/2026	16:00	23.8	79
05/03/2026	16:15	23.9	79
05/03/2026	16:30	24.1	80
05/03/2026	16:45	24.1	80
05/03/2026	17:00	24.1	80
05/03/2026	17:15	24.2	81
05/03/2026	17:30	24.3	81
05/03/2026	17:45	24.3	81
05/03/2026	18:00	24.4	81
05/03/2026	18:15	24.5	81
05/03/2026	18:30	24.6	81
05/03/2026	18:45	24.8	81
05/03/2026	19:00	24.6	81
05/03/2026	19:15	24.5	81
05/03/2026	19:30	24.5	81
05/03/2026	19:45	24.5	81
05/03/2026	20:00	24.5	81
05/03/2026	20:15	24.5	81
05/03/2026	20:30	24.5	81
05/03/2026	20:45	24.6	81
05/03/2026	21:00	24.5	81
05/03/2026	21:15	24.6	81
05/03/2026	21:30	24.6	81

05/03/2026	21:45	24.6	81
05/03/2026	22:00	24.6	81
05/03/2026	22:15	24.6	81
05/03/2026	22:30	24.6	81
05/03/2026	22:45	24.6	81
05/03/2026	23:00	24.6	81
05/03/2026	23:15	24.6	81
05/03/2026	23:30	24.8	81
05/03/2026	23:45	24.6	81
06/03/2026	0:00	24.8	81
06/03/2026	0:15	24.8	81
06/03/2026	0:30	24.9	81
06/03/2026	0:45	24.9	81
06/03/2026	1:00	24.8	81
06/03/2026	1:15	24.9	81
06/03/2026	1:30	24.9	81
06/03/2026	1:45	24.9	81
06/03/2026	2:00	24.9	81
06/03/2026	2:15	25.0	82
06/03/2026	2:30	24.9	81
06/03/2026	2:45	25.0	81
06/03/2026	3:00	25.0	82
06/03/2026	3:15	25.0	82
06/03/2026	3:30	25.0	82
06/03/2026	3:45	25.1	82
06/03/2026	4:00	25.1	82
06/03/2026	4:15	25.0	81
06/03/2026	4:30	25.1	82
06/03/2026	4:45	25.2	82
06/03/2026	5:00	25.1	82
06/03/2026	5:15	25.1	82
06/03/2026	5:30	25.1	82
06/03/2026	5:45	25.2	82
06/03/2026	6:00	25.2	82
06/03/2026	6:15	25.2	82
06/03/2026	6:30	25.2	82

06/03/2026	6:45	25.2	82
06/03/2026	7:00	25.2	82
06/03/2026	7:15	25.3	82
06/03/2026	7:30	25.3	82
06/03/2026	7:45	25.3	82
06/03/2026	8:00	25.2	82
06/03/2026	8:15	25.3	82
06/03/2026	8:30	25.2	82
06/03/2026	8:45	25.3	82
06/03/2026	9:00	25.3	82
06/03/2026	9:15	25.4	82
06/03/2026	9:30	25.4	82
06/03/2026	9:45	25.3	82
06/03/2026	10:00	25.4	82
06/03/2026	10:15	25.4	82
06/03/2026	10:30	25.4	82
06/03/2026	10:45	25.2	75
06/03/2026	11:00	24.1	65
06/03/2026	11:15	23.2	66
06/03/2026	11:30	22.9	73
06/03/2026	11:45	22.8	76
06/03/2026	12:00	22.9	77
06/03/2026	12:15	22.9	77
06/03/2026	12:30	22.9	77
06/03/2026	12:45	22.9	78
06/03/2026	13:00	22.8	77
06/03/2026	13:15	22.8	77
06/03/2026	13:30	22.8	77
06/03/2026	13:45	22.6	77
06/03/2026	14:00	22.5	79
06/03/2026	14:15	22.5	79
06/03/2026	14:30	22.3	79
06/03/2026	14:45	22.3	79
06/03/2026	15:00	22.2	79
06/03/2026	15:15	22.3	80
06/03/2026	15:30	22.5	81

06/03/2026	15:45	22.6	79
06/03/2026	16:00	22.6	80
06/03/2026	16:15	22.9	80
06/03/2026	16:30	23.1	80
06/03/2026	16:45	23.1	80
06/03/2026	17:00	23.2	80
06/03/2026	17:15	23.3	80
06/03/2026	17:30	23.4	80
06/03/2026	17:45	23.5	80
06/03/2026	18:00	23.6	80
06/03/2026	18:15	23.6	80
06/03/2026	18:30	23.8	80
06/03/2026	18:45	23.8	80
06/03/2026	19:00	23.8	80
06/03/2026	19:15	23.9	80
06/03/2026	19:30	23.9	80
06/03/2026	19:45	23.9	80
06/03/2026	20:00	23.9	80
06/03/2026	20:15	24.0	80
06/03/2026	20:30	24.0	80
06/03/2026	20:45	24.1	80
06/03/2026	21:00	24.1	80
06/03/2026	21:15	24.1	80
06/03/2026	21:30	24.2	80
06/03/2026	21:45	24.1	80
06/03/2026	22:00	24.1	81
06/03/2026	22:15	24.2	81
06/03/2026	22:30	24.2	81
06/03/2026	22:45	24.2	81
06/03/2026	23:00	24.3	81
06/03/2026	23:15	24.3	81
06/03/2026	23:30	24.3	81
06/03/2026	23:45	24.3	81
07/03/2026	0:00	24.3	81
07/03/2026	0:15	24.4	81
07/03/2026	0:30	24.3	81

07/03/2026	0:45	24.4	81
07/03/2026	1:00	24.4	81
07/03/2026	1:15	24.4	81
07/03/2026	1:30	24.4	81
07/03/2026	1:45	24.6	81
07/03/2026	2:00	24.5	81
07/03/2026	2:15	24.5	81
07/03/2026	2:30	24.6	81
07/03/2026	2:45	24.6	81
07/03/2026	3:00	24.5	81
07/03/2026	3:15	24.6	81
07/03/2026	3:30	24.6	81
07/03/2026	3:45	24.6	81
07/03/2026	4:00	24.6	81
07/03/2026	4:15	24.6	81
07/03/2026	4:30	24.6	81
07/03/2026	4:45	24.8	81
07/03/2026	5:00	24.8	82
07/03/2026	5:15	24.8	82
07/03/2026	5:30	24.9	82
07/03/2026	5:45	24.8	82
07/03/2026	6:00	24.9	82
07/03/2026	6:15	24.8	82
07/03/2026	6:30	24.9	82
07/03/2026	6:45	24.9	82
07/03/2026	7:00	25.0	82
07/03/2026	7:15	24.9	82
07/03/2026	7:30	24.9	82
07/03/2026	7:45	25.0	82
07/03/2026	8:00	25.0	82
07/03/2026	8:15	25.0	82
07/03/2026	8:30	25.0	82
07/03/2026	8:45	25.0	82
07/03/2026	9:00	25.1	82
07/03/2026	9:15	25.1	82
07/03/2026	9:30	25.2	82

07/03/2026	9:45	25.1	82
07/03/2026	10:00	25.1	82
07/03/2026	10:15	25.2	82
07/03/2026	10:30	25.2	82
07/03/2026	10:45	25.2	82
07/03/2026	11:00	25.2	82
07/03/2026	11:15	25.2	82
07/03/2026	11:30	25.2	82
07/03/2026	11:45	25.2	82
07/03/2026	12:00	25.2	82
07/03/2026	12:15	25.2	82
07/03/2026	12:30	25.2	82
07/03/2026	12:45	25.2	82
07/03/2026	13:00	25.2	82
07/03/2026	13:15	25.2	82
07/03/2026	13:30	25.3	82
07/03/2026	13:45	25.3	82
07/03/2026	14:00	25.3	82
07/03/2026	14:15	25.3	82
07/03/2026	14:30	25.4	82
07/03/2026	14:45	25.3	82
07/03/2026	15:00	25.3	82
07/03/2026	15:15	25.4	82
07/03/2026	15:30	25.4	82
07/03/2026	15:45	25.4	82
07/03/2026	16:00	25.4	82
07/03/2026	16:15	25.4	82
07/03/2026	16:30	25.4	82
07/03/2026	16:45	25.4	82
07/03/2026	17:00	25.4	82
07/03/2026	17:15	25.5	82
07/03/2026	17:30	25.5	82
07/03/2026	17:45	25.5	82
07/03/2026	18:00	25.5	82
07/03/2026	18:15	25.6	82
07/03/2026	18:30	25.5	82

07/03/2026	18:45	25.6	82
07/03/2026	19:00	25.6	82
07/03/2026	19:15	25.6	82
07/03/2026	19:30	25.6	82
07/03/2026	19:45	25.6	82
07/03/2026	20:00	25.6	82
07/03/2026	20:15	25.8	82
07/03/2026	20:30	25.6	82
07/03/2026	20:45	25.8	82
07/03/2026	21:00	25.8	82
07/03/2026	21:15	25.8	82
07/03/2026	21:30	25.8	82
07/03/2026	21:45	25.9	82
07/03/2026	22:00	25.8	82
07/03/2026	22:15	25.8	82
07/03/2026	22:30	25.8	82
07/03/2026	22:45	25.8	82
07/03/2026	23:00	25.9	82
07/03/2026	23:15	25.8	82
07/03/2026	23:30	25.9	82
07/03/2026	23:45	25.9	82
08/03/2026	0:00	25.9	82
08/03/2026	0:15	25.9	82
08/03/2026	0:30	25.9	82
08/03/2026	0:45	25.9	82
08/03/2026	1:00	25.9	82
08/03/2026	1:15	25.9	82
08/03/2026	1:30	25.9	82
08/03/2026	1:45	25.9	82
08/03/2026	2:00	26.0	82
08/03/2026	2:15	26.0	82
08/03/2026	2:30	25.9	82
08/03/2026	2:45	26.0	82
08/03/2026	3:00	25.9	82
08/03/2026	3:15	26.1	82
08/03/2026	3:30	26.1	82

08/03/2026	3:45	26.0	82
08/03/2026	4:00	26.1	82
08/03/2026	4:15	26.1	82
08/03/2026	4:30	26.1	82
08/03/2026	4:45	26.1	82
08/03/2026	5:00	26.1	82
08/03/2026	5:15	26.1	82
08/03/2026	5:30	26.1	82
08/03/2026	5:45	26.1	82
08/03/2026	6:00	26.1	82
08/03/2026	6:15	26.1	82
08/03/2026	6:30	26.1	82
08/03/2026	6:45	26.1	82
08/03/2026	7:00	26.1	82
08/03/2026	7:15	26.2	82
08/03/2026	7:30	26.2	82
08/03/2026	7:45	26.1	82
08/03/2026	8:00	26.2	82
08/03/2026	8:15	26.1	82
08/03/2026	8:30	26.2	82
08/03/2026	8:45	26.2	82
08/03/2026	9:00	26.2	82
08/03/2026	9:15	26.1	82
08/03/2026	9:30	26.2	82
08/03/2026	9:45	26.3	82
08/03/2026	10:00	26.2	82
08/03/2026	10:15	26.2	82
08/03/2026	10:30	26.2	82
08/03/2026	10:45	26.2	82
08/03/2026	11:00	26.3	82
08/03/2026	11:15	26.3	82
08/03/2026	11:30	26.3	82
08/03/2026	11:45	26.3	82
08/03/2026	12:00	26.3	82
08/03/2026	12:15	26.3	82
08/03/2026	12:30	26.3	82

08/03/2026	12:45	26.3	82
08/03/2026	13:00	26.3	82
08/03/2026	13:15	26.3	82
08/03/2026	13:30	26.3	82
08/03/2026	13:45	26.3	82
08/03/2026	14:00	26.3	82
08/03/2026	14:15	26.3	82
08/03/2026	14:30	26.3	82
08/03/2026	14:45	26.3	82
08/03/2026	15:00	26.3	82
08/03/2026	15:15	26.4	82
08/03/2026	15:30	26.4	82
08/03/2026	15:45	26.4	82
08/03/2026	16:00	26.4	82
08/03/2026	16:15	26.3	82
08/03/2026	16:30	26.3	82
08/03/2026	16:45	26.3	82
08/03/2026	17:00	26.3	82
08/03/2026	17:15	26.4	82
08/03/2026	17:30	26.5	82
08/03/2026	17:45	26.5	82
08/03/2026	18:00	26.5	82
08/03/2026	18:15	26.5	82
08/03/2026	18:30	26.5	81
08/03/2026	18:45	26.4	81
08/03/2026	19:00	26.5	81
08/03/2026	19:15	26.5	81
08/03/2026	19:30	26.5	81
08/03/2026	19:45	26.5	81
08/03/2026	20:00	26.6	81
08/03/2026	20:15	26.6	81
08/03/2026	20:30	26.5	82
08/03/2026	20:45	26.5	81
08/03/2026	21:00	26.6	82
08/03/2026	21:15	26.5	81
08/03/2026	21:30	26.5	82

08/03/2026	21:45	26.5	82
08/03/2026	22:00	26.6	82
08/03/2026	22:15	26.6	82
08/03/2026	22:30	26.5	81
08/03/2026	22:45	26.6	82
08/03/2026	23:00	26.6	82
08/03/2026	23:15	26.6	82
08/03/2026	23:30	26.6	82
08/03/2026	23:45	26.6	82
09/03/2026	0:00	26.6	82
09/03/2026	0:15	26.6	82
09/03/2026	0:30	26.6	82
09/03/2026	0:45	26.8	82
09/03/2026	1:00	26.8	82
09/03/2026	1:15	26.6	82
09/03/2026	1:30	26.8	82
09/03/2026	1:45	26.6	82
09/03/2026	2:00	26.8	82
09/03/2026	2:15	26.8	82
09/03/2026	2:30	26.8	82
09/03/2026	2:45	26.8	82
09/03/2026	3:00	26.8	82
09/03/2026	3:15	26.8	82
09/03/2026	3:30	26.8	82
09/03/2026	3:45	26.8	82
09/03/2026	4:00	26.8	82
09/03/2026	4:15	26.8	82
09/03/2026	4:30	26.8	82
09/03/2026	4:45	26.8	82
09/03/2026	5:00	26.8	82
09/03/2026	5:15	26.8	82
09/03/2026	5:30	26.8	82
09/03/2026	5:45	26.8	82
09/03/2026	6:00	26.8	82
09/03/2026	6:15	26.8	81
09/03/2026	6:30	26.8	82

09/03/2026	6:45	26.8	82
09/03/2026	7:00	26.8	82
09/03/2026	7:15	26.8	82
09/03/2026	7:30	26.8	82
09/03/2026	7:45	26.8	82
09/03/2026	8:00	26.8	82
09/03/2026	8:15	26.8	82
09/03/2026	8:30	26.8	82
09/03/2026	8:45	26.8	82
09/03/2026	9:00	26.8	81
09/03/2026	9:15	26.8	82
09/03/2026	9:30	26.8	82
09/03/2026	9:45	26.8	82
09/03/2026	10:00	26.8	82
09/03/2026	10:15	26.8	82
09/03/2026	10:30	26.8	81
09/03/2026	10:45	26.9	82
09/03/2026	11:00	26.8	81
09/03/2026	11:15	26.8	81
09/03/2026	11:30	26.8	81
09/03/2026	11:45	26.9	81
09/03/2026	12:00	26.8	82
09/03/2026	12:15	26.9	82
09/03/2026	12:30	25.6	66
09/03/2026	12:45	24.1	65
09/03/2026	13:00	22.9	67
09/03/2026	13:15	22.8	73
09/03/2026	13:30	22.8	74
09/03/2026	13:45	22.8	75
09/03/2026 Temp & Humidity Data Logger Ends	14:00	22.8	75
09/03/2026	14:15	22.6	74
09/03/2026	14:30	22.6	75
09/03/2026	14:45	23.2	75
09/03/2026	15:00	24.3	78
09/03/2026	15:15	24.3	74
09/03/2026	15:30	24.5	74

09/03/2026	15:45	24.6	73
09/03/2026	16:00	24.8	72

5. L9_EPR3_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	10:45	26.5	70
04/03/2026	11:00	25.8	71
04/03/2026	11:15	25.8	70
04/03/2026	11:30	25.5	71
04/03/2026	11:45	25.3	71
04/03/2026	12:00	25.2	71
04/03/2026	12:15	25.2	71
04/03/2026	12:30	25.3	70
04/03/2026	12:45	25.1	71
04/03/2026	13:00	25.0	71
04/03/2026	13:15	25.0	71
04/03/2026	13:30	24.9	71
04/03/2026	13:45	25.1	71
04/03/2026	14:00	25.2	68
04/03/2026	14:15	25.3	70
04/03/2026	14:30	25.4	70
04/03/2026	14:45	25.5	68
04/03/2026	15:00	26.1	75
04/03/2026	15:15	23.5	69
04/03/2026	Temp & Humidity Data Logger Start 15:30	19.8	81
04/03/2026	15:45	19.0	84
04/03/2026	16:00	18.6	85
04/03/2026	16:15	18.6	86
04/03/2026	16:30	19.3	89
04/03/2026	16:45	19.8	87
04/03/2026	17:00	19.8	85
04/03/2026	17:15	19.6	85
04/03/2026	17:30	20.0	84
04/03/2026	17:45	20.2	83
04/03/2026	18:00	20.4	82
04/03/2026	18:15	20.5	82
04/03/2026	18:30	20.6	81

04/03/2026	18:45	20.8	81
04/03/2026	19:00	20.9	81
04/03/2026	19:15	20.9	81
04/03/2026	19:30	21.1	81
04/03/2026	19:45	21.1	80
04/03/2026	20:00	21.2	80
04/03/2026	20:15	21.3	80
04/03/2026	20:30	21.4	80
04/03/2026	20:45	21.3	80
04/03/2026	21:00	21.4	80
04/03/2026	21:15	21.5	79
04/03/2026	21:30	21.5	79
04/03/2026	21:45	21.5	79
04/03/2026	22:00	21.6	79
04/03/2026	22:15	21.6	79
04/03/2026	22:30	21.6	79
04/03/2026	22:45	21.6	79
04/03/2026	23:00	21.8	79
04/03/2026	23:15	21.8	79
04/03/2026	23:30	21.8	79
04/03/2026	23:45	21.9	79
05/03/2026	0:00	21.9	80
05/03/2026	0:15	22.0	80
05/03/2026	0:30	22.1	80
05/03/2026	0:45	22.1	80
05/03/2026	1:00	22.1	80
05/03/2026	1:15	22.2	80
05/03/2026	1:30	22.2	81
05/03/2026	1:45	22.3	81
05/03/2026	2:00	22.3	81
05/03/2026	2:15	22.3	81
05/03/2026	2:30	22.3	81
05/03/2026	2:45	22.3	81
05/03/2026	3:00	22.3	81
05/03/2026	3:15	22.4	81
05/03/2026	3:30	22.3	81

05/03/2026	3:45	22.5	81
05/03/2026	4:00	22.5	81
05/03/2026	4:15	22.5	81
05/03/2026	4:30	22.5	81
05/03/2026	4:45	22.6	79
05/03/2026	5:00	22.5	81
05/03/2026	5:15	22.6	80
05/03/2026	5:30	22.8	80
05/03/2026	5:45	22.8	80
05/03/2026	6:00	22.9	80
05/03/2026	6:15	22.8	80
05/03/2026	6:30	22.8	80
05/03/2026	6:45	22.9	80
05/03/2026	7:00	22.9	80
05/03/2026	7:15	22.9	80
05/03/2026	7:30	23.0	80
05/03/2026	7:45	22.9	80
05/03/2026	8:00	22.9	80
05/03/2026	8:15	23.0	79
05/03/2026	8:30	23.0	79
05/03/2026	8:45	23.0	78
05/03/2026	9:00	23.0	77
05/03/2026	9:15	23.0	77
05/03/2026	9:30	23.0	76
05/03/2026	9:45	23.1	76
05/03/2026	10:00	23.1	76
05/03/2026	10:15	23.0	76
05/03/2026	10:30	23.1	76
05/03/2026	10:45	23.1	75
05/03/2026	11:00	23.1	76
05/03/2026	11:15	23.1	75
05/03/2026	11:30	23.1	75
05/03/2026	11:45	23.2	75
05/03/2026	12:00	23.2	75
05/03/2026	12:15	23.2	74
05/03/2026	12:30	21.6	80

05/03/2026	12:45	21.0	81
05/03/2026	13:00	20.5	81
05/03/2026	13:15	20.2	82
05/03/2026	13:30	20.1	83
05/03/2026	13:45	20.0	83
05/03/2026	14:00	19.9	84
05/03/2026	14:15	19.8	84
05/03/2026	14:30	19.6	84
05/03/2026	14:45	19.5	84
05/03/2026	15:00	19.8	85
05/03/2026	15:15	20.0	85
05/03/2026	15:30	20.1	85
05/03/2026	15:45	20.1	84
05/03/2026	16:00	20.1	84
05/03/2026	16:15	20.1	85
05/03/2026	16:30	19.9	84
05/03/2026	16:45	20.3	84
05/03/2026	17:00	20.8	82
05/03/2026	17:15	21.1	81
05/03/2026	17:30	21.4	82
05/03/2026	17:45	21.8	84
05/03/2026	18:00	22.3	85
05/03/2026	18:15	22.4	84
05/03/2026	18:30	22.3	83
05/03/2026	18:45	22.3	82
05/03/2026	19:00	22.3	81
05/03/2026	19:15	22.3	81
05/03/2026	19:30	22.3	81
05/03/2026	19:45	22.3	81
05/03/2026	20:00	22.4	80
05/03/2026	20:15	22.5	80
05/03/2026	20:30	22.5	79
05/03/2026	20:45	22.5	79
05/03/2026	21:00	22.6	77
05/03/2026	21:15	22.6	76
05/03/2026	21:30	22.6	76

05/03/2026	21:45	22.6	76
05/03/2026	22:00	22.8	76
05/03/2026	22:15	22.8	76
05/03/2026	22:30	22.8	76
05/03/2026	22:45	22.6	76
05/03/2026	23:00	22.8	75
05/03/2026	23:15	22.8	75
05/03/2026	23:30	22.9	76
05/03/2026	23:45	22.9	76
06/03/2026	0:00	22.9	76
06/03/2026	0:15	23.0	76
06/03/2026	0:30	23.0	76
06/03/2026	0:45	23.0	77
06/03/2026	1:00	23.1	77
06/03/2026	1:15	23.1	77
06/03/2026	1:30	23.1	77
06/03/2026	1:45	23.2	77
06/03/2026	2:00	23.2	77
06/03/2026	2:15	23.3	77
06/03/2026	2:30	23.2	77
06/03/2026	2:45	23.3	77
06/03/2026	3:00	23.3	78
06/03/2026	3:15	23.3	78
06/03/2026	3:30	23.4	78
06/03/2026	3:45	23.3	78
06/03/2026	4:00	23.4	78
06/03/2026	4:15	23.5	78
06/03/2026	4:30	23.4	78
06/03/2026	4:45	23.5	78
06/03/2026	5:00	23.5	78
06/03/2026	5:15	23.5	78
06/03/2026	5:30	23.6	78
06/03/2026	5:45	23.6	79
06/03/2026	6:00	23.6	79
06/03/2026	6:15	23.6	79
06/03/2026	6:30	23.8	79

06/03/2026	6:45	23.6	79
06/03/2026	7:00	23.8	79
06/03/2026	7:15	23.8	79
06/03/2026	7:30	23.8	79
06/03/2026	7:45	23.8	79
06/03/2026	8:00	23.8	79
06/03/2026	8:15	23.9	79
06/03/2026	8:30	23.8	77
06/03/2026	8:45	23.8	76
06/03/2026	9:00	23.8	76
06/03/2026	9:15	23.9	75
06/03/2026	9:30	23.9	75
06/03/2026	9:45	23.9	75
06/03/2026	10:00	24.0	77
06/03/2026	10:15	24.2	77
06/03/2026	10:30	24.3	77
06/03/2026	10:45	24.4	78
06/03/2026	11:00	24.5	78
06/03/2026	11:15	22.9	76
06/03/2026	11:30	21.8	80
06/03/2026	11:45	21.4	81
06/03/2026	12:00	21.1	81
06/03/2026	12:15	20.8	82
06/03/2026	12:30	20.6	83
06/03/2026	12:45	20.5	83
06/03/2026	13:00	20.5	83
06/03/2026	13:15	20.2	82
06/03/2026	13:30	20.1	82
06/03/2026	13:45	20.0	82
06/03/2026	14:00	19.8	82
06/03/2026	14:15	19.6	82
06/03/2026	14:30	19.8	83
06/03/2026	14:45	19.6	82
06/03/2026	15:00	19.3	82
06/03/2026	15:15	19.2	83
06/03/2026	15:30	19.2	84

06/03/2026	15:45	19.1	84
06/03/2026	16:00	19.2	84
06/03/2026	16:15	19.0	84
06/03/2026	16:30	19.0	84
06/03/2026	16:45	18.9	84
06/03/2026	17:00	18.9	84
06/03/2026	17:15	18.9	84
06/03/2026	17:30	18.6	84
06/03/2026	17:45	18.6	85
06/03/2026	18:00	18.6	85
06/03/2026	18:15	18.6	85
06/03/2026	18:30	18.5	85
06/03/2026	18:45	18.5	85
06/03/2026	19:00	18.3	84
06/03/2026	19:15	18.2	84
06/03/2026	19:30	18.2	85
06/03/2026	19:45	18.3	86
06/03/2026	20:00	18.2	85
06/03/2026	20:15	18.2	85
06/03/2026	20:30	18.2	85
06/03/2026	20:45	18.2	86
06/03/2026	21:00	18.2	86
06/03/2026	21:15	18.2	86
06/03/2026	21:30	18.1	86
06/03/2026	21:45	18.2	86
06/03/2026	22:00	18.0	86
06/03/2026	22:15	18.2	87
06/03/2026	22:30	18.1	86
06/03/2026	22:45	18.1	86
06/03/2026	23:00	18.1	86
06/03/2026	23:15	18.8	92
06/03/2026	23:30	19.8	94
06/03/2026	23:45	20.4	95
07/03/2026	0:00	20.9	95
07/03/2026	0:15	21.3	95
07/03/2026	0:30	21.6	95

07/03/2026	0:45	21.9	94
07/03/2026	1:00	22.1	94
07/03/2026	1:15	22.3	94
07/03/2026	1:30	22.3	94
07/03/2026	1:45	22.5	94
07/03/2026	2:00	22.8	90
07/03/2026	2:15	22.9	90
07/03/2026	2:30	23.0	90
07/03/2026	2:45	23.1	90
07/03/2026	3:00	23.2	89
07/03/2026	3:15	23.3	90
07/03/2026	3:30	23.4	89
07/03/2026	3:45	23.5	89
07/03/2026	4:00	23.6	89
07/03/2026	4:15	23.6	89
07/03/2026	4:30	23.8	89
07/03/2026	4:45	23.8	89
07/03/2026	5:00	23.9	89
07/03/2026	5:15	24.0	89
07/03/2026	5:30	24.1	89
07/03/2026	5:45	24.2	89
07/03/2026	6:00	24.1	89
07/03/2026	6:15	24.2	89
07/03/2026	6:30	24.3	89
07/03/2026	6:45	24.2	89
07/03/2026	7:00	24.3	89
07/03/2026	7:15	23.5	84
07/03/2026	7:30	22.3	85
07/03/2026	7:45	21.6	85
07/03/2026	8:00	21.3	86
07/03/2026	8:15	20.8	84
07/03/2026	8:30	20.3	84
07/03/2026	8:45	20.1	84
07/03/2026	9:00	19.8	84
07/03/2026	9:15	19.8	86
07/03/2026	9:30	19.8	86

07/03/2026	9:45	19.6	86
07/03/2026	10:00	19.5	85
07/03/2026	10:15	19.3	85
07/03/2026	10:30	19.2	85
07/03/2026	10:45	19.1	85
07/03/2026	11:00	19.1	86
07/03/2026	11:15	18.9	85
07/03/2026	11:30	18.9	85
07/03/2026	11:45	18.9	85
07/03/2026	12:00	18.8	85
07/03/2026	12:15	18.6	85
07/03/2026	12:30	18.5	85
07/03/2026	12:45	18.5	85
07/03/2026	13:00	18.5	86
07/03/2026	13:15	18.4	85
07/03/2026	13:30	18.3	85
07/03/2026	13:45	18.5	85
07/03/2026	14:00	18.3	86
07/03/2026	14:15	18.3	86
07/03/2026	14:30	18.2	85
07/03/2026	14:45	18.3	86
07/03/2026	15:00	18.3	86
07/03/2026	15:15	18.2	86
07/03/2026	15:30	18.3	85
07/03/2026	15:45	18.2	85
07/03/2026	16:00	18.0	85
07/03/2026	16:15	18.0	85
07/03/2026	16:30	17.9	85
07/03/2026	16:45	18.0	86
07/03/2026	17:00	17.9	86
07/03/2026	17:15	18.0	86
07/03/2026	17:30	17.9	86
07/03/2026	17:45	17.9	86
07/03/2026	18:00	17.9	86
07/03/2026	18:15	17.9	86
07/03/2026	18:30	17.9	86

07/03/2026	18:45	17.9	86
07/03/2026	19:00	17.9	86
07/03/2026	19:15	17.9	86
07/03/2026	19:30	17.9	86
07/03/2026	19:45	17.8	86
07/03/2026	20:00	17.8	86
07/03/2026	20:15	17.8	86
07/03/2026	20:30	17.8	86
07/03/2026	20:45	17.6	86
07/03/2026	21:00	17.8	86
07/03/2026	21:15	17.6	86
07/03/2026	21:30	17.8	87
07/03/2026	21:45	17.8	87
07/03/2026	22:00	17.8	87
07/03/2026	22:15	17.9	88
07/03/2026	22:30	17.8	87
07/03/2026	22:45	17.9	87
07/03/2026	23:00	17.8	87
07/03/2026	23:15	18.5	92
07/03/2026	23:30	19.5	95
07/03/2026	23:45	20.2	95
08/03/2026	0:00	20.5	95
08/03/2026	0:15	21.0	95
08/03/2026	0:30	21.3	95
08/03/2026	0:45	21.5	95
08/03/2026	1:00	21.8	95
08/03/2026	1:15	21.9	94
08/03/2026	1:30	22.1	94
08/03/2026	1:45	22.3	94
08/03/2026	2:00	22.3	94
08/03/2026	2:15	22.5	94
08/03/2026	2:30	22.6	90
08/03/2026	2:45	22.8	90
08/03/2026	3:00	23.0	90
08/03/2026	3:15	23.0	90
08/03/2026	3:30	23.2	90

08/03/2026	3:45	23.2	89
08/03/2026	4:00	23.3	90
08/03/2026	4:15	23.3	89
08/03/2026	4:30	23.4	89
08/03/2026	4:45	23.5	89
08/03/2026	5:00	23.5	89
08/03/2026	5:15	23.6	89
08/03/2026	5:30	23.8	89
08/03/2026	5:45	23.8	89
08/03/2026	6:00	23.9	89
08/03/2026	6:15	23.9	89
08/03/2026	6:30	24.0	89
08/03/2026	6:45	24.1	89
08/03/2026	7:00	24.1	89
08/03/2026	7:15	23.2	84
08/03/2026	7:30	22.0	85
08/03/2026	7:45	21.2	84
08/03/2026	8:00	20.5	84
08/03/2026	8:15	20.1	84
08/03/2026	8:30	19.9	84
08/03/2026	8:45	19.6	84
08/03/2026	9:00	19.3	85
08/03/2026	9:15	19.3	86
08/03/2026	9:30	19.3	86
08/03/2026	9:45	19.2	86
08/03/2026	10:00	19.1	86
08/03/2026	10:15	19.1	86
08/03/2026	10:30	18.9	86
08/03/2026	10:45	18.9	85
08/03/2026	11:00	18.8	85
08/03/2026	11:15	18.6	86
08/03/2026	11:30	18.6	86
08/03/2026	11:45	18.5	86
08/03/2026	12:00	18.5	85
08/03/2026	12:15	18.5	86
08/03/2026	12:30	18.5	86

08/03/2026	12:45	18.5	86
08/03/2026	13:00	18.4	86
08/03/2026	13:15	18.3	86
08/03/2026	13:30	18.3	86
08/03/2026	13:45	18.4	86
08/03/2026	14:00	18.3	86
08/03/2026	14:15	18.3	86
08/03/2026	14:30	18.3	86
08/03/2026	14:45	18.3	86
08/03/2026	15:00	18.3	86
08/03/2026	15:15	18.3	86
08/03/2026	15:30	18.3	86
08/03/2026	15:45	18.2	86
08/03/2026	16:00	18.2	86
08/03/2026	16:15	18.1	86
08/03/2026	16:30	18.1	86
08/03/2026	16:45	18.1	86
08/03/2026	17:00	18.1	86
08/03/2026	17:15	18.0	86
08/03/2026	17:30	17.9	86
08/03/2026	17:45	17.9	86
08/03/2026	18:00	17.9	86
08/03/2026	18:15	18.0	87
08/03/2026	18:30	18.0	86
08/03/2026	18:45	18.0	86
08/03/2026	19:00	17.8	86
08/03/2026	19:15	17.9	86
08/03/2026	19:30	17.8	86
08/03/2026	19:45	17.8	86
08/03/2026	20:00	17.8	86
08/03/2026	20:15	17.8	86
08/03/2026	20:30	17.8	86
08/03/2026	20:45	17.6	87
08/03/2026	21:00	17.6	87
08/03/2026	21:15	17.8	87
08/03/2026	21:30	17.8	87

08/03/2026	21:45	17.6	87
08/03/2026	22:00	17.8	87
08/03/2026	22:15	17.8	88
08/03/2026	22:30	17.8	87
08/03/2026	22:45	17.9	87
08/03/2026	23:00	17.8	87
08/03/2026	23:15	18.3	92
08/03/2026	23:30	19.4	95
08/03/2026	23:45	20.1	95
09/03/2026	0:00	20.6	96
09/03/2026	0:15	20.9	95
09/03/2026	0:30	21.2	95
09/03/2026	0:45	21.4	95
09/03/2026	1:00	21.6	95
09/03/2026	1:15	21.8	94
09/03/2026	1:30	22.0	94
09/03/2026	1:45	22.2	94
09/03/2026	2:00	22.3	94
09/03/2026	2:15	22.5	93
09/03/2026	2:30	22.6	90
09/03/2026	2:45	22.8	90
09/03/2026	3:00	22.9	90
09/03/2026	3:15	23.0	90
09/03/2026	3:30	23.0	90
09/03/2026	3:45	23.2	90
09/03/2026	4:00	23.2	89
09/03/2026	4:15	23.2	89
09/03/2026	4:30	23.4	89
09/03/2026	4:45	23.5	89
09/03/2026	5:00	23.5	89
09/03/2026	5:15	23.6	89
09/03/2026	5:30	23.6	89
09/03/2026	5:45	23.8	89
09/03/2026	6:00	23.8	89
09/03/2026	6:15	23.9	89
09/03/2026	6:30	23.9	89

09/03/2026	6:45	23.9	89	
09/03/2026	7:00	24.1	89	
09/03/2026	7:15	23.3	85	
09/03/2026	7:30	22.3	87	
09/03/2026	7:45	21.6	87	
09/03/2026	8:00	21.2	86	
09/03/2026	8:15	20.6	85	
09/03/2026	8:30	20.2	85	
09/03/2026	8:45	20.0	85	
09/03/2026	9:00	19.8	84	
09/03/2026	9:15	19.5	86	
09/03/2026	9:30	19.6	86	
09/03/2026	9:45	19.3	86	
09/03/2026	10:00	19.3	86	
09/03/2026	10:15	19.2	86	
09/03/2026	10:30	19.2	86	
09/03/2026	10:45	19.1	86	
09/03/2026	11:00	19.1	86	
09/03/2026	11:15	19.0	86	
09/03/2026	11:30	18.9	86	
09/03/2026	11:45	18.6	85	
09/03/2026	12:00	18.9	86	
09/03/2026	12:15	19.3	87	
09/03/2026	12:30	19.9	86	
09/03/2026	12:45	20.1	85	
09/03/2026	13:00	20.3	84	
09/03/2026	13:15	20.5	84	
09/03/2026	13:30	20.6	85	
09/03/2026	13:45	20.8	84	
09/03/2026	Temp & Humidity Data Logger Ends	14:00	20.9	84
09/03/2026		14:15	21.1	84
09/03/2026		14:30	20.9	82
09/03/2026		14:45	20.2	84
09/03/2026		15:00	24.0	82
09/03/2026		15:15	25.8	74
09/03/2026		15:30	25.2	75

09/03/2026	15:45	25.2	75
09/03/2026	16:00	25.1	75

6. L9_EPR5_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	10:45	26.1	69
04/03/2026	11:00	25.6	70
04/03/2026	11:15	25.5	67
04/03/2026	11:30	25.5	67
04/03/2026	11:45	25.2	69
04/03/2026	12:00	24.9	70
04/03/2026	12:15	25.1	70
04/03/2026	12:30	25.1	70
04/03/2026	12:45	24.8	70
04/03/2026	13:00	24.8	70
04/03/2026	13:15	24.6	70
04/03/2026	13:30	24.6	71
04/03/2026	13:45	24.6	71
04/03/2026	14:00	25.1	69
04/03/2026	14:15	25.2	70
04/03/2026	14:30	25.2	70
04/03/2026	14:45	25.2	67
04/03/2026	15:00	26.1	75
04/03/2026	15:15	22.1	63
04/03/2026	Temp & Humidity Data Logger Start 15:30	20.6	88
04/03/2026	15:45	21.3	93
04/03/2026	16:00	21.9	94
04/03/2026	16:15	22.3	93
04/03/2026	16:30	20.2	69
04/03/2026	16:45	19.1	81
04/03/2026	17:00	20.1	91
04/03/2026	17:15	21.0	94
04/03/2026	17:30	21.6	95
04/03/2026	17:45	22.1	95
04/03/2026	18:00	20.5	72
04/03/2026	18:15	19.1	79
04/03/2026	18:30	20.2	92

04/03/2026	18:45	21.2	95
04/03/2026	19:00	21.9	96
04/03/2026	19:15	22.2	95
04/03/2026	19:30	20.0	70
04/03/2026	19:45	19.5	89
04/03/2026	20:00	20.6	94
04/03/2026	20:15	21.5	96
04/03/2026	20:30	22.1	96
04/03/2026	20:45	21.5	88
04/03/2026	21:00	19.1	73
04/03/2026	21:15	19.8	91
04/03/2026	21:30	20.9	95
04/03/2026	21:45	21.6	96
04/03/2026	22:00	22.2	96
04/03/2026	22:15	21.1	83
04/03/2026	22:30	19.3	82
04/03/2026	22:45	20.3	93
04/03/2026	23:00	21.2	95
04/03/2026	23:15	22.0	96
04/03/2026	23:30	22.5	96
04/03/2026	23:45	22.9	93
05/03/2026	0:00	23.2	93
05/03/2026	0:15	23.5	92
05/03/2026	0:30	23.8	91
05/03/2026	0:45	23.9	91
05/03/2026	1:00	24.0	91
05/03/2026	1:15	24.1	91
05/03/2026	1:30	24.1	90
05/03/2026	1:45	24.2	90
05/03/2026	2:00	24.2	90
05/03/2026	2:15	24.3	89
05/03/2026	2:30	24.3	89
05/03/2026	2:45	24.4	89
05/03/2026	3:00	24.5	89
05/03/2026	3:15	24.5	89
05/03/2026	3:30	24.6	88

05/03/2026	3:45	24.8	88
05/03/2026	4:00	24.8	88
05/03/2026	4:15	24.9	88
05/03/2026	4:30	24.9	87
05/03/2026	4:45	25.0	87
05/03/2026	5:00	25.1	87
05/03/2026	5:15	25.2	87
05/03/2026	5:30	25.2	86
05/03/2026	5:45	25.3	86
05/03/2026	6:00	25.2	86
05/03/2026	6:15	25.4	86
05/03/2026	6:30	25.4	86
05/03/2026	6:45	25.5	86
05/03/2026	7:00	25.5	86
05/03/2026	7:15	24.0	69
05/03/2026	7:30	21.9	74
05/03/2026	7:45	20.5	76
05/03/2026	8:00	19.4	70
05/03/2026	8:15	18.8	80
05/03/2026	8:30	20.2	90
05/03/2026	8:45	21.4	94
05/03/2026	9:00	21.9	92
05/03/2026	9:15	20.1	70
05/03/2026	9:30	18.8	76
05/03/2026	9:45	19.9	90
05/03/2026	10:00	21.0	94
05/03/2026	10:15	21.6	94
05/03/2026	10:30	22.2	94
05/03/2026	10:45	21.3	74
05/03/2026	11:00	19.2	73
05/03/2026	11:15	19.8	89
05/03/2026	11:30	20.8	92
05/03/2026	11:45	21.5	93
05/03/2026	12:00	21.9	92
05/03/2026	12:15	22.3	91
05/03/2026	12:30	22.2	82

05/03/2026	12:45	19.9	73
05/03/2026	13:00	20.2	89
05/03/2026	13:15	21.3	93
05/03/2026	13:30	22.1	94
05/03/2026	13:45	21.3	74
05/03/2026	14:00	20.6	79
05/03/2026	14:15	21.1	80
05/03/2026	14:30	21.5	81
05/03/2026	14:45	21.8	82
05/03/2026	15:00	20.2	67
05/03/2026	15:15	18.8	76
05/03/2026	15:30	20.0	90
05/03/2026	15:45	21.1	94
05/03/2026	16:00	22.0	94
05/03/2026	16:15	21.1	76
05/03/2026	16:30	19.1	75
05/03/2026	16:45	20.1	92
05/03/2026	17:00	21.2	95
05/03/2026	17:15	22.1	96
05/03/2026	17:30	22.2	95
05/03/2026	17:45	19.9	72
05/03/2026	18:00	19.8	89
05/03/2026	18:15	21.1	95
05/03/2026	18:30	21.8	96
05/03/2026	18:45	22.3	96
05/03/2026	19:00	21.6	89
05/03/2026	19:15	19.5	76
05/03/2026	19:30	20.2	92
05/03/2026	19:45	21.2	95
05/03/2026	20:00	21.8	96
05/03/2026	20:15	22.3	96
05/03/2026	20:30	21.1	83
05/03/2026	20:45	19.1	79
05/03/2026	21:00	20.1	92
05/03/2026	21:15	21.1	95
05/03/2026	21:30	21.6	96

05/03/2026	21:45	22.1	96
05/03/2026	22:00	22.2	96
05/03/2026	22:15	20.1	74
05/03/2026	22:30	19.2	87
05/03/2026	22:45	20.4	94
05/03/2026	23:00	21.3	96
05/03/2026	23:15	21.9	96
05/03/2026	23:30	22.4	97
05/03/2026	23:45	22.9	94
06/03/2026	0:00	23.2	93
06/03/2026	0:15	23.3	92
06/03/2026	0:30	23.5	91
06/03/2026	0:45	23.6	91
06/03/2026	1:00	23.6	91
06/03/2026	1:15	23.8	90
06/03/2026	1:30	23.8	90
06/03/2026	1:45	23.9	90
06/03/2026	2:00	24.1	90
06/03/2026	2:15	24.1	90
06/03/2026	2:30	24.1	89
06/03/2026	2:45	24.2	89
06/03/2026	3:00	24.3	89
06/03/2026	3:15	24.3	89
06/03/2026	3:30	24.3	89
06/03/2026	3:45	24.3	89
06/03/2026	4:00	24.5	89
06/03/2026	4:15	24.6	89
06/03/2026	4:30	24.6	88
06/03/2026	4:45	24.6	87
06/03/2026	5:00	24.8	87
06/03/2026	5:15	24.9	87
06/03/2026	5:30	24.9	87
06/03/2026	5:45	24.9	86
06/03/2026	6:00	25.0	86
06/03/2026	6:15	25.0	86
06/03/2026	6:30	25.2	86

06/03/2026	6:45	25.2	86
06/03/2026	7:00	25.2	85
06/03/2026	7:15	23.5	66
06/03/2026	7:30	21.3	74
06/03/2026	7:45	20.0	76
06/03/2026	8:00	19.3	70
06/03/2026	8:15	19.2	85
06/03/2026	8:30	20.5	91
06/03/2026	8:45	21.5	94
06/03/2026	9:00	21.9	91
06/03/2026	9:15	19.8	69
06/03/2026	9:30	19.1	84
06/03/2026	9:45	20.3	93
06/03/2026	10:00	21.4	95
06/03/2026	10:15	22.1	95
06/03/2026	10:30	21.9	87
06/03/2026	10:45	19.6	71
06/03/2026	11:00	19.8	89
06/03/2026	11:15	20.8	94
06/03/2026	11:30	21.5	95
06/03/2026	11:45	22.1	95
06/03/2026	12:00	20.4	71
06/03/2026	12:15	19.0	80
06/03/2026	12:30	20.2	91
06/03/2026	12:45	21.3	94
06/03/2026	13:00	22.0	95
06/03/2026	13:15	22.1	91
06/03/2026	13:30	22.1	90
06/03/2026	13:45	22.2	89
06/03/2026	14:00	22.2	89
06/03/2026	14:15	22.2	89
06/03/2026	14:30	22.3	89
06/03/2026	14:45	22.3	89
06/03/2026	15:00	22.5	89
06/03/2026	15:15	22.5	88
06/03/2026	15:30	22.6	86

06/03/2026	15:45	22.6	85
06/03/2026	16:00	22.6	85
06/03/2026	16:15	22.6	85
06/03/2026	16:30	22.8	85
06/03/2026	16:45	22.8	85
06/03/2026	17:00	22.8	85
06/03/2026	17:15	22.8	85
06/03/2026	17:30	22.9	85
06/03/2026	17:45	22.9	85
06/03/2026	18:00	23.0	85
06/03/2026	18:15	23.1	85
06/03/2026	18:30	23.1	85
06/03/2026	18:45	23.1	85
06/03/2026	19:00	23.1	84
06/03/2026	19:15	23.1	84
06/03/2026	19:30	23.1	84
06/03/2026	19:45	23.1	84
06/03/2026	20:00	23.2	84
06/03/2026	20:15	23.2	84
06/03/2026	20:30	23.2	84
06/03/2026	20:45	23.2	84
06/03/2026	21:00	23.2	84
06/03/2026	21:15	23.3	84
06/03/2026	21:30	23.4	84
06/03/2026	21:45	23.3	84
06/03/2026	22:00	23.3	84
06/03/2026	22:15	23.4	84
06/03/2026	22:30	23.4	84
06/03/2026	22:45	23.3	84
06/03/2026	23:00	23.4	84
06/03/2026	23:15	23.4	84
06/03/2026	23:30	23.4	84
06/03/2026	23:45	23.5	84
07/03/2026	0:00	23.5	84
07/03/2026	0:15	23.5	84
07/03/2026	0:30	23.5	84

07/03/2026	0:45	23.5	84
07/03/2026	1:00	23.5	84
07/03/2026	1:15	23.6	84
07/03/2026	1:30	23.6	84
07/03/2026	1:45	23.8	84
07/03/2026	2:00	23.6	84
07/03/2026	2:15	23.8	84
07/03/2026	2:30	23.8	84
07/03/2026	2:45	23.8	84
07/03/2026	3:00	23.6	84
07/03/2026	3:15	23.8	84
07/03/2026	3:30	23.8	84
07/03/2026	3:45	23.8	84
07/03/2026	4:00	23.9	84
07/03/2026	4:15	23.9	84
07/03/2026	4:30	23.9	84
07/03/2026	4:45	23.8	84
07/03/2026	5:00	24.0	84
07/03/2026	5:15	23.9	84
07/03/2026	5:30	23.9	84
07/03/2026	5:45	24.0	84
07/03/2026	6:00	24.0	84
07/03/2026	6:15	24.1	84
07/03/2026	6:30	24.1	84
07/03/2026	6:45	24.0	84
07/03/2026	7:00	24.1	84
07/03/2026	7:15	24.1	84
07/03/2026	7:30	24.1	84
07/03/2026	7:45	24.1	84
07/03/2026	8:00	24.1	84
07/03/2026	8:15	24.1	84
07/03/2026	8:30	24.1	84
07/03/2026	8:45	24.1	84
07/03/2026	9:00	24.2	84
07/03/2026	9:15	24.2	84
07/03/2026	9:30	24.2	84

07/03/2026	9:45	24.3	84
07/03/2026	10:00	24.2	84
07/03/2026	10:15	24.3	84
07/03/2026	10:30	24.3	84
07/03/2026	10:45	24.3	84
07/03/2026	11:00	24.3	84
07/03/2026	11:15	24.3	83
07/03/2026	11:30	24.3	83
07/03/2026	11:45	24.3	83
07/03/2026	12:00	24.3	83
07/03/2026	12:15	24.3	83
07/03/2026	12:30	24.3	83
07/03/2026	12:45	24.3	83
07/03/2026	13:00	24.3	83
07/03/2026	13:15	24.3	83
07/03/2026	13:30	24.4	83
07/03/2026	13:45	24.4	83
07/03/2026	14:00	24.3	83
07/03/2026	14:15	24.4	83
07/03/2026	14:30	24.5	83
07/03/2026	14:45	24.5	82
07/03/2026	15:00	24.5	82
07/03/2026	15:15	24.4	82
07/03/2026	15:30	24.5	82
07/03/2026	15:45	24.5	82
07/03/2026	16:00	24.5	82
07/03/2026	16:15	24.6	82
07/03/2026	16:30	24.5	82
07/03/2026	16:45	24.5	82
07/03/2026	17:00	24.6	82
07/03/2026	17:15	24.5	82
07/03/2026	17:30	24.6	82
07/03/2026	17:45	24.6	82
07/03/2026	18:00	24.6	81
07/03/2026	18:15	24.6	81
07/03/2026	18:30	24.6	81

07/03/2026	18:45	24.6	81
07/03/2026	19:00	24.6	81
07/03/2026	19:15	24.6	81
07/03/2026	19:30	24.6	81
07/03/2026	19:45	24.8	81
07/03/2026	20:00	24.6	81
07/03/2026	20:15	24.6	81
07/03/2026	20:30	24.8	81
07/03/2026	20:45	24.8	81
07/03/2026	21:00	24.8	81
07/03/2026	21:15	24.8	81
07/03/2026	21:30	24.8	81
07/03/2026	21:45	24.8	81
07/03/2026	22:00	24.8	81
07/03/2026	22:15	24.8	81
07/03/2026	22:30	24.8	81
07/03/2026	22:45	24.8	81
07/03/2026	23:00	24.9	81
07/03/2026	23:15	24.9	81
07/03/2026	23:30	24.9	81
07/03/2026	23:45	24.9	81
08/03/2026	0:00	24.9	81
08/03/2026	0:15	24.9	81
08/03/2026	0:30	24.9	81
08/03/2026	0:45	24.9	81
08/03/2026	1:00	24.9	81
08/03/2026	1:15	24.9	81
08/03/2026	1:30	24.9	81
08/03/2026	1:45	24.9	81
08/03/2026	2:00	25.0	81
08/03/2026	2:15	25.0	81
08/03/2026	2:30	24.9	81
08/03/2026	2:45	25.0	81
08/03/2026	3:00	25.0	81
08/03/2026	3:15	25.0	81
08/03/2026	3:30	25.0	81

08/03/2026	3:45	25.0	81
08/03/2026	4:00	25.0	81
08/03/2026	4:15	25.0	81
08/03/2026	4:30	25.1	81
08/03/2026	4:45	25.1	81
08/03/2026	5:00	25.1	81
08/03/2026	5:15	25.2	81
08/03/2026	5:30	25.1	81
08/03/2026	5:45	25.2	81
08/03/2026	6:00	25.1	81
08/03/2026	6:15	25.1	81
08/03/2026	6:30	25.1	81
08/03/2026	6:45	25.2	81
08/03/2026	7:00	25.2	81
08/03/2026	7:15	25.2	81
08/03/2026	7:30	25.2	81
08/03/2026	7:45	25.2	81
08/03/2026	8:00	25.2	82
08/03/2026	8:15	25.2	82
08/03/2026	8:30	25.2	82
08/03/2026	8:45	25.2	81
08/03/2026	9:00	25.2	81
08/03/2026	9:15	25.2	81
08/03/2026	9:30	25.2	81
08/03/2026	9:45	25.2	81
08/03/2026	10:00	25.2	81
08/03/2026	10:15	25.2	81
08/03/2026	10:30	25.3	81
08/03/2026	10:45	25.2	81
08/03/2026	11:00	25.2	81
08/03/2026	11:15	25.3	81
08/03/2026	11:30	25.3	81
08/03/2026	11:45	25.3	81
08/03/2026	12:00	25.3	80
08/03/2026	12:15	25.3	80
08/03/2026	12:30	25.3	80

08/03/2026	12:45	25.4	80
08/03/2026	13:00	25.3	80
08/03/2026	13:15	25.3	80
08/03/2026	13:30	25.3	80
08/03/2026	13:45	25.4	80
08/03/2026	14:00	25.3	80
08/03/2026	14:15	25.4	80
08/03/2026	14:30	25.4	80
08/03/2026	14:45	25.4	80
08/03/2026	15:00	25.4	80
08/03/2026	15:15	25.4	80
08/03/2026	15:30	25.4	80
08/03/2026	15:45	25.4	80
08/03/2026	16:00	25.5	80
08/03/2026	16:15	25.4	79
08/03/2026	16:30	25.4	79
08/03/2026	16:45	25.4	79
08/03/2026	17:00	25.4	79
08/03/2026	17:15	25.4	79
08/03/2026	17:30	25.4	79
08/03/2026	17:45	25.4	79
08/03/2026	18:00	25.5	79
08/03/2026	18:15	25.5	79
08/03/2026	18:30	25.5	79
08/03/2026	18:45	25.5	79
08/03/2026	19:00	25.5	79
08/03/2026	19:15	25.4	79
08/03/2026	19:30	25.5	79
08/03/2026	19:45	25.5	79
08/03/2026	20:00	25.5	79
08/03/2026	20:15	25.5	79
08/03/2026	20:30	25.6	79
08/03/2026	20:45	25.6	79
08/03/2026	21:00	25.5	79
08/03/2026	21:15	25.5	79
08/03/2026	21:30	25.6	79

08/03/2026	21:45	25.6	79
08/03/2026	22:00	25.6	79
08/03/2026	22:15	25.6	79
08/03/2026	22:30	25.6	79
08/03/2026	22:45	25.6	79
08/03/2026	23:00	25.6	79
08/03/2026	23:15	25.6	79
08/03/2026	23:30	25.6	79
08/03/2026	23:45	25.6	79
09/03/2026	0:00	25.5	79
09/03/2026	0:15	25.6	79
09/03/2026	0:30	25.6	79
09/03/2026	0:45	25.6	79
09/03/2026	1:00	25.6	79
09/03/2026	1:15	25.6	79
09/03/2026	1:30	25.6	79
09/03/2026	1:45	25.6	79
09/03/2026	2:00	25.6	80
09/03/2026	2:15	25.6	80
09/03/2026	2:30	25.8	80
09/03/2026	2:45	25.6	80
09/03/2026	3:00	25.8	80
09/03/2026	3:15	25.8	80
09/03/2026	3:30	25.8	80
09/03/2026	3:45	25.8	80
09/03/2026	4:00	25.8	80
09/03/2026	4:15	25.8	80
09/03/2026	4:30	25.8	80
09/03/2026	4:45	25.9	80
09/03/2026	5:00	25.9	80
09/03/2026	5:15	25.8	80
09/03/2026	5:30	25.8	80
09/03/2026	5:45	25.9	80
09/03/2026	6:00	25.9	80
09/03/2026	6:15	25.9	80
09/03/2026	6:30	25.9	80

09/03/2026	6:45	25.9	80
09/03/2026	7:00	25.9	80
09/03/2026	7:15	25.9	80
09/03/2026	7:30	25.8	80
09/03/2026	7:45	25.9	80
09/03/2026	8:00	26.0	80
09/03/2026	8:15	25.9	80
09/03/2026	8:30	25.9	80
09/03/2026	8:45	25.9	80
09/03/2026	9:00	26.0	80
09/03/2026	9:15	25.9	80
09/03/2026	9:30	26.0	80
09/03/2026	9:45	25.9	80
09/03/2026	10:00	25.9	80
09/03/2026	10:15	25.9	80
09/03/2026	10:30	26.0	80
09/03/2026	10:45	25.9	79
09/03/2026	11:00	25.9	79
09/03/2026	11:15	25.9	79
09/03/2026	11:30	25.9	79
09/03/2026	11:45	25.9	79
09/03/2026	12:00	25.9	79
09/03/2026	12:15	25.9	79
09/03/2026	12:30	25.9	79
09/03/2026	12:45	26.0	79
09/03/2026	13:00	25.9	79
09/03/2026	13:15	25.9	79
09/03/2026	13:30	25.2	61
09/03/2026	13:45	22.5	63
09/03/2026	Temp & Humidity Data Logger Ends 14:00	20.6	60
09/03/2026	14:15	19.6	62
09/03/2026	14:30	18.8	62
09/03/2026	14:45	18.2	62
09/03/2026	15:00	20.0	87
09/03/2026	15:15	23.2	74
09/03/2026	15:30	23.8	73

09/03/2026	15:45	24.1	71
09/03/2026	16:00	24.5	71

7. L9_EPR9_09032026

Timestamp for sample frequency every 15min			
Date	Time	Temperature_Celsius	Relative_Humidity(%)
04/03/2026	10:45	25.8	71
04/03/2026	11:00	25.8	71
04/03/2026	11:15	25.8	71
04/03/2026	11:30	25.6	71
04/03/2026	11:45	25.4	71
04/03/2026	12:00	25.2	71
04/03/2026	12:15	25.4	70
04/03/2026	12:30	25.3	70
04/03/2026	12:45	25.1	70
04/03/2026	13:00	25.1	71
04/03/2026	13:15	25.1	70
04/03/2026	13:30	24.9	71
04/03/2026	13:45	25.1	71
04/03/2026	14:00	25.2	68
04/03/2026	14:15	25.4	70
04/03/2026	14:30	25.4	70
04/03/2026	14:45	25.4	69
04/03/2026	15:00	26.1	76
04/03/2026	15:15	22.0	57
04/03/2026	Temp & Humidity Data Logger Start 15:30	20.4	61
04/03/2026	15:45	20.1	61
04/03/2026	16:00	20.0	61
04/03/2026	16:15	19.9	61
04/03/2026	16:30	20.0	61
04/03/2026	16:45	20.0	61
04/03/2026	17:00	20.1	61
04/03/2026	17:15	20.1	61
04/03/2026	17:30	20.1	62
04/03/2026	17:45	19.8	66
04/03/2026	18:00	20.0	62
04/03/2026	18:15	20.1	62
04/03/2026	18:30	20.0	61

04/03/2026	18:45	19.9	61
04/03/2026	19:00	19.9	61
04/03/2026	19:15	19.9	61
04/03/2026	19:30	21.2	49
04/03/2026	19:45	22.1	44
04/03/2026	20:00	22.6	40
04/03/2026	20:15	21.9	39
04/03/2026	20:30	20.8	37
04/03/2026	20:45	21.2	40
04/03/2026	21:00	22.3	39
04/03/2026	21:15	22.2	36
04/03/2026	21:30	21.0	36
04/03/2026	21:45	20.8	38
04/03/2026	22:00	22.2	36
04/03/2026	22:15	22.1	36
04/03/2026	22:30	20.9	35
04/03/2026	22:45	20.5	36
04/03/2026	23:00	22.0	36
04/03/2026	23:15	22.2	35
04/03/2026	23:30	21.1	35
04/03/2026	23:45	20.3	36
05/03/2026	0:00	21.8	36
05/03/2026	0:15	22.3	35
05/03/2026	0:30	21.1	35
05/03/2026	0:45	20.4	35
05/03/2026	1:00	21.0	37
05/03/2026	1:15	22.4	36
05/03/2026	1:30	21.6	35
05/03/2026	1:45	20.8	35
05/03/2026	2:00	20.2	36
05/03/2026	2:15	21.9	36
05/03/2026	2:30	22.3	35
05/03/2026	2:45	20.8	32
05/03/2026	3:00	21.6	36
05/03/2026	3:15	22.3	35
05/03/2026	3:30	21.2	35

05/03/2026	3:45	20.6	35
05/03/2026	4:00	21.0	36
05/03/2026	4:15	22.3	36
05/03/2026	4:30	21.6	35
05/03/2026	4:45	20.9	35
05/03/2026	5:00	20.3	35
05/03/2026	5:15	22.0	36
05/03/2026	5:30	22.2	35
05/03/2026	5:45	21.1	35
05/03/2026	6:00	20.5	34
05/03/2026	6:15	20.2	36
05/03/2026	6:30	21.9	36
05/03/2026	6:45	22.2	35
05/03/2026	7:00	21.1	35
05/03/2026	7:15	20.5	34
05/03/2026	7:30	20.9	57
05/03/2026	7:45	20.5	73
05/03/2026	8:00	19.8	74
05/03/2026	8:15	19.3	76
05/03/2026	8:30	19.1	77
05/03/2026	8:45	19.0	77
05/03/2026	9:00	18.8	78
05/03/2026	9:15	18.6	79
05/03/2026	9:30	18.6	79
05/03/2026	9:45	18.5	79
05/03/2026	10:00	18.5	78
05/03/2026	10:15	18.3	78
05/03/2026	10:30	18.3	79
05/03/2026	10:45	18.2	79
05/03/2026	11:00	18.3	79
05/03/2026	11:15	18.8	69
05/03/2026	11:30	19.5	62
05/03/2026	11:45	19.6	61
05/03/2026	12:00	19.8	61
05/03/2026	12:15	18.3	75
05/03/2026	12:30	18.0	76

05/03/2026	12:45	17.8	77
05/03/2026	13:00	17.6	77
05/03/2026	13:15	18.8	67
05/03/2026	13:30	19.4	64
05/03/2026	13:45	19.6	62
05/03/2026	14:00	19.8	62
05/03/2026	14:15	19.8	62
05/03/2026	14:30	19.9	61
05/03/2026	14:45	19.9	61
05/03/2026	15:00	19.8	61
05/03/2026	15:15	19.8	61
05/03/2026	15:30	19.8	60
05/03/2026	15:45	19.9	61
05/03/2026	16:00	19.8	61
05/03/2026	16:15	20.0	62
05/03/2026	16:30	19.9	61
05/03/2026	16:45	19.8	60
05/03/2026	17:00	19.9	61
05/03/2026	17:15	19.9	62
05/03/2026	17:30	20.0	62
05/03/2026	17:45	20.1	62
05/03/2026	18:00	20.1	62
05/03/2026	18:15	20.2	62
05/03/2026	18:30	20.1	61
05/03/2026	18:45	20.1	61
05/03/2026	19:00	20.0	61
05/03/2026	19:15	19.9	61
05/03/2026	19:30	21.2	49
05/03/2026	19:45	22.1	45
05/03/2026	20:00	22.6	41
05/03/2026	20:15	21.5	39
05/03/2026	20:30	20.5	40
05/03/2026	20:45	21.6	40
05/03/2026	21:00	22.6	37
05/03/2026	21:15	21.4	36
05/03/2026	21:30	20.3	36

05/03/2026	21:45	21.5	39
05/03/2026	22:00	22.4	38
05/03/2026	22:15	21.3	36
05/03/2026	22:30	20.3	35
05/03/2026	22:45	21.2	37
05/03/2026	23:00	22.3	36
05/03/2026	23:15	21.5	35
05/03/2026	23:30	20.4	35
05/03/2026	23:45	21.3	36
06/03/2026	0:00	22.4	36
06/03/2026	0:15	21.4	35
06/03/2026	0:30	20.5	35
06/03/2026	0:45	20.3	36
06/03/2026	1:00	21.9	35
06/03/2026	1:15	22.2	35
06/03/2026	1:30	21.0	35
06/03/2026	1:45	20.2	34
06/03/2026	2:00	21.3	35
06/03/2026	2:15	22.3	35
06/03/2026	2:30	21.3	35
06/03/2026	2:45	20.5	34
06/03/2026	3:00	21.4	35
06/03/2026	3:15	22.4	35
06/03/2026	3:30	21.3	35
06/03/2026	3:45	20.5	34
06/03/2026	4:00	21.2	35
06/03/2026	4:15	22.5	35
06/03/2026	4:30	21.4	34
06/03/2026	4:45	20.5	34
06/03/2026	5:00	20.6	35
06/03/2026	5:15	22.1	35
06/03/2026	5:30	21.8	35
06/03/2026	5:45	20.8	34
06/03/2026	6:00	20.2	35
06/03/2026	6:15	21.6	35
06/03/2026	6:30	22.3	35

06/03/2026	6:45	21.1	34
06/03/2026	7:00	20.2	34
06/03/2026	7:15	21.1	35
06/03/2026	7:30	21.5	55
06/03/2026	7:45	21.5	60
06/03/2026	8:00	21.5	57
06/03/2026	8:15	21.2	55
06/03/2026	8:30	20.9	55
06/03/2026	8:45	20.6	56
06/03/2026	9:00	20.6	56
06/03/2026	9:15	20.5	57
06/03/2026	9:30	20.4	58
06/03/2026	9:45	20.3	58
06/03/2026	10:00	20.3	58
06/03/2026	10:15	20.3	59
06/03/2026	10:30	20.3	59
06/03/2026	10:45	20.3	59
06/03/2026	11:00	20.3	59
06/03/2026	11:15	20.2	58
06/03/2026	11:30	20.1	59
06/03/2026	11:45	20.1	58
06/03/2026	12:00	20.1	59
06/03/2026	12:15	20.1	59
06/03/2026	12:30	20.1	59
06/03/2026	12:45	20.1	59
06/03/2026	13:00	20.0	57
06/03/2026	13:15	19.9	57
06/03/2026	13:30	19.8	57
06/03/2026	13:45	19.8	57
06/03/2026	14:00	19.6	57
06/03/2026	14:15	19.6	57
06/03/2026	14:30	19.4	57
06/03/2026	14:45	19.5	57
06/03/2026	15:00	19.5	58
06/03/2026	15:15	19.5	59
06/03/2026	15:30	19.6	60

06/03/2026	15:45	19.8	60
06/03/2026	16:00	19.8	60
06/03/2026	16:15	19.8	60
06/03/2026	16:30	19.9	60
06/03/2026	16:45	19.9	61
06/03/2026	17:00	19.9	60
06/03/2026	17:15	19.8	61
06/03/2026	17:30	19.9	61
06/03/2026	17:45	20.0	61
06/03/2026	18:00	20.1	62
06/03/2026	18:15	20.1	62
06/03/2026	18:30	20.1	61
06/03/2026	18:45	20.1	61
06/03/2026	19:00	20.1	61
06/03/2026	19:15	20.1	61
06/03/2026	19:30	21.3	49
06/03/2026	19:45	22.2	44
06/03/2026	20:00	22.6	40
06/03/2026	20:15	21.3	38
06/03/2026	20:30	20.6	41
06/03/2026	20:45	21.9	39
06/03/2026	21:00	22.5	37
06/03/2026	21:15	21.1	36
06/03/2026	21:30	20.8	38
06/03/2026	21:45	22.1	36
06/03/2026	22:00	22.2	36
06/03/2026	22:15	21.0	35
06/03/2026	22:30	21.0	36
06/03/2026	22:45	22.3	36
06/03/2026	23:00	21.8	35
06/03/2026	23:15	20.8	35
06/03/2026	23:30	20.5	36
06/03/2026	23:45	21.9	35
07/03/2026	0:00	22.1	35
07/03/2026	0:15	20.6	34
07/03/2026	0:30	21.6	35

07/03/2026	0:45	22.2	35
07/03/2026	1:00	21.0	34
07/03/2026	1:15	20.6	35
07/03/2026	1:30	22.1	35
07/03/2026	1:45	22.0	35
07/03/2026	2:00	20.9	34
07/03/2026	2:15	20.8	35
07/03/2026	2:30	22.2	35
07/03/2026	2:45	20.8	40
07/03/2026	3:00	21.6	40
07/03/2026	3:15	22.1	36
07/03/2026	3:30	21.0	35
07/03/2026	3:45	20.4	34
07/03/2026	4:00	21.1	36
07/03/2026	4:15	22.5	35
07/03/2026	4:30	21.4	34
07/03/2026	4:45	20.6	34
07/03/2026	5:00	20.6	35
07/03/2026	5:15	22.2	35
07/03/2026	5:30	21.8	42
07/03/2026	5:45	21.9	36
07/03/2026	6:00	21.1	35
07/03/2026	6:15	20.5	35
07/03/2026	6:30	20.6	36
07/03/2026	6:45	22.2	35
07/03/2026	7:00	21.8	35
07/03/2026	7:15	20.9	34
07/03/2026	7:30	21.0	55
07/03/2026	7:45	21.2	59
07/03/2026	8:00	21.5	56
07/03/2026	8:15	21.2	56
07/03/2026	8:30	21.0	56
07/03/2026	8:45	20.9	56
07/03/2026	9:00	20.6	57
07/03/2026	9:15	20.8	60
07/03/2026	9:30	21.1	61

07/03/2026	9:45	21.1	59
07/03/2026	10:00	21.0	59
07/03/2026	10:15	21.0	59
07/03/2026	10:30	20.9	59
07/03/2026	10:45	20.9	59
07/03/2026	11:00	20.9	59
07/03/2026	11:15	20.8	59
07/03/2026	11:30	20.8	58
07/03/2026	11:45	20.8	59
07/03/2026	12:00	20.5	58
07/03/2026	12:15	20.5	58
07/03/2026	12:30	20.4	59
07/03/2026	12:45	20.5	58
07/03/2026	13:00	20.5	58
07/03/2026	13:15	20.3	58
07/03/2026	13:30	20.3	58
07/03/2026	13:45	20.2	57
07/03/2026	14:00	20.2	59
07/03/2026	14:15	20.2	59
07/03/2026	14:30	20.2	58
07/03/2026	14:45	20.2	58
07/03/2026	15:00	20.2	59
07/03/2026	15:15	20.1	58
07/03/2026	15:30	20.1	57
07/03/2026	15:45	20.1	57
07/03/2026	16:00	20.0	57
07/03/2026	16:15	20.1	58
07/03/2026	16:30	20.1	58
07/03/2026	16:45	20.1	59
07/03/2026	17:00	19.9	58
07/03/2026	17:15	19.9	58
07/03/2026	17:30	19.8	59
07/03/2026	17:45	19.9	58
07/03/2026	18:00	19.9	58
07/03/2026	18:15	20.0	59
07/03/2026	18:30	19.9	58

07/03/2026	18:45	20.0	59
07/03/2026	19:00	19.9	60
07/03/2026	19:15	20.1	60
07/03/2026	19:30	21.3	48
07/03/2026	19:45	22.3	42
07/03/2026	20:00	21.5	39
07/03/2026	20:15	21.0	40
07/03/2026	20:30	22.2	39
07/03/2026	20:45	21.6	36
07/03/2026	21:00	20.5	36
07/03/2026	21:15	21.3	37
07/03/2026	21:30	22.2	36
07/03/2026	21:45	21.0	35
07/03/2026	22:00	20.3	35
07/03/2026	22:15	21.5	36
07/03/2026	22:30	21.4	39
07/03/2026	22:45	19.9	44
07/03/2026	23:00	21.9	39
07/03/2026	23:15	21.3	36
07/03/2026	23:30	20.5	35
07/03/2026	23:45	21.2	36
08/03/2026	0:00	22.1	35
08/03/2026	0:15	21.0	35
08/03/2026	0:30	20.3	35
08/03/2026	0:45	21.8	35
08/03/2026	1:00	20.9	40
08/03/2026	1:15	21.2	42
08/03/2026	1:30	21.8	37
08/03/2026	1:45	20.8	35
08/03/2026	2:00	20.3	36
08/03/2026	2:15	21.9	36
08/03/2026	2:30	21.5	35
08/03/2026	2:45	20.6	35
08/03/2026	3:00	21.0	36
08/03/2026	3:15	22.2	35
08/03/2026	3:30	21.1	34

08/03/2026	3:45	20.4	34
08/03/2026	4:00	21.0	35
08/03/2026	4:15	21.9	37
08/03/2026	4:30	20.3	43
08/03/2026	4:45	22.2	37
08/03/2026	5:00	21.2	35
08/03/2026	5:15	20.4	35
08/03/2026	5:30	20.8	36
08/03/2026	5:45	22.2	35
08/03/2026	6:00	21.3	35
08/03/2026	6:15	20.6	34
08/03/2026	6:30	20.3	35
08/03/2026	6:45	22.0	35
08/03/2026	7:00	20.4	40
08/03/2026	7:15	21.6	39
08/03/2026	7:30	21.3	47
08/03/2026	7:45	21.2	57
08/03/2026	8:00	21.1	56
08/03/2026	8:15	21.0	56
08/03/2026	8:30	20.9	56
08/03/2026	8:45	20.8	56
08/03/2026	9:00	20.8	57
08/03/2026	9:15	20.8	59
08/03/2026	9:30	20.9	59
08/03/2026	9:45	20.8	57
08/03/2026	10:00	20.8	59
08/03/2026	10:15	20.6	58
08/03/2026	10:30	20.8	57
08/03/2026	10:45	20.5	57
08/03/2026	11:00	20.6	57
08/03/2026	11:15	20.3	57
08/03/2026	11:30	20.3	57
08/03/2026	11:45	20.2	57
08/03/2026	12:00	20.3	57
08/03/2026	12:15	20.3	57
08/03/2026	12:30	20.2	57

08/03/2026	12:45	20.2	57
08/03/2026	13:00	20.2	57
08/03/2026	13:15	20.2	57
08/03/2026	13:30	20.2	57
08/03/2026	13:45	20.1	57
08/03/2026	14:00	20.1	57
08/03/2026	14:15	20.1	57
08/03/2026	14:30	20.1	57
08/03/2026	14:45	20.1	58
08/03/2026	15:00	20.1	58
08/03/2026	15:15	20.1	57
08/03/2026	15:30	20.1	57
08/03/2026	15:45	19.9	57
08/03/2026	16:00	19.9	57
08/03/2026	16:15	19.9	57
08/03/2026	16:30	19.8	58
08/03/2026	16:45	19.8	57
08/03/2026	17:00	19.9	58
08/03/2026	17:15	19.9	59
08/03/2026	17:30	19.9	57
08/03/2026	17:45	19.9	58
08/03/2026	18:00	19.8	59
08/03/2026	18:15	20.1	60
08/03/2026	18:30	20.1	59
08/03/2026	18:45	20.1	59
08/03/2026	19:00	20.1	59
08/03/2026	19:15	20.1	59
08/03/2026	19:30	21.5	47
08/03/2026	19:45	22.2	42
08/03/2026	20:00	21.1	39
08/03/2026	20:15	21.0	41
08/03/2026	20:30	22.2	39
08/03/2026	20:45	21.3	36
08/03/2026	21:00	21.2	39
08/03/2026	21:15	22.2	36
08/03/2026	21:30	21.1	35

08/03/2026	21:45	20.3	35
08/03/2026	22:00	21.5	36
08/03/2026	22:15	21.9	35
08/03/2026	22:30	20.9	35
08/03/2026	22:45	20.4	36
08/03/2026	23:00	21.9	35
08/03/2026	23:15	21.3	35
08/03/2026	23:30	20.5	34
08/03/2026	23:45	21.0	35
09/03/2026	0:00	21.8	37
09/03/2026	0:15	20.4	43
09/03/2026	0:30	22.1	37
09/03/2026	0:45	21.1	35
09/03/2026	1:00	20.5	35
09/03/2026	1:15	20.9	36
09/03/2026	1:30	22.2	35
09/03/2026	1:45	21.2	34
09/03/2026	2:00	20.5	34
09/03/2026	2:15	20.9	35
09/03/2026	2:30	22.0	36
09/03/2026	2:45	20.3	43
09/03/2026	3:00	22.1	37
09/03/2026	3:15	21.2	35
09/03/2026	3:30	20.5	35
09/03/2026	3:45	20.4	36
09/03/2026	4:00	22.1	35
09/03/2026	4:15	21.5	35
09/03/2026	4:30	20.8	34
09/03/2026	4:45	20.2	32
09/03/2026	5:00	21.5	35
09/03/2026	5:15	21.5	41
09/03/2026	5:30	22.0	38
09/03/2026	5:45	21.1	35
09/03/2026	6:00	20.3	34
09/03/2026	6:15	20.1	35
09/03/2026	6:30	21.8	36

09/03/2026	6:45	21.8	35
09/03/2026	7:00	20.9	34
09/03/2026	7:15	20.2	32
09/03/2026	7:30	20.6	56
09/03/2026	7:45	21.1	60
09/03/2026	8:00	21.3	56
09/03/2026	8:15	21.1	55
09/03/2026	8:30	20.8	56
09/03/2026	8:45	20.6	55
09/03/2026	9:00	20.4	55
09/03/2026	9:15	20.6	60
09/03/2026	9:30	20.8	58
09/03/2026	9:45	20.8	57
09/03/2026	10:00	20.5	57
09/03/2026	10:15	20.5	57
09/03/2026	10:30	20.4	57
09/03/2026	10:45	20.4	57
09/03/2026	11:00	20.2	58
09/03/2026	11:15	20.3	57
09/03/2026	11:30	20.2	56
09/03/2026	11:45	20.3	56
09/03/2026	12:00	20.1	56
09/03/2026	12:15	20.1	56
09/03/2026	12:30	19.8	60
09/03/2026	12:45	18.5	73
09/03/2026	13:00	18.1	75
09/03/2026	13:15	17.9	76
09/03/2026	13:30	17.9	77
09/03/2026	13:45	18.1	80
09/03/2026 Temp & Humidity Data Logger Ends	14:00	18.6	67
09/03/2026	14:15	19.3	62
09/03/2026	14:30	19.5	60
09/03/2026	14:45	19.4	59
09/03/2026	15:00	20.6	84
09/03/2026	15:15	23.8	70
09/03/2026	15:30	24.3	67

09/03/2026	15:45	24.5	66
09/03/2026	16:00	24.6	66